

NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

SUMMARY OF TEST REPORT

TEST REPORT NO: ATS/201106/02

DATE: 19/11/2020

ULR-TC543320000000935P

DISCIPLINE: ELECTRONICS

GROUP: SAFETY TESTING

(Number of Pages in Test Report: Page No. 1 to 107)

TEST FORMAT AS PER IS 13252 (PART 1): 2010+A1:2013+A2:2015/IEC 60950-1:2005+A1: 2009+A2:2013

1. Name of the Manufacturer: GlobTek (Suzhou) Co., Ltd

2. Product: ITE POWER SUPPLY (Power Adaptor for IT Equipment)

3. Model: GT-83084-0806-0.8-USB-W2IN

GlobTek, Inc.

4. Trademark:

5. Model differences provided (if applicable): N/A

6. Model differences verified as per MEITY Guidelines for series formulation: N/A

7 Test Results: Refer below

PARTA: GENERAL

| SL. NO. | TEST REQUIREMENT | TEST CODE | CLAUSE | VERDICT |
|---------|---------------------------|-----------|--------|---------|
| 1. | Components | EL 2100 | 1.5 | Р |
| 2. | Power interface | EL 2101 | 1.6 | Р |
| 3. | Markings and instructions | EL 2102 | 1.7 | Р |

PART B: PROTECTION FROM HAZARDS

| SL. NO. | TEST REQUIREMENT | TEST CODE | CLAUSE | VERDICT |
|---------|--|-----------|--------|---------|
| 1. | Protection from electric shock and energy hazards | EL 2103 | 2.1 | Р |
| 2. | SELV circuits | EL 2104 | 2.2 | Р |
| 3. | TNV circuits | EL 2105 | 2.3 | N/A |
| 4. | Limited current circuits | EL 2106 | 2.4 | Р |
| 5. | Limited power source | EL 2107 | 2.5 | Р |
| 6. | Provisions for earthing and bonding | EL 2108 | 2.6 | N/A |
| 7. | Overcurrent and earth fault protection in primary circuits | EL 2109 | 2.7 | Р |
| 8. | Safety interlocks | EL 2110 | 2.8 | N/A |
| 9. | Electrical insulation | EL 2111 | 2.9 | Р |
| 10. | Clearances, creepage distance and distances through insulation | EL 2112 | 2.10 | Р |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

TEST REPORT NO: ATS/201106/02

DATE: 19/11/2020

PART C: WIRING, CONNECTIONS AND PHYSICAL REQUIREMENTS

| SL. NO | TEST REQUIREMENT | TEST CODE | CLAUSE | VERDICT |
|--------|--|-----------|--------|---------|
| 1. | Wiring, connections and supply | EL 2113 | 3.1 | N/A |
| 2. | Connection to a mains supply | EL 2114 | 3.2 | Р |
| 3. | Wiring terminals for connection of external conductors | EL 2115 | 3.3 | N/A |
| 4. | Disconnections from the main supply | EL 2116 | 3.4 | Р |
| 5. | Interconnection of equipment | EL 2117 | 3.5 | Р |
| 6. | Stability | EL 2118 | 4.1 | N/A |
| 7. | Mechanical strength | EL 2119 | 4.2 | Р |
| 8. | Design and construction | EL 2120 | 4.3 | Р |
| 9. | Protection against hazardous moving parts | EL 2121 | 4.4 | N/A |
| 10. | Thermal requirements | EL 2122 | 4.5 | Р |
| 11. | Openings in enclosures | EL 2123 | 4.6 | N/A |
| 12. | Resistance to fire | EL 2124 | 4.7 | Р |

PART D: ELECTRICAL REQUIREMENTS AND SIMULATED ABNORMAL CONDITIONS

| SL. NO. | TEST REQUIREMENT | TEST CODE | CLAUSE | VERDICT |
|---------|--|-----------|--------|---------|
| 1. | Touch current and protective conductor current | EL 2125 | 5.1 | Р |
| 2. | Electric strength | EL 2126 | 5.2 | Р |
| 3. | Abnormal operating and fault conditions | EL 2127 | 5.3 | Р |

PART E:CONNECTION TO TELECOM AND CABLE DISTRIBUTION SYSTEM

| SL. NO. | TEST REQUIREMENT | TEST CODE | CLAUSE | VERDICT |
|---------|--|-----------|--------|---------|
| 1. | Protection of telecommunication network service persons and users of other equipment connected to the network, from hazards in the equipment | EL 2128 | 6.1 | N/A |
| 2. | Protection of equipment users from overvoltages on telecommunication networks | EL 2129 | 6.2 | N/A |
| 3. | Protection of the telecommunication wiring system from overheating | EL 2130 | 6.3 | N/A |
| 4. | Connection to cable distribution systems | EL 2131 | 7 | N/A |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

TEST REPORT NO: ATS/201106/02

DATE: 19/11/2020

GENERAL INFORMATION:

 The conformity certificates of critical components are verified to ensure complete testing of apparatus under test and details regarding harmonized IEC standards (where IEC standards are not available) are also provided in the list of critical components.

CONCLUSION:

- Sample meets all relevant requirements of IS 13252 (PART 1): 2010+A1:2013+A2:2015/ IEC 60950-1:2005 +A1: 2009+A2:2013
- 2.) Sample fails to meet the following test requirements.

I, hereby undertake that the verdict stated in the test reports for all the test matches with the test results. The sample meets all relevant requirements IS 13252 (PART 1): 2010+A1:2013+A2:2015/ IEC 60950-1:2005 +A1: 2009+A2:2013/ does not meet the requirements. If any deviation found, suitable punitive action may be taken by BIS.

Date: 19/11/2020

(Signature of Authorized person with Stamp)

YAD RAM Head - Laboratory





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Test Report No.: ATS/201106/02

Page 1 of 107

Issue Date: 19/11/2020

ULR-TC543320000000935P

| Manufacturer: | GlobTek (Suzhou) Co., Ltd | | | | |
|---------------------|---|------------------|----------------|--|--|
| | No. 76, Jinling East Road, Suzhou Industrial | Park, China | | | |
| Test item: | ITE POWER SUPPLY (Power Adaptor for IT | Equipment) | | | |
| Identification: | Model: GT-83084-0806-0.8-USB-W2IN | S | erial No.: Nil | | |
| Receipt No.: | 201106/02 | Date of receipt: | 06/11/2020 | | |
| | Accurate Test Solutions | | | | |
| address: | F-21 Sector- 11, Noida-201301, U.P., (INDIA) | | | | |
| Test specification: | IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2 IEC 60950-1: 2005 + A1: 2009 + A2 : 2013 | 2015 / | | | |
| Test Result: | The test item passed / failed the test specific | cation. | | | |
| Other Aspects: | This test report consists of 107 pages. | | | | |

| Tested by: | Approved by / Authorized Signatory: | Issued by: |
|------------------------------|--|-----------------------------|
| Laju | Ilan- | Subli |
| Testing Engineer: Raju Kumar | Head of Laboratory: Yad Ram | Technical Manager : Subhash |
| Date: 19/11/2020 | Date: 19/11/2020 | Date: 19/11/2020 |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No. ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 2 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2: 2013

ULR-TC543320000000935P

TEST REPORT

IS 13252 (Part 1): 2010 + A1: 2013+ A2: 2015 / IEC 60950-1: 2005 + A1: 2009 + A2: 2013

Information technology equipment - Safety -

Part 1: General requirements "Power Adapter for IT Equipment"

Report Reference No...... ATS/201106/02 Date of issue 19/11/2020

Total number of pages 107

Testing Laboratory Accurate Test Solutions

Address F-21, Sector-11, Noida-201301, U.P., (INDIA)

Manufacturer's name GlobTek (Suzhou) Co., Ltd

Address No. 76, Jinling East Road, Suzhou Industrial Park, China

Test specification:

Standard IS 13252 (Part 1): 2010 + A1: 2013+ A2:2015 /

IEC 60950-1: 2005 + A1: 2009 +A2:2013

Test procedure..... Compliance Report

Non-standard test method...... N/A

Test Report Form No...... BIS_IT/PA_IS13252_V1.3 Test Report Form(s) Originator......: Bureau of Indian Standards

Master TRF...... 03/06/2016

Test item description ITE POWER SUPPLY (Power Adaptor for IT Equipment)

Trade Mark:

pm GlobTek, Inc.

Model/Type reference Model: GT-83084-0806-0.8-USB-W2IN

Ratings Input: 100-240V~ 50/60Hz, 0.3A

Output: 5.2V ____ 1.5A 7.8W

Other Documents submitted: Please refer to Table – List of Attachments at Page No. 08

Approved by / Tested by: Issued by: Authorized Signatory: Testing Engineer: Raju Kumar Head of Laboratory: Yad Ram Technical Manager: Subhash Date: 19/11/2020 Date: 19/11/2020 EST Date: 19/11/2020



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 3 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

| Test Code | Description | Measurement/ testing | Total No. of tests | Total no. of applicable tests/ Req. | No. of tests/ Req. passed | Page No. |
|--------------|-------------------------|--|--------------------|-------------------------------------|------------------------------------|-------------|
| EL 2100 | General Requirements | Components (Cl.1.5) | 18 | 05 | 05 | 11-12 |
| EL 2101 | General Requirements | Power interface (CI.1.6) | 05 | 04 | 04 | 13 |
| EL 2102 | Marking Requirements | Marking & instructions(Cl.1.7) | 39 | 15 | 15 | 14-16 |
| EL 2103 | Electrical safety | Protection from electric shock and energy hazards (Cl.2.1) | 14 | 04 | 04 | 17-18 |
| EL 2104 | Electrical safety | SELV Circuits (Cl.2.2) | 04 | 04 | 04 | 19 |
| EL 2105 | Electrical safety | TNV Circuits (CI.2.3) | 12 | 00 | . N/A | 20 |
| EL 2106 | Electrical safety | Limited current circuits (Cl.2.4) | 04 | 04 | 04 | 21 |
| EL 2107 | Electrical safety | Limited Power sources (Cl.2.5) | 07 | 03 | 03 | 22 |
| EL 2108 | Electrical safety | Provisions for earthing and bonding (Cl.2.6) | 19 | 00 | N/A | 23-24 |
| EL 2109 | Electrical safety | Overcurrent and earth fault protection in primary circuits (CI.2.7) | 07 | 04 | 04 | 25 |
| EL 2110 | Electrical safety | Safety Interlocks (Cl.2.8) | 13 | 00 | N/A | 26 |
| EL 2111 | Electrical safety | Electrical Insulation (Cl.2.9) | 05 | 05 | 05 | 27 |
| EL 2112 | Electrical safety | Clearances, Creepage distances and distances through insulation (Cl.2.10) | 63 | 27 | 27 | 28-31 |
| EL 2113 | Wiring | Wiring, connections and supply (Cl.3) | 11 | 01 | 01 | 32 |
| EL 2114 | Wiring | Connection to a main supply (Cl.3.2) | 14 | 02 | 0,2 | 33-34 |
| EL 2115 | Wiring | Wiring terminals for connection of external conductors (Cl.3.3) | 09 | 00 | N/A | 35 |
| EL 2116 | Wiring | Disconnection for the main supply (Cl.3.4) | 12 T.S. | 04 | 04 | 36 |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

| Report No.: | | IS 13252 (Part 1): 2010 + A1: 20 IEC 60950-1: 2005 + A1:2009 | | | Page C5433200000 | e 4 of 107 |
|-------------|--|---|---------------|--------|---------------------|------------|
| Dated. | 19/11/2020 | 1EC 00930-1, 2003 + A1,2003 | 5 1 AZ . 2013 | OLIV-1 | 0010020000 | 3000001 |
| EL 2117 | Wiring | Interconnection of equipment (Cl.3.5) | 05 | 03 | 03 | 37 |
| EL 2118 | Mechanical properties | Stability (Cl.4.1) | 04 | 00 | N/A | 38 |
| EL 2119 | Mechanical properties | Mechanical strength (Cl.4.2) | 13 | 06 | 06 | 39 |
| EL 2120 | Mechanical properties | Design and construction (Cl.4.3) | 25 | 07 | 07 | 40-41 |
| EL 2121 | Mechanical properties | Protection against hazardous moving parts (Cl.4.4) | 14 | 00 | N/A | 42 |
| EL 2122 | Thermal Properties | Thermal requirements (Cl.4.5) | 06 | 06 | 06 | 43 |
| EL 2123 | Mechanical properties | Openings in Enclosures (Cl.4.6) | 18 | 00 | N/A | 44-45 |
| EL 2124 | Fire Safety | Resistance to fire (Cl.4.7) | 25 | 09 | 09 | 46-50 |
| EL 2125 | Insulating properties | Electrical requirements and simulated abnormal conditions(Cl.5),5.1 | 20 | 10 | 10 | 51-52 |
| EL 2126 | Insulating properties | Electric Strength (Cl.5.2) | 03 | 03 | 03 | 53 |
| EL 2127 | Insulating properties | Abnormal operating and fault conditions (CI.5.3) | 11 | 07 | 07 | 54 |
| EL 2128 | Communicating connection | Protection of telecommunication network service persons, and users of other equipment connected to the network, from hazards in the equipment(CI.6.1) | 04 | 00 | N/A | 55-56 |
| EL 2129 | Communicating connection | Protection of equipment users from overvoltages on telecommunication networks (Cl.6.2) | 06 | 00 | N/A | 57 |
| EL 2130 | Communicating connection | Protection of the telecommunication wiring system from overheating (Cl.6.3) | 05 | 00 | N/A | 58-59 |
| EL 2131 | Connection to cable distribution systems | Connection to cable distribution systems (Ci.7) | 08 | 00 | N/A | 60 |
| EL 2132 | Fire safety | Tests for resistance to heat and fire (Annex Alexander) | EST SO | 02 | 02 | 61-62 |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

| Report No.: ATS/201106/02 Dated: 19/11/2020 | | IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / IEC 60950-1: 2005 + A1:2009 + A2 : 2013 | | ULR-T | Page 5 of 107 ULR-TC543320000000935P | | |
|--|------------|--|----|-------|---|-------|--|
| EL 2133 | Insulating | Motor tests under | 19 | 00 | N/A | 63-64 | |

| Dated. | 19/11/2020 | IEC 60950-1: 2005 + A1.2008 | 9 + AZ . 2013 | OLK-1 | 03433200000 | 009331 |
|---------|-------------------------|---|---------------|-------|-------------|--------|
| EL 2133 | Insulating properties | Motor tests under abnormal conditions (Annex B) | 19 | 00 | N/A | 63-64 |
| EL 2134 | Electrical Safety | Transformers (Annex C) | 03 | 03 | 03 | 65 |
| EL 2135 | Insulating properties | Measuring Instruments For Touch-Current Tests (Annex D) | 03 | 02 | 02 | 66 |
| EL 2136 | Thermal Properties | Temperature Rise of A Winding(Annex E) | 01 | 00 | N/A | 67 |
| EL 2137 | Electrical safety | Measurement of Clearances And Creepage Distances (Annex F) | 01 | 01 | 01 | 68 |
| EL 2138 | Electrical safety | Alternative Method For Determining Minimum Clearances (Annex G) | 17 | 00 | N/A | 69-70 |
| EL 2139 | Radiation Safety | Ionizing Radiation (Annex H) | 01 | 00 | N/A | 71 |
| EL 2140 | Electrical Safety | Table of electrochemical potentials (Annex J) | 01 | 00 | N/A | 72 |
| EL 2141 | General Requirements | Thermal controls (Annex K) | 07 | 00 | N/A | 73 |
| EL 2142 | General Requirements | Normal load conditions for some types of electrical business equipment (Annex L) | 08 | 02 | 02 | 74 |
| EL 2143 | Electrical Safety | Criteria for telephone ringing signals (Annex M) | 13 | 00 | N/A | 75 |
| EL 2144 | Electrical safety | Impulse Test Generators(Annex N) | 03 | 00 | N/A | 76 |
| EL 2145 | General Requirements | Normative References (Annex P) | 01 | 00 | N/A | 77 |
| EL 2146 | General Requirements | Voltage dependent resistors (VDRs) (Annex Q) | 03 | 00 | N/A | 78-79 |
| EL 2147 | General Requirements | Examples Of Requirements For Quality Control Programmes (Annex R) | 03 | 00 | N/A | 80 |
| EL 2148 | General Requirements | Procedure For ImpulseST Testing (Annex S) | 04 | 00 | N/A | 81 |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

| Report No.: ATS/201106/02 | IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / | Page 6 of 107 |
|---------------------------|--|------------------------|
| Dated: 19/11/2020 | IEC 60950-1: 2005 + A1:2009 + A2 : 2013 | ULR-TC543320000000935P |

| EL 2149 | L 2149 Protection Guidance on Protection Against Ingress of Water (Annex T) | | 01 | 00 | N/A | 82 |
|---------|--|--|-----|----|-----|-------|
| EL 2150 | 2150 Wiring Insulated Winding Wires For Use Without Interleaved Insulation (Annex U) | | 17 | 00 | N/A | 83-84 |
| EL 2151 | 151 Electrical Ac Power Distribution Systems(Annex V) | | 05 | 03 | 03 | 85 |
| EL 2152 | Electrical Safety | Summation of Touch Currents (Annex W) | 08 | 00 | N/A | 86 |
| EL 2153 | Electrical Safety | Maximum Heating Effect In Transformer Tests (Annex X) | 03 | 03 | 03 | 87 |
| EL 2154 | Radiation safety | Ultraviolet light conditioning test (Annex Y) | 05 | 00 | N/A | 88 |
| EL 2155 | Electrical Safety | Overvoltage Categories (Annex Z) | 01 | 01 | 01 | 89 |
| EL 2156 | Mechanical properties | STATE OF THE PROPERTY OF THE P | | 00 | N/A | 90 |
| EL 2157 | | | -24 | | | |
| EL 2158 | Electrical Safety | Evaluation Of Integrated Circuit (IC) Current Limiters (Annex CC) | 06 | 00 | N/A | 91 |
| EL 2159 | Mechanical properties | Requirements For The Mounting Means Of Rack- Mounted Equipment (Annex DD) | 04 | 00 | N/A | 92 |
| EL 2160 | Electrical Safety | Household And Home/Office Document/Media Shredders (Annex EE) | 06 | 00 | N/A | 93 |

Certificate: It is certified that the above tests were performed and found to be passing/Failing in the requirement tested.







NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 7 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Copy of marking plate:



Marking plate of ITE POWER SUPPLY





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 8 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Table - List of Attachments

| Attachment No. | Attachment Description | No. of pages in Attachment |
|----------------|------------------------|----------------------------|
| Attachment – 1 | Plug Dimension | 106 |
| Attachment – 2 | Photo Document | 107 |

General remarks:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

Possible test case verdicts:

- test object does meet the requirement...... P (Pass)

- test object does not meet the requirement..... F (Fail)

Testing....:

Date of receipt of test item 06/11/2020

Laboratory conditions

Ambient Temperature 25 ± 10°C





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

| I | 10 + A1: 2013 + A2 : 2015 / Page 9 of 107 |
|---|---|
| Dated: 19/11/2020 IEC 60950-1: 2005 | 5 + A1:2009 + A2 : 2013 ULR-TC543320000000935P |
| Test item particularsIT | E POWER SUPPLY (Power Adaptor for IT Equipment) |
| Equipment mobility | movable hand-held transportable stationary for building-in direct plug-in |
| | pluggable equipment type A type B permanent connection detachable power supply cord non-detachable power supply cord not directly connected to the mains |
| Operating condition | continuous rated operating / resting time: |
| Access location | operator accessible restricted access location |
| Over voltage category (OVC) | OVC I OVC II OVC III OVC IV other: |
| Mains supply tolerance (%) or absolute mains supply values1 | 10%, +6% |
| Class of equipment | Class I ⊠ Class II □ Class III Not classified |
| Considered current rating of protective device as a part of the building installation (A) | 6A (for India) |
| Pollution degree (PD) | PD 1 ⊠ PD 2 □ PD 3 |
| IP protection class IF | PX0 |
| Altitude during operation (m) U | p to 4000 |
| Altitude of test laboratory (m) < | 1000 |
| Mass of equipment (kg) 0. | .045Kg |
| Abbreviations that may be used throughout thi | is test report: |
| PE/PB protective earth/protective bondi | ing Pri: primary |
| CB circuit breaker | sec secondary |
| (SW)PS (switching) power supply | gnd ground |
| HV high voltage | I/O: input/output |
| PCB printed circuit (wiring) board | ii: installation instruction |
| TIW: triple insulated wire | PSU: Power Supply Unit |



B/I..... built-in application (compliance shall be guarantee in host equipment)

F/B/S/R: Functional/Basic/Supplementary/Reinforced Insulation



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 10 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

General product information:

1) Application details / Description of the product:

The equipment under the test is Class II direct plug-in "ITE POWER SUPPLY (Power Adaptor for IT Equipment)",

Model: GT-83084-0806-0.8-USB-W2IN

having rated Input: 100-240V~ 50/60Hz, 0.3A

Output: 5.2V === 1.5A 7.8W

Max. specified ambient temperature (°C): 60°C

2) Differences between the models....... N/A

Model No. tested with-in the family series.....: N/A

3) Options:

The equipment was tested without any optional accessory installed. Hence, this report does not cover parameters that are influenced by the installation of optional accessory that might affect safety in the meaning of this standard.





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 11 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to General Requirements

EL 2100 -- V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|-------------|---|---------|
| 1.5 | Components* | EL 2100-00 | Verification of approvals with due correlation between the components used and the approval certificates submitted (Please see the table 1.5.1) | Р |
| 1.5.1 | General: | EL 2100-01 | See below | Р |
| | Components shall be complying with IEC 60950-1 or relevant component standard. | | Component certified with relevant component standard. | Р |
| | Components and subassemblies approved for IEC 62368-1 can be considered as complying with this standard | | | N/A |
| 1.5.2 | Evaluation and testing of components | EL 2100-02 | Components certified to IEC standards and / or their harmonized standards are used within their ratings (see table 1.5.1) | Р |
| 1.5.3 | Thermal controls | EL 2100-03 | No thermal controls used | N/A |
| 1.5.4 | Transformers | EL 2100-04 | See annex C | Р |
| 1.5.5 | Interconnecting cables* | EL 2100-05 | No interconnecting cables | N/A |
| 1.5.6 | Capacitors bridging insulation * | EL 2100-06 | Certified Y capacitor used (See table 1.5.1) | Р |
| 1.5.7 | Resistors bridging insulation | EL 2100-07 | No such insulation | N/A |
| 1.5.7.1 | Resistors bridging functional, basic or supplementary insulation* | EL 2100-08 | See above cl. no. 1.5.7 | N/A |
| 1.5.7.2 | Resistors bridging double or reinforced insulation between a.c. mains and other circuits | EL 2100-09 | See above cl. no. 1.5.7 | N/A |
| 1.5.7.3 | Resistors bridging double insulation or reinforced insulation between the a.c. mains supply and circuits connected to an antenna or coaxial cable | EL 2100-10 | See above cl. no. 1.5.7 | N/A |
| 1.5.8 | Components in equipment for IT power distribution systems* | EL 2100-11 | Not for IT power distribution systems | N/A |
| 1.5.9 | Surge suppressors | EL 2100-12 | No Surge suppressors used | N/A |
| 1.5.9.1 | General* | EL 2100-13 | See above cl no. 1.5.9 | N/A |
| 1.5.9.2 | Protection of VDRs* | EL 2100-14 | See above cl no. 1.5.9 | N/A |
| 1.5.9.3 | Bridging of functional insulation by a VDR* | EL 21005155 | See above cl no. 1.5.9 | N/A |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 Dated: 19/11/2020 IEC 60950-1: 2005 +

IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 /

Page 12 of 107

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to General Requirements

EL 2100 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--------------------------|---------|
| 1.5.9.4 | Bridging of basic insulation by a VDR* | EL 2100-16 | See above cl no. 1.5.9 | N/A |
| 1.5.9.5 | Bridging of supplementary, double or reinforced insulation by a VDR* | I . | See above cl no. 1.5.9 | N/A |

* Total number of Requirements to be observed / inspected = 10
Total No of applicable Requirement = 02
No of Requirements for which the sample passed: = 02

Total number of tests to be conducted : = 08
Total No of applicable Tests = 03
No. of tests for which the sample passed: = 03

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)
SUBHASH
Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 13 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2101 - V1.4

| CI. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---------------------------------------|------------|---|---------|
| 1.6 | Power interface* | EL 2101-00 | 1 | Р |
| 1.6.1 | AC power distribution systems* | EL 2101-01 | TN power distribution systems | Р |
| 1.6.2 | Input current | EL 2101-02 | See table 1.6.2 | Р |
| 1.6.3 | Voltage limit of hand-held equipment* | EL 2101-03 | Not a hand held equipment | N/A |
| 1.6.4 | Neutral conductor * | EL 2101-04 | Neutral conductor is insulated from the body throughout the equipment | Р |

* Total number of Requirements to be observed / inspected = 04
Total No of applicable Requirement = 03
No of Requirements for which the sample passed: = 03

Total number of tests to be conducted : = 01
Total No of applicable Tests = 01
No. of tests for which the sample passed: = 01

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)
SUBHASH

Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 14 of 107

ULR-TC543320000000935P

Tests relating to Marking Requirements

EL 2102 - V1.4

| | | | Will be the second of the seco | |
|---------|---|------------|--|---------|
| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
| 1.7 | Marking and instructions* | EL 2102-00 | | Р |
| 1.7.1 | Power rating and identification markings | | See below | Р |
| 1.7.1.1 | Power rating marking* | EL 2102-01 | See below | Р |
| | Rated voltage(s) or voltage ranges(s) (V)*. | EL 2102-02 | 100-240V~ | Р |
| | Multiple mains supply connections*. | EL 2102-03 | No multiple main supply connection | N/A |
| | Symbol for nature of supply, for d.c. only*: | EL 2102-04 | AC supply | N/A |
| | Rated frequency or rated frequency range (Hz) *: | EL 2102-05 | 50/60Hz | Р |
| | Rated current (mA or A)*: | EL 2102-06 | 0.3A | Р |
| 1.7.1.2 | Identification markings* | EL 2102-07 | See below | Р |
| | Manufacturer's name or trade- mark or identification mark *: | EL 2102-08 | GlobTek, Inc. | Р |
| | Model identification or type reference *: | EL 2102-09 | GT-83084-0806-0.8-USB-W2IN | Р |
| | Symbol for Class II equipment only*: | EL 2102-10 | Symbol marked | Р |
| | Other markings and symbols*: | EL 2102-11 | Other markings and symbols does not give rise to misunderstanding | Р |
| 1.7.1.3 | Use of graphical symbols* | EL 2102-12 | Graphical symbol used | Р |
| 1.7.2 | Safety instructions and marking* | EL 2102-13 | See below | Р |
| 1.7.2.1 | General | EL 2102-14 | Safety instructions provided in instruction manual | Р |
| 1.7.2.2 | Disconnect devices* | EL 2102-15 | Plug is part of direct plug-in equipment, considred as disconnect device | Р |
| 1.7.2.3 | Overcurrent protective devices* | EL 2102-16 | Pluggable equipment TYPE A | N/A |
| 1.7.2.4 | IT power distribution systems* | EL 2102-17 | Not for connection to IT power distribution systems | N/A |
| 1.7.2.5 | Operator access with a tool* | EL 2102-18 | No tools required | N/A |
| 1.7.2.6 | Ozone* | EL 2102-19 | No ozone generated | N/A |
| 1.7.3 | Short duty cycles* | EL 2102-20 | Continuous operation | N/A |
| 1.7.4 | Supply voltage adjustment* | 5(2102-21 | No supply voltage adjustment | N/A |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 15 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Marking Requirements

EL 2102 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--|---------|
| 1.7.5 | Power outlets on the equipment* | EL 2102-22 | No standard power outlets | N/A |
| 1.7.6 | Fuse identification (marking, special fusing characteristics, cross-reference) | EL 2102-23 | Fusible resistor is clearly and adequately marked with fusible resistor number (RF1) | Р |
| | Fuse(s) shall clearly and adequately marked with fuse number and rating*. | | | |
| 1.7.7 | Wiring terminals | EL 2102-24 | See below | N/A |
| 1.7.7.1 | Protective earthing and bonding terminals* | EL 2102-25 | Class II equipment | N/A |
| 1.7.7.2 | Terminals for a.c. mains supply conductors* | EL 2102-26 | Not a permanently connected equipment | N/A |
| 1.7.7.3 | Terminals for d.c. mains supply conductors* | EL 2102-27 | No dc mains supply | N/A |
| 1.7.8 | Controls and indicators | EL 2102-28 | No controls and indicators used | N/A |
| 1.7.8.1 | Identification, location and marking *: | EL 2102-29 | See above cl. no. 1.7.8 | N/A |
| 1.7.8.2 | Colours* | EL 2102-30 | See above cl. no. 1.7.8 | N/A |
| 1.7.8.3 | Symbols according to IEC 60417*: | EL 2102-31 | See above cl. no. 1.7.8 | N/A |
| 1.7.8.4 | Markings using figures* : | EL 2102-32 | No such figures used | N/A |
| 1.7.9 | Isolation of multiple power sources* | EL 2102-33 | No multiple power sources | N/A |
| 1.7.10 | Thermostats and other regulating devices* | EL 2102-34 | No such components used | N/A |
| 1.7.11 | Durability | EL 2102-35 | Marking were legible and durable after the test | Р |
| 1.7.12 | Removable parts* | EL 2102-36 | No such parts | N/A |
| 1.7.13 | Replaceable batteries* | EL 2102-37 | No battery used | N/A |
| | Language(s) | | See above | N/A |
| 1.7.14 | Equipment for restricted access locations* | EL 2102-38 | Equipment not intended to installed in restricted access locations | N/A |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 16 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

* Total number of Requirements to be observed / inspected = 35
Total No of applicable Requirement = 14
No of Requirements for which the sample passed: = 14

Total number of tests to be conducted : = 04
Total No of applicable Tests = 02
No. of tests for which the sample passed: = 02

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 17 of 107

ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2103 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--|---------|
| 2.1 | Protection from electric shock and energy hazards* | EL 2103-00 | | Р |
| 2.1.1 | Protection in operator access areas* | EL 2103-01 | Complies | Р |
| 2.1.1.1 | Access to energized parts | EL 2103-02 | Complies | Р |
| | Test by inspection : | | No hazardous parts are accessible to user | Р |
| | Test with test finger (Figure 2A) | 5a 1 | No access to any parts at hazardous voltage with the test finger | Р |
| | Test with test pin (Figure 2B): | | The test pin cannot touch bare hazardous parts | Р |
| | Test with test probe (Figure 2C) | | Complies | Р |
| 2.1.1.2 | Battery compartments * | EL 2103-03 | No battery compartments | N/A |
| 2.1.1.3 | Access to ELV wiring | EL 2103-04 | No ELV wiring | N/A |
| | Working voltage (Vpeak or Vrms); minimum distance through insulation (mm) | | See above cl. no. 2.1.1.3 | N/A |
| 2.1.1.4 | Access to hazardous voltage circuit wiring | EL 2103-05 | No hazardous voltage circuit wiring | N/A |
| 2.1.1.5 | Energy hazards : | EL 2103-06 | No hazardous energy level (see table 2.1.1.5) | Р |
| 2.1.1.6 | Manual controls | EL 2103-07 | No such controls | N/A |
| 2.1.1.7 | Discharge of capacitors in equipment | | No such construction | N/A |
| | Measured voltage (V); time-constant (s): | EL 2103-08 | See above | N/A |
| 2.1.1.8 | Energy hazards – d.c. mains supply | | No dc mains supply | N/A |
| | a) Capacitor connected to the d.c. mains supply : | EL 2103-09 | See above cl. no. 2.1.1.8 | N/A |
| | b) Internal battery connected to the d.c. mains supply : | EL 2103-10 | See above cl. no. 2.1.1.8 | N/A |
| 2.1.1.9 | Audio amplifiers to be tested according to IEC 60065, cl. 9.1.1.: | EL 2103-11 | No such type device | N/A |
| 2.1.2 | Protection in service access areas | EL 2103-12 | No such area | N/A |
| 2.1.3 | Protection in restricted access locations | EL 2103-13 | Not for restricted access locations | N/A |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 18 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

* Total number of Requirements to be observed / inspected = 03
Total No of applicable Requirement = 02
No of Requirements for which the sample passed: = 02

Total number of tests to be conducted : = 11
Total No of applicable Tests = 02
No. of tests for which the sample passed: = 02

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)
SUBHASH
Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 19 of 107 ULR-TC543320000000935P

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Tests relating to Electrical Safety

EL 2104 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|---|---------|
| 2.2 | SELV circuits* | EL 2104-00 | | Р |
| 2.2.2 | Voltages under normal conditions | EL 2104-01 | Within SELV limit under normal operating conditions (see table 2.2.2) | Р |
| 2.2.3 | Voltages under fault conditions | EL 2104-02 | Within SELV limit under fault conditions (see table 2.2.3) | Р |
| 2.2.4 | Connection of SELV circuits to other circuits*: | EL 2104-03 | SELV to SELV connection only | Р |

* Total number of Requirements to be observed / inspected = 02

Total No of applicable Requirement = 02

No of Requirements for which the sample passed: = 02

Total number of tests to be conducted : = 02

Total No of applicable Tests = 02

No. of tests for which the sample passed: = 02

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

Technical Manager

F-21 SEC-11 NOIDA SO NOIDA



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 20 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2105 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--------------------------|---------|
| 2.3 | TNV circuits* | EL 2105-00 | | N/A |
| 2.3.1 | Type of TNV circuits: TNV-1 / TNV-2 / TNV-3 | EL 2105-01 | No TNV circuits | N/A |
| | a) Limits of TNV-1: | EL 2105-02 | See above cl. no. 2.3.1 | N/A |
| | b) Limits of TNV-2 or TNV-3: Continuous voltages, combination of AC and DC values, are such that : $\frac{U_{ac}}{71} + \frac{U_{oc}}{120} \le 1$ | EL 2105-03 | See above cl. no. 2.3.1 | N/A |
| 2.3.2 | Separation from other circuits and from accessible parts* | EL 2105-04 | See above cl. no. 2.3.1 | N/A |
| 2.3.2.1 | General Requirements | EL 2105-05 | See above cl. no. 2.3.1 | N/A |
| 2.3.2.2 | Protection by basic insulation | EL 2105-06 | See above cl. no. 2.3.1 | N/A |
| 2.3.2.3 | Protection by earthing | EL 2105-07 | See above cl. no. 2.3.1 | N/A |
| 2.3.2.4 | Protection by other constructions : | EL 2105-08 | See above cl. no. 2.3.1 | N/A |
| 2.3.3 | Separation from hazardous voltages | EL 2105-09 | See above cl. no. 2.3.1 | N/A |
| 2.3.4 | Connection of TNV circuits to other circuits | EL 2105-10 | See above cl. no. 2.3.1 | N/A |
| 2.3.5 | Test for operating voltages generated externally | EL 2105-11 | See above cl. no. 2.3.1 | N/A |

* Total number of Requirements to be observed / inspected = 02
Total No of applicable Requirement = 00
No of Requirements for which the sample passed: = N/A
Total number of tests to be conducted : = 10
Total No of applicable Tests = 00
No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)
SUBHASH
Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 21 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2106 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--------------------------------------|---------|
| 2.4 | Limited current circuits * | EL 2106-00 | | Р |
| 2.4.1 | General requirements * | EL 2106-01 | See Below | Р |
| 2.4.2 | Limit values | EL 2106-02 | See table 2.4.2 | Р |
| 2.4.3 | Connection of limited current circuits to other circuits* | EL 2106-03 | SELV to SELV circuit connection only | Р |

* Total number of Requirements to be observed / inspected = 03

Total No of applicable Requirement = 03

No of Requirements for which the sample passed: = 03

Total number of tests to be conducted : = 01

Total No of applicable Tests = 01

No. of tests for which the sample passed: = 01

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH

Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 22 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2107 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|------------------------------|---------|
| 2.5 | Limited power sources * | EL 2107-00 | See below | Р |
| | a) Inherently limited output | EL 2107-01 | No inherently limited output | N/A |
| | b) Impedance limited output | EL 2107-02 | No impedance limited output | N/A |
| | c) Regulating network limited output under normal operating and single fault condition | EL 2107-03 | See table 2.5 | Р |
| | Use of integrated circuit (IC) current limiters | | | |
| | d) Overcurrent protective device limited output | EL 2107-04 | No such protective device | N/A |
| | Max. output voltage (V), Max. output current (A), Max. apparent power (VA) | EL 2107-05 | See table 2.5 | Р |
| | Current rating of overcurrent protective device (A) | EL 2107-06 | See above cl. no. 2.5 d) | N/A |

*Total number of Requirements to be observed / inspected = 01

Total No of applicable Requirement = 01

No of Requirements for which the sample passed: = 01

Total number of tests to be conducted : = 06

Total No of applicable Tests = 02

No. of tests for which the sample passed: = 02

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH

Technical Manager



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 23 of 107 ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2108 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--------------------------|---------|
| 2.6 | Provisions for earthing and bonding* | EL 2108-00 | Class II equipment | N/A |
| 2.6.1 | Protective earthing | EL 2108-01 | See above Cl. No. 2.6 | N/A |
| 2.6.2 | Functional earthing: The Functional earthing either separated from hazardous voltages by double or reinforced insulation or by protectively earthed screen or conductive part separated by at least basic insulation, or safely connected to Protective Bonding Conductor.* | EL 2108-02 | See above Cl. No. 2.6 | N/A |
| | Use of symbol for functional earthing:* | EL 2108-03 | See above Cl. No. 2.6 | N/A |
| 2.6.3 | Protective earthing and protective bonding conductors* | EL 2108-04 | See above Cl. No. 2.6 | N/A |
| 2.6.3.2 | Size of protective earthing conductors | EL 2108-05 | See above Cl. No. 2.6 | N/A |
| | Rated current (A), cross-sectional area (mm2), | | See above Cl. No. 2.6 | N/A |
| 2.6.3.3 | Size of protective bonding conductors | EL 2108-06 | See above Cl. No. 2.6 | N/A |
| | Protective current Rating(A), cross- sectional area (mm2) | | See above Cl. No. 2.6 | N/A |
| 2.6.3.4 | Resistance of earthing conductors and their terminations; resistance (Ω), voltage drop (V), test current (A), duration (min): | EL 2108-07 | See above Cl. No. 2.6 | N/A |
| 2.6.3.5 | Colour of insulation*: | EL 2108-08 | See above Cl. No. 2.6 | N/A |
| 2.6.4 | Terminals | | See above Cl. No. 2.6 | N/A |
| 2.6.4.2 | Protective earthing and bonding terminals: Rated current(A), Type, Nominal thread diameter (mm) | EL 2108-09 | See above Cl. No. 2.6 | N/A |
| 2.6.4.3 | Separation of the protective earthing conductor from protective bonding conductors* | EL 2108-10 | See above Cl. No. 2.6 | N/A |
| 2.6.5 | Integrity of protective earthing* | | See above Cl. No. 2.6 | N/A |
| 2.6.5.1 | Interconnection of equipment* | EL 2108-11 | See above Cl. No. 2.6 | N/A |
| 2.6.5.2 | Components in protective earthing conductors and protective bonding conductors* | EL 2108-12 | See above Cl. No. 2.6 | N/A |
| 2.6.5.3 | Disconnection of protective earth* | EL 2108-13 | See above Cl. No. 2.6 | N/A |

SEC-11 ST AJU



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 24 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| 2.6.5.4 | Parts that can be removed by an operator* | EL 2108-14 | See above Cl. No. 2.6 | N/A |
|---------|---|------------|-----------------------|-----|
| 2.6.5.5 | Parts removed during servicing* | EL 2108-15 | See above Cl. No. 2.6 | N/A |
| 2.6.5.6 | Corrosion resistance* | EL 2108-16 | See above Cl. No. 2.6 | N/A |
| 2.6.5.7 | Screws for protective bonding* | EL 2108-17 | See above Cl. No. 2.6 | N/A |
| 2.6.5.8 | Reliance on telecommunication network or cable distribution system* | EL 2108-18 | See above Cl. No. 2.6 | N/A |

*- Total number of Requirements to be observed / inspected = 14

Total No of applicable Requirement = 00

No of Requirements for which the sample passed =N/A

Total number of tests to be conducted = 05

Total No of applicable Tests = 00

No. of tests for which the sample passed = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH

Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 25 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2109 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|---|---------|
| 2.7 | Overcurrent and earth fault protection in primary circuits* | EL 2109-00 | | Р |
| 2.7.1 | Basic requirements: Protection in primary circuits against overcurrents, short-circuits and earth faults shall be provided, either as an integral part of the equipment or as part of building installation. | EL 2109-01 | The equipment relies on Fusible resistor. A built-in Fusible resistor (RF1) provided as an overcurrent protection device | P |
| | If pluggable equipment Type B or permanently connected equipment relies on protective device external to the equipment for protection, the equipment installation Instructions shall so state and shall also specify the requirements for short-circuit protection or overcurrent protection or, where necessary, for both. | | Pluggable equipment Type A | N/A |
| 2.7.2 | Faults not simulated in 5.3.7* need not be fitted as an integral part of the equipment | EL 2109-02 | No such protection as integral part of the equipment | N/A |
| 2.7.3 | Short-circuit backup protection | EL 2109-03 | The building installation is considered as providing short circuit backup protection | Р |
| 2.7.4 | Number and location of protective devices : | EL 2109-04 | One Fusible resistor (RF1) used in Line | Р |
| 2.7.5 | Protection by several devices* | EL 2109-05 | Protection by single devices | N/A |
| 2.7.6 | Warning to service personnel*: | EL 2109-06 | No such warning required | N/A |

* Total number of Requirements to be observed / inspected = 04
Total No of applicable Requirement = 01

No of Requirements for which the sample passed: = 01

Total number of tests to be conducted : = 03
Total No of applicable Tests = 03

No. of tests for which the sample passed: = 03

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)
SUBHASH
Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 26 of 107 ULR-TC543320000000935P

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Tests relating to Electrical Safety

EL 2110 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--------------------------|---------|
| 2.8 | Safety Interlocks* | EL 2110-00 | | N/A |
| 2.8.1 | General principles* | EL 2110-01 | No safety interlocks | N/A |
| 2.8.2 | Protection requirements | EL 2110-02 | See above cl. no. 2.8.1 | N/A |
| 2.8.3 | Inadvertent reactivation | EL 2110-03 | See above cl. no. 2.8.1 | N/A |
| 2.8.4 | Fail-safe operation | EL 2110-04 | See above cl. no. 2.8.1 | N/A |
| 2.8.5 | Moving parts | EL 2110-05 | | N/A |
| 2.8.6 | Overriding* | EL 2110-06 | See above cl. no. 2.8.1 | N/A |
| 2.8.7 | Switches, relays and their related circuits | EL 2110-07 | See above cl. no. 2.8.1 | N/A |
| 2.8.7.1 | Separation distances for contact gaps and their related circuits' | EL 2110-08 | See above cl. no. 2.8.1 | N/A |
| 2.8.7.2 | Overload test | EL 2110-09 | See above cl. no. 2.8.1 | N/A |
| 2.8.7.3 | Endurance test | EL 2110-10 | | N/A |
| 2.8.7.4 | Electric strength test | EL 2110-11 | See above cl. no. 2.8.1 | N/A |
| 2.8.8 | Mechanical actuators | EL 2110-12 | See above cl. no. 2.8.1 | N/A |

* Total number of Requirements to be observed / inspected = 03

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 10

Total No of applicable Tests = 00

Total No of applicable Tests = 00
No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

Technical Manager

F-21 SEC-11 TO NOIDA



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 /

Page 27 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2111 - V1.4

| CI. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|---|---------|
| 2.9 | Electrical insulation* | EL 2111-00 | | Р |
| 2.9.1 | Properties of insulating materials* | EL 2111-01 | Natural rubber, materials, containing asbestos and hygroscopic materials are not used | Р |
| 2.9.2 | Humidity conditioning | EL 2111-02 | See below | Р |
| | Relative Humidity: 93 ±3 %, Temperature: t at 40 ± 2°C Duration: 120 hours | | Relative humidity: 93% Temperature: 40°C, Tested for 120 Hours. | Р |
| 2.9.3 | Grade of insulation* | EL 2111-03 | Primary- secondary: Reinforced insulation Other: Functional insulation | Р |
| 2.9.4 | Separation from hazardous voltages* | EL 2111-04 | See below | Р |
| | Method(s) used | | Method 1 (b) used | P |

* Total number of Requirements to be observed / inspected = 04

Total No of applicable Requirement = 04

No of Requirements for which the sample passed: = 04

Total number of tests to be conducted : = 01

Total No of applicable Tests = 01

No. of tests for which the sample passed: = 01

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH

Technical Manager



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 28 of 107

ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2112 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|----------|--|------------|--|---------|
| 2.10 | Clearances, creepage distances and distances through Insulation* | EL 2112-00 | | Р |
| 2.10.1.1 | Frequency * | EL 2112-01 | 50/60Hz | Р |
| 2.10.1.2 | Pollution degrees* | EL 2112-02 | Pollution degree 2 | Р |
| 2.10.1.3 | Reduced values for functional insulation | EL 2112-03 | Functional insulations complies with requirements of cl. no 5.3.4 c) | Р |
| 2.10.1.4 | Intervening unconnected conductive parts | EL 2112-04 | No such transformer used | N/A |
| 2.10.1.5 | Insulation with varying dimensions | EL 2112-05 | No such transformer | N/A |
| 2.10.1.6 | Special separation requirements | EL 2112-06 | Special separation not used | N/A |
| 2.10.1.7 | Insulation in circuits generating starting pulses | EL 2112-07 | No such circuits | N/A |
| 2.10.2 | Determination of working voltage | EL 2112-08 | See table 2.10.2 | Р |
| 2.10.2.2 | RMS working voltage | EL 2112-09 | See above cl. no. 2.10.2 | Р |
| 2.10.2.3 | Peak working voltage | EL 2112-10 | See above cl. no. 2.10.2 | Р |
| 2.10.3 | Clearances | EL 2112-11 | See below cl. no. 2.10.3.2 to 2.10.3.9 | Р |
| 2.10.3.1 | General | EL 2112-12 | See below | Р |
| 2.10.3.2 | Mains transient voltages* | | See below | Р |
| | a) AC mains supply *: | EL 2112-13 | Overvoltage category II, mains transient voltage 2500Vpeak | Р |
| | b) Earthed d.c. mains supplies* | EL 2112-14 | No dc mains supply | N/A |
| | c) Unearthed d.c. mains supplies*: | EL 2112-15 | No dc mains supply | N/A |
| | d) Battery operation*: | EL 2112-16 | No battery used | N/A |
| 2.10.3.3 | Clearances in primary circuits | EL 2112-17 | See table 2.10.3 and 2.10.4 | Р |
| 2.10.3.4 | Clearances in secondary circuits | EL 2112-18 | Complied with cl. no. 5.3.4 c) | Р |
| 2.10.3.5 | Clearances in circuits having starting pulses | EL 2112-19 | No such circuits | N/A |
| 2.10.3.6 | Transients from a.c. mains supply: | EL 2112-20 | Considered 2500Vpeak | Р |
| 2.10.3.7 | Transients from d.c. mains supply : | EL 2112-21 | No dc mains supply | N/A |

F-21 SEC-11 NOIDA

-11 E | 0



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 29 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| 2.10.3.8 | Transients from telecommunication networks and cable distribution systems : | EL 2112-22 | No telecommunication network and cable distribution systems | N/A |
|-----------|---|------------|---|-----|
| 2.10.3.9 | Measurement of transient voltages | | See below | N/A |
| | a) Transients from a mains supply | EL 2112-23 | See below | N/A |
| | For an a.c. mains supply | | Considered 2500Vpeak | N/A |
| | For a d.c. mains supply | | No dc mains supply | N/A |
| | b) Transients from a telecommunication network | EL 2112-24 | No telecommunication network | N/A |
| 2.10.4 | Creepage distances* | EL 2112-25 | See below cl. no. 2.10.4.2 to 2.10.4.3 | Р |
| 2.10.4.1 | General | EL 2112-26 | See below | Р |
| 2.10.4.2 | Material group and comparative tracking index : CTI tests* | EL 2112-27 | Material group IIIb assumed | Р |
| 2.10.4.3 | Minimum creepage distances | EL 2112-28 | See table 2.10.3 and 2.10.4 | Р |
| 2.10.5 | Solid insulation | EL 2112-29 | See below | Р |
| 2.10.5.1 | General | EL 2112-30 | See below | Р |
| 2.10.5.2 | Distances through insulation | EL 2112-31 | See table 2.10.5 | Р |
| 2.10.5.3 | Insulating compound as solid insulation | EL 2112-32 | See table 2.10.5 | Р |
| 2.10.5.4 | Semiconductor devices | EL 2112-33 | | N/A |
| 2.10.5.5. | Cemented joints | EL 2112-34 | No cemented joints used | N/A |
| 2.10.5.6 | Thin sheet material - General | EL 2112-35 | | N/A |
| 2.10.5.7 | Separable thin sheet material | EL 2112-36 | Reinforced insulation | Р |
| 2.10.5.8 | Non-separable thin sheet material | EL 2112-37 | Separable thin sheet material | N/A |
| 2.10.5.9 | Thin sheet material – standard test procedure | EL 2112-38 | Alternate test procedure used | N/A |
| | Electric strength test as per CI.5.2.2 | | See above cl. no. 2.10.5.9 | N/A |
| 2.10.5.10 | Thin sheet material – alternative test procedure | EL 2112-39 | Electric strength test applied to double layer of the insulation tape | Р |
| | Electric strength test as per Cl.5.2.2 | | See table 5.2 | Р |
| 2.10.5.11 | Insulation in wound components | EL 2112-40 | Electric strength test applied on transformer | Р |
| 2.10.5.12 | Wire in wound components | CECT | See below | Р |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 30 of 107
Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| | If Peak Working voltage >71 V | .3 | Working voltage exceeded 71 V peak | Р |
|-----------|---|------------|--|-----|
| | a) Basic insulation not under stress | EL 2112-41 | No such insulation | N/A |
| | b) Basic, supplementary, reinforced insulation | EL 2112-42 | Reinforced insulation used | Р |
| | c) Compliance with Annex U | EL 2112-43 | Approved triple insulated wire used | Р |
| | d) Where two winding wires in contact inside wound component; angle between 45° and 90° | EL 2112-44 | Insulating layers used at crossover point. | Р |
| 2.10.5.13 | Wire with solvent-based enamel in wound components | | Not used | N/A |
| | a) Electric strength test (Type test as per Cl.5.2.2) | EL 2112-45 | See above cl. no. 2.10.5.13 | N/A |
| | b) Electric Strength test (Routine test as per Cl.5.2.2) | EL 2112-46 | See above cl. no. 2.10.5.13 | N/A |
| 2.10.5.14 | Additional insulation in wound components | | No such additional components | N/A |
| | If Peak Working Voltage >71V | | See above cl. no. 2.10.5.14 | N/A |
| | a) Basic insulation not under stress | EL 2112-47 | See above cl. no. 2.10.5.14 | N/A |
| | b) Supplementary, reinforced insulation | EL 2112-48 | See above cl. no. 2.10.5.14 | N/A |
| 2.10.6 | Construction of printed boards* | | Uncoated printed boards used | Р |
| 2.10.6.1 | Uncoated printed boards | EL 2112-49 | See table 2.10.3 to 2.10.4 | Р |
| 2.10.6.2 | Coated printed boards | EL 2112-50 | Not used | N/A |
| 2.10.6.3 | Insulation between conductors on the same inner surface of a printed board | EL 2112-51 | No such construction | N/A |
| 2.10.6.4 | Insulation between conductors on different surfaces of a printed board* | | See above cl. no. 2.10.6.3 | N/A |
| | a) Minimum Thickness of insulation: 0.4mm or | EL 2112-52 | See above cl. no. 2.10.6.3 | N/A |
| | b) Confirm with one of the specification and pass the relevant tests as per Table 2R | EL 2112-53 | See above cl. no. 2.10.6.3 | N/A |
| 2.10.7 | Component external terminations | EL 2112-54 | No external termination used | N/A |
| 2.10.8 | Tests on coated printed boards and coated components | E TEST SO | Uncoated printed boards used | N/A |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

| Report No.: ATS/201106/02 | IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 / | Page 31 of 107 |
|---------------------------|---|------------------------|
| Dated: 19/11/2020 | IEC 60950-1: 2005 + A1:2009 + A2 : 2013 | ULR-TC543320000000935P |

| 2.10.8.1 | Sample preparation and preliminary inspection* | EL 2112-55 | See above cl. no. 2.10.8 | N/A |
|----------|---|------------|------------------------------|-----|
| 2.10.8.2 | Thermal conditioning | EL 2112-56 | See above cl. no. 2.10.8 | N/A |
| 2.10.8.3 | Electric strength test | EL 2112-57 | See above cl. no. 2.10.8 | N/A |
| 2.10.8.4 | Abrasion resistance test | EL 2112-58 | See above cl. no. 2.10.8 | N/A |
| 2.10.9 | Thermal cycling | EL 2112-59 | Not used | N/A |
| 2.10.10 | Test for Pollution Degree 1 environment and insulating compound | EL 2112-60 | Pollution degree 2 | N/A |
| 2.10.11 | Tests for semiconductor devices and cemented joints | EL 2112-61 | | N/A |
| 2.10.12 | Enclosed and sealed parts | EL 2112-62 | No enclosed and sealed parts | N/A |

* Total number of Requirements to be observed / inspected = 10

Total No of applicable Requirement = 07

No of Requirements for which the sample passed: = 07

Total number of tests to be conducted : = 53
Total No of applicable Tests = 19

No. of tests for which the sample passed: = 19

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 32 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Wiring

EL 2113 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|---|---------|
| 3.0 | Wiring, connections and supply* | EL 2113-00 | See below | Р |
| 3.1.1 | Current rating and overcurrent protection | EL 2113-01 | No internal wiring | N/A |
| 3.1.2 | Protection against mechanical damage* | EL 2113-02 | No internal wiring | N/A |
| 3.1.3 | Securing of internal wiring* | EL 2113-03 | No internal wiring | N/A |
| 3.1.4 | Insulation of conductors | EL 2113-04 | | N/A |
| 3.1.5 | Beads and ceramic insulators | EL 2113-05 | Beads and ceramic insulators are not used | N/A |
| 3.1.6 | Screws for electrical contact pressure* | EL 2113-06 | No such screws used | N/A |
| 3.1.7 | Insulating materials in electrical connections* | EL 2113-07 | No Insulating materials in electrical connections | N/A |
| 3.1.8 | Self-tapping and spaced thread screws* | EL 2113-08 | No such screws used | N/A |
| 3.1.9 | Termination of conductors : 10 N pull test | EL 2113-09 | | N/A |
| 3.1.10 | Sleeving on wiring* | EL 2113-10 | No sleeving used | N/A |

*Total number of Requirements to be observed / inspected = 07

Total No of applicable Requirement = 01

No of Requirements for which the sample passed: = 01

Total number of tests to be conducted : = 04

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager F-21 SEC-11 ON NOIDA NOIDA



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 33 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Wiring

EL 2114 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--|---------|
| 3.2 | Connection to a mains supply* | EL 2114-00 | | Р |
| 3.2.1 | Means of connection | | See below | Р |
| 3.2.1.1 | Connection to an a.c. mains supply* | EL 2114-01 | Plug is part of direct plug-in equipment, considred as disconnect device | Р |
| 3.2.1.2 | Connection to a d.c. mains supply* | EL 2114-02 | No dc mains supply | N/A |
| 3.2.2 | Multiple supply connections | EL 2114-03 | No multiple supply connections | N/A |
| 3.2.3 | Permanently connected equipment | EL 2114-04 | Not a permanently connected equipment | N/A |
| 3.2.4 | Appliance inlets: Are so Located that parts at hazardous voltage are not accessible during insertion or removal of the connector, connector can be inserted without difficulty and after insertion of the connector, the equipment is not supported by the connector for any position of normal use on a flat surface (appliance inlets complying with IEC 60309 or IEC 60320 considered to comply with this requirement. | | Appliance inlet not used | N/A |
| 3.2.5 | Power supply cords | | Power supply cord set not used | N/A |
| 3.2.5.1 | AC power supply cords* | EL 2114-06 | See above cl. no. 3.2.5 | N/A |
| | Rated current (A), cross-sectional area (mm²), AWG | | See above cl. no. 3.2.5 | N/A |
| 3.2.5.2 | DC power supply cords* | EL 2114-07 | See above cl. no. 3.2.5 | N/A |
| 3.2.6 | Cord anchorages and strain relief | | See above cl. no. 3.2.5 | N/A |
| | Mass of the equipment: Pull Force (N): | EL 2114-08 | See above cl. no. 3.2.5 | N/A |
| | b) Longitudinal displacement: 2 mm (Max) | EL 2114-09 | See above cl. no. 3.2.5 | N/A |
| 3.2.7 | Protection against mechanical damage | EL 2114-10 | No sharp point &cutting edge | Р |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

| Report No.: ATS/201106/02 | IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / | Page 34 of 107 |
|---------------------------|--|------------------------|
| Dated: 19/11/2020 | IEC 60950-1: 2005 + A1:2009 + A2 : 2013 | ULR-TC543320000000935P |

| 3.2.8 | Cord guards | | See above cl. no. 3.2.5 | N/A |
|-------|---|------------|-------------------------|-----|
| | a) Diameter or minor dimension D (mm): Test mass (g): | EL 2114-11 | See above cl. no. 3.2.5 | N/A |
| | b) Radius of curvature of cord : 1.5 D (Min) | EL 2114-12 | See above cl. no. 3.2.5 | N/A |
| 3.2.9 | Supply wiring space | EL 2114-13 | See above cl. no. 3.2.5 | N/A |

| * Total number of Requirements to be observed / inspected | = 04 |
|---|------|
| Total No of applicable Requirement | = 02 |
| No of Requirements for which the sample passed: | = 02 |

| Total number of tests to be conducted : | = 10 |
|---|------|
| Total No of applicable Tests | = 01 |
| No. of tests for which the sample passed: | = 01 |

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

. 2012

Page 35 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Wiring

EL 2115 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--------------------------|---------|
| 3.3 | Wiring terminals for connection of external conductors* | EL 2115-00 | | N/A |
| 3.3.1 | Wiring terminals* | EL 2115-01 | No wiring terminals | N/A |
| 3.3.2 | Connection of non-detachable power supply cords | EL 2115-02 | See above cl. no. 3.3.1 | N/A |
| 3.3.3 | Screw terminals* | EL 2115-03 | See above cl. no. 3.3.1 | N/A |
| 3.3.4 | Conductor sizes to be connected | EL 2115-04 | See above cl. no. 3.3.1 | N/A |
| | Rated current (A), cord/cable type, cross-sectional area (mm2) | | See above cl. no. 3.3.1 | N/A |
| 3.3.5 | Wiring terminal sizes | EL 2115-05 | See above cl. no. 3.3.1 | N/A |
| | Rated current (A), type, nominal thread diameter (mm) | | See above cl. no. 3.3.1 | N/A |
| 3.3.6 | Wiring terminal design | EL 2115-06 | See above cl. no. 3.3.1 | N/A |
| 3.3.7 | Grouping of wiring terminals* | EL 2115-07 | See above cl. no. 3.3.1 | N/A |
| 3.3.8 | Stranded wire | EL 2115-08 | See above cl. no. 3.3.1 | N/A |

* Total number of Requirements to be observed / inspected = 04

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 05

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

pproving Authority)

SUBHASH

Technical Manager



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 /

Page 36 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2: 2013

ULR-TC543320000000935P

Tests relating to Wiring

EL 2116 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--|---------|
| 3.4 | Disconnection from the mains supply* | EL 2116-00 | | Р |
| 3.4.1 | General Requirement A disconnect device or devices shall be provided to disconnect the equipment from the mains supply for servicing. | EL 2116-01 | See below Cl. No. 3.4.2 | P |
| 3.4.2 | Disconnect devices* | EL 2116-02 | Direct plug-in equipment as disconnect devices | Р |
| 3.4.3 | Permanently connected equipment* | EL 2116-03 | Not a permanently connected equipment | N/A |
| 3.4.4 | Parts which remain energized* | EL 2116-04 | No such parts | N/A |
| 3.4.5 | Switches in flexible cords* | EL 2116-05 | Cord are not used | N/A |
| 3.4.6 | Number of poles - single-phase and d.c. equipment* | EL 2116-06 | Disconnected devices, disconnected both poles simultaneously | Р |
| 3.4.7 | Number of poles - three-phase equipment* | EL 2116-07 | Single phase equipment | N/A |
| 3.4.8 | Switches as disconnect devices* | EL 2116-08 | No switch used | N/A |
| 3.4.9 | Plugs as disconnect devices* | EL 2116-09 | Direct plug-in equipment | N/A |
| 3.4.10 | Interconnected equipment* | EL 2116-10 | No interconnected equipment | N/A |
| 3.4.11 | Multiple power sources* | EL 2116-11 | No multiple power sources | N/A |

* Total number of Requirements to be observed / inspected = 11
Total No of applicable Requirement = 03
No of Requirements for which the sample passed: = 03

Total number of tests to be conducted : = 01
Total No of applicable Tests = 01
No. of tests for which the sample passed: = 01

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)
SUBHASH
Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 37 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Wiring

EL 2117 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|---|---------|
| 3.5 | Interconnection of equipment* | EL 2117-00 | | Р |
| 3.5.1 | General requirements* | EL 2117-01 | See below | Р |
| 3.5.2 | Types of interconnection circuits* | EL 2117-02 | SELV-SELV connection only | Р |
| 3.5.3 | ELV circuits as interconnection circuits * | EL 2117-03 | No ELV circuits | N/A |
| 3.5.4 | Data ports for additional equipment | EL 2117-04 | No such data ports for additional equipment | N/A |

* Total number of Requirements to be observed / inspected = 04

Total No of applicable Requirement = 03

No of Requirements for which the sample passed: = 03

Total number of tests to be conducted : = 01

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH

Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 38 of 107 ULR-TC543320000000935P

Tests relating to Mechanical Properties

EL 2118 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--------------------------------|---------|
| 4 | PHYSICAL REQUIREMENTS* | EL 2118-00 | | Р |
| 4.1 | Stability | EL 2118-01 | No such equipment | N/A |
| | a) A unit having a mass of 7 kg or more shall not fall over when tilted to an angle of 10° from its normal upright position. Alternatively, the unit is placed in its intended position of use on a plane, inclined at an angle of 10° to the horizontal, and then rotated slowly through an angle of 360° about its normal vertical axis. | EL 2118-02 | Mass less than 7Kg. | N/A |
| | b) A floor-standing unit having a mass of 25 kg or more shall not fall over when a force equal to 20 % of the weight of the unit, but not more than 250 N, is applied in any direction except upwards, at a height not exceeding 2 m from the floor. | EL 2118-03 | Not a floor standing equipment | N/A |
| | c) A floor-standing unit shall not fall over when a constant downward force of 800 N is applied at the point of maximum moment to any horizontal surface of at least 125 mm by at least 200 mm, at a height up to 1 m from the floor. | EL 2118-04 | Not a floor standing equipment | N/A |

| * Total number of Requirements to be observed / inspected | = 01 |
|---|-------|
| Total No of applicable Requirement | = 01 |
| No of Requirements for which the sample passed | = 01 |
| Total number of tests to be conducted | = 04 |
| Total No of applicable Tests | = 00 |
| No. of tests for which the sample passed | = N/A |

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(ASOVISIA MANAGER Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 39 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Mechanical Properties

EL 2119 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|---|---------|
| 4.2 | Mechanical Strength | EL 2119-00 | | Р |
| 4.2.1 | General | EL 2119-01 | See below | Р |
| 4.2.2 | Steady force test, 10 N | EL 2119-02 | Force applied on component. Result: No damage, No hazards | Р |
| 4.2.3 | Steady force test, 30 N | EL 2119-03 | No such parts | N/A |
| 4.2.4 | Steady force test, 250 N | EL 2119-04 | Force applied on each side of the enclosure. Result: No damage, No hazards | Р |
| 4.2.5 | Impact test | EL 2119-05 | No such equipment | N/A |
| | a) Fall test as per Fig. 4A | EL 2119-06 | See above cl. No. 4.2.5 | N/A |
| | b) Swing test as per Fig. 4A | EL 2119-07 | See above cl. No. 4.2.5 | N/A |
| 4.2.6 | Drop test; height (mm) : | EL 2119-08 | Dropped three times from height of 1000mm. Result: No damage, No hazards | Р |
| 4.2.7 | Stress relief test | EL 2119-09 | Test performed at 70°C for 7 hours. No deformation of enclosure | Р |
| 4.2.8 | Cathode Ray Tubes | EL 2119-10 | | N/A |
| 4.2.9 | High Pressure Lamps* | EL 2119-11 | No such lamps used | N/A |
| 4.2.10 | Wall or ceiling mounted equipment; force(N) | EL 2119-12 | No such equipment | N/A |

*Total number of Requirements to be observed / inspected

= 01

Total No of applicable Requirement

= 00

No of Requirements for which the sample passed:

= N/A

Total number of tests to be conducted

= 12

Total No of applicable Tests

= 06

No. of tests for which the sample passed:

= 06

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)
SUBHASH
Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 / IEC 60950-1: 2005 + A1:2009 + A2: 2013 Page 40 of 107 ULR-TC543320000000935P

Tests relating to Mechanical Properties

EL 2120 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|---|---------|
| 4.3 | Design and Construction* | EL 2120-00 | | Р |
| 4.3.1 | Edges and corners* | EL 2120-01 | All edges or corners accessible to operator are rounded and smoothed | Р |
| 4.3.2 | Handles and manual controls; force (N): | EL 2120-02 | Handles and manual controls not used | N/A |
| 4.3.3 | Adjustable controls | EL 2120-03 | No such controls used | N/A |
| 4.3.4 | Securing of parts | EL 2120-04 | Internal parts are well secured against mechanical stress occurring in normal use | Р |
| 4.3.5 | Connections by Plugs and Sockets* | EL 2120-05 | No misconnection likely to create hazard | Р |
| 4.3.6 | Direct plug-in equipment | EL 2120-06 | See below | Р |
| | Torque | EL 2120-07 | Complies | Р |
| | Compliance with the relevant mains plug standard | EL 2120-08 | Comply with IS 1293: 2019 | Р |
| 4.3.7 | Heating elements in earthed equipment* | EL 2120-09 | No heating elements | N/A |
| 4.3.8 | Batteries Portable secondary sealed cells and batteries (other than button) containing alkaline or other non-acid electrolyte shall comply with IEC 62133 | | No battery used | N/A |
| | a) Overcharging of a rechargeable battery | EL 2120-10 | See above cl. No. 4.3.8 | N/A |
| | b) Unintentional charging of a non-rechargeable battery | EL 2120-11 | See above cl. No. 4.3.8 | N/A |
| | c) Reverse charging of a rechargeable battery | EL 2120-12 | See above cl. No. 4.3.8 | N/A |
| | d) Excessive discharging rate for any battery | EL 2120-13 | See above cl. No. 4.3.8 | N/A |
| | e) Electric strength as per Cl.5.3.9.2 | EL 2120-14 | See above cl. No. 4.3.8 | N/A |
| 4.3.9 | Oil & grease* | EL 2120-15 | No oil or grease | N/A |
| 4.3.10 | Dust, powders, liquids and gases | EL 2120-16 | Equipment neither use nor produce them | N/A |
| 4.3.11 | Containers for liquids or gases | EL 2120-17 | Equipment does not contain liquids or gases | N/A |
| 4.3.12 | Flammable liquids | EL 2120-18 | No flammable liquids | N/A |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 41 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| 4.3.13 | Radiation | | See below | N/A |
|------------|---|------------|--------------------------|-----|
| 4.3.13.2 | Ionizing radiation | EL 2120-19 | No radiation | N/A |
| 4.3.13.3 | Effect of ultraviolet (UV) radiation on materials | EL 2120-20 | | N/A |
| 4.3.13.4 | Human exposure to ultraviolet (UV) radiation | EL 2120-21 | | N/A |
| 4.3.13.5 | Lasers (including laser diodes) and LED's: | | | N/A |
| 4.3.13.5.1 | Lasers (including laser diodes) For laser see IEC 60825-1, respective part as applicable. | EL 2120-22 | | N/A |
| | Laser class : | | | N/A |
| 4.3.13.5.2 | Light emitting diodes (LED's) | EL 2120-23 | | N/A |
| 4.3.13.6 | Other types* | EL 2120-24 | No other type radiations | N/A |

| * Total number of Requirements to be observed / inspected | = 06 |
|---|------|
| Total No of applicable Requirement | = 03 |
| No of Requirements for which the sample passed: | = 03 |
| | |
| Total number of tests to be conducted : | = 19 |
| Total No of applicable Tests | = 04 |
| No. of tests for which the sample passed: | = 04 |

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 42 of 107 ULR-TC543320000000935P

Tests relating to Mechanical Properties

EL 2121 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|----------------------------------|---------|
| 4.4 | Protection against hazardous moving parts | EL 2121-00 | No moving parts in the equipment | N/A |
| 4.4.1 | General | EL 2121-01 | See above cl. No. 4.4 | N/A |
| 4.4.2 | Protection in operator access areas | EL 2121-02 | See above cl. No. 4.4 | N/A |
| 4.4.3 | Protection in restricted access locations * | EL 2121-03 | See above cl. No. 4.4 | N/A |
| 4.4.4 | Protection in service access areas* | EL 2121-04 | See above cl. No. 4.4 | N/A |
| 4.4.5 | Protection against moving fan blades | EL 2121-05 | See above cl. No. 4.4 | N/A |
| 4.4.5.1 | General* | EL 2121-06 | See above cl. No. 4.4 | N/A |
| | Not considered likely to cause pain or injury. A) | EL 2121-07 | See above cl. No. 4.4 | N/A |
| | Is considered likely to cause pain, not injury. B) | EL 2121-08 | See above cl. No. 4.4 | N/A |
| | Considered likely to cause injury. C) | EL 2121-09 | See above cl. No. 4.4 | N/A |
| 4.4.5.2 | Protection for users* | EL 2121-10 | See above cl. No. 4.4 | N/A |
| | Use of symbol or warning* | EL 2121-11 | See above cl. No. 4.4 | N/A |
| 4.4.5.3 | Protection for service persons* | EL 2121-12 | See above cl. No. 4.4 | N/A |
| | Use of symbol or warning * | EL 2121-13 | See above cl. No. 4.4 | N/A |

* Total number of Requirements to be observed / inspected = 07

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 07

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)
SUBHASH

Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 43 of 107 ULR-TC543320000000935P

Tests relating to Thermal Properties

EL 2122 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|-----------------------------------|------------|--|---------|
| 4.5 | Thermal Requirements* | EL 2122-00 | See table 4.5 | Р |
| 4.5.1 | General | EL 2122-01 | See table 4.5 | Р |
| 4.5.2 | Temperature tests | EL 2122-02 | See table 4.5 | Р |
| 4.5.3 | Temperature limits for materials* | EL 2122-03 | See table 4.5 | Р |
| 4.5.4 | Touch temperature limits* | EL 2122-04 | See table 4.5 | Р |
| 4.5.5 | Resistance to abnormal heat | EL 2122-05 | Phenolic material used, No further test required (See table 1.5.1) | Р |

*Total number of Requirements to be observed / inspected = 03

Total No of applicable Requirement = 03

No of Requirements for which the sample passed: = 03

Total number of tests to be conducted : = 03

Total No of applicable Tests = 03

No. of tests for which the sample passed: = 03

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager

F-21 SEC-11 NOIDA S



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

.

Page 44 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Mechanical Properties

EL 2123 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--------------------------|---------|
| 4.6 | Openings in enclosures* | EL 2123-00 | | N/A |
| 4.6.1 | Top and side openings | EL 2123-01 | No such opening | N/A |
| | Dimensions (mm) : | | | N/A |
| 4.6.2 | Bottoms of fire enclosures : | EL 2123-02 | | N/A |
| | Construction of the bottom, dimensions (mm): | | | N/A |
| 4.6.3 | Doors or covers in fire enclosures* | EL 2123-03 | No doors and covers used | N/A |
| 4.6.4 | Openings in transportable equipment | EL 2123-04 | No such openings | N/A |
| 4.6.4.1 | Constructional design measures | EL 2123-05 | See above cl. No. 4.6.4 | N/A |
| | Dimensions (mm) | | See above cl. No. 4.6.4 | N/A |
| 4.6.4.2 | Evaluation measures for larger openings | EL 2123-06 | See above cl. No. 4.6.4 | N/A |
| 4.6.4.3 | Use of metallized parts | EL 2123-07 | No metalized parts | N/A |
| 4.6.5 | Adhesives for constructional purposes: Compliance is checked by examination of the construction and of the available data. If such data is not available, compliance is checked by the following tests. | EL 2123-08 | No adhesives used | N/A |
| | a)Temperature Conditioning at : | EL 2123-09 | See above cl. No. 4.6.5 | N/A |
| | 100 °C \pm 2 °C for one week; or | | | |
| | 90 °C ± 2 °C for three weeks; or | | | |
| | 82 °C ± 2 °C for eight weeks. | | | |
| | After temperature conditioning b) Leave the sample between 20°C to 30°C for 1 hour | EL 2123-10 | See above cl. No. 4.6.5 | N/A |
| | c) Place the sample at – 40°C±2°C for 4 hours | EL 2123-11 | See above cl. No. 4.6.5 | N/A |
| | d) Remove and allow the sample to come to any convenient temperature between 20 °C and | EL 2123-12 | See above cl. No. 4.6.5 | N/A |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 45 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| e) Place the sample in a cabinet at 91 % to 95 % relative humidity for 72 h; | EL 2123-13 | See above cl. No. 4.6.5 | N/A |
|---|------------|-------------------------|-----|
| f) Remove the sample and leave it at any convenient temperature between 20 °C and 30 °C for 1 h; | EL 2123-14 | See above cl. No. 4.6.5 | N/A |
| g) Place the sample in an oven at the temperature used for the temperature conditioning for 4 h; | EL 2123-15 | See above cl. No. 4.6.5 | N/A |
| h) Remove the sample and allow it to reach any convenient temperature between 20 °C; and 30 °C for 8 h. | EL 2123-16 | See above cl. No. 4.6.5 | N/A |
| i) The sample is then immediately subjected to the tests of Cl.4.2 as applicable. | EL 2123-17 | See above cl. No. 4.6.5 | N/A |

* Total number of Requirements to be observed / inspected = 02

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 16

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing-in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager

F-21 SEC-11 NOIDA SEC



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 46 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Fire Safety

EL 2124 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|---|---------|
| 4.7 | Resistance to fire* | EL 2124-00 | | Р |
| 4.7.1 | Reducing the risk of ignition and spread of flame | | See below | Р |
| | Method 1, selection and application of components wiring and materials OR | EL 2124-01 | Method 1 used (see table 1.5.1) | Р |
| | Method 2, application of all of simulated fault condition tests | EL 2124-02 | Not used | N/A |
| 4.7.2 | Conditions for a fire enclosure* | | See below | Р |
| 4.7.2.1 | Parts requiring a fire enclosure* | EL 2124-03 | All parts in primary and secondary circuit | Р |
| 4.7.2.2 | Parts not requiring a fire enclosure | EL 2124-04 | Fire enclosure is required to cover all parts | N/A |
| 1.7.3 | Materials* | EL 2124-05 | See below | Р |
| 4.7.3.1 | General* | EL 2124-06 | Components and material have adequate flammability classification (see table 1.5.1) | Р |
| | a)Class of material used* | EL 2124-07 | Certified material used (See table 1.5.1) | Р |
| | b) Where HB40 CLASS MATERIAL, HB75 CLASS MATERIAL or HBF CLASS FOAMED MATERIAL, is required, | EL 2124-08 | Not used | N/A |
| | material passing the glow-wire test at 550 °C according to IEC 60695-2-11 is acceptable as an Alternative. | | | |
| | c) Where it is not practical to protect components against overheating under fault conditions, the components shall be mounted on V-1 CLASS MATERIAL. Additionally, such components shall be separated from material of a class lower than V-1 CLASS MATERIAL by at least 13 mm of air, or by a solid barrier of V-1 CLASS MATERIAL. | EL 2124-09 | V-0 class material used | P |
| 4.7.3.2 | Materials for fire enclosures | TESTSO | Certified material used (See table 1.5.1) | Р |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 47 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

| a) For MOVABLE EQUIPMENT having a total mass not exceeding 18 kg, the material of a FIRE ENCLOSURE, in the thinnest significant wall thickness used, shall be of V-1 CLASS MATERIAL or shall pass the test of Clause A.2. | EL 2124-10 | See above Cl. No. 4.7.3.2 | Р |
|---|------------|---------------------------|-----|
| b) For MOVABLE EQUIPMENT having a total mass exceeding 18 kg and for all STATIONARY EQUIPMENT, the material of a FIRE ENCLOSURE, in the thinnest significant wall thickness used, shall be of 5VB CLASS MATERIAL or shall pass the test of Clause A.1. | EL 2124-11 | Mass <18Kg. | N/A |
| c) Materials for components that fill an opening in a FIRE ENCLOSURE, and that are intended to be mounted in this opening shall: be of V-1 CLASS MATERIAL; or pass the tests of Clause A.2; or comply with the flammability requirements of the relevant IEC component standard | EL 2124-12 | No such openings | N/A |
| d) Plastic materials of a FIRE ENCLOSURE shall be located more than 13 mm through air from arcing parts such as unenclosed commutators and unenclosed switch contacts. | EL 2124-13 | No such arcing parts | N/A |
| e) Plastic materials of a FIRE ENCLOSURE located less than 13mm through air from non-arcing parts which, under any condition of normal or abnormal operation, could attain a temperature sufficient to ignite the material, shall be capable of passing the test of IEC 60695-2-20. | EL 2124-14 | | N/A |
| The average time to ignition of the samples shall be not less than 15sec. If the sample melts through without igniting, the time at which this occurs is not considered to be the time to ignition. | F-21 | | |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 48 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| 4.7.3.3 | Materials for components and other parts outside fire enclosures * | | No such components or parts | N/A |
|---------|---|------------|---|-----|
| | a) Materials shall be of : | EL 2124-15 | See above cl. No. 4.7.3.3 | N/A |
| | - HB75 CLASS MATERIAL if | | | |
| | the thinnest significant thickness of this material is < 3 mm, or | | , | |
| | - HB40 CLASS MATERIAL if | | × | |
| | the thinnest significant thickness | | | |
| | of this material is ≥ 3 mm, | | | |
| | or | | _ | |
| | - HBF CLASS FOAMED | | | |
| | MATERIAL.* | | Α | |
| | b) Connectors shall comply with one of the following: | EL 2124-16 | See above cl. No. 4.7.3.3 | N/A |
| | - be made of V-2 CLASS | | | |
| | MATERIAL; or | | | |
| | - pass the tests of Clause A.2; | 14 | | |
| | or | | | |
| | - comply with the flammability | | | |
| | requirements of the relevant IEC component standard; or | | | |
| | - be mounted on V-1 CLASS | | _ | |
| | MATERIAL and be of a small size; or | | | |
| | - be located in a SECONDARY | | | |
| | CIRCUIT supplied by a power source that is limited to a | | | - |
| | maximum of 15 VA (see 1.4.11) under normal operating conditions and after a single fault in the equipment (see 1.4.14). | | | |
| 4.7.3.4 | Materials for components and other parts inside fire enclosures | | Certified material used (see table 1.5.1) | Р |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 49 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

| | | | | - |
|---------|---|------------|---------------------------------|-----|
| | a) Inside FIRE ENCLOSURES, materials for components and other parts shall comply with | EL 2124-17 | See above cl. No. 4.7.3.4 | Р |
| | one of the following: | | | |
| | - be of V-2 CLASS MATERIAL | | | |
| | or | | | |
| | HF-2 CLASS FOAMED MATERIAL; or | | 4 | |
| | - pass the flammability test | | - | |
| | described in Clause A.2; or | | | |
| | - meet the flammability | | 8 | |
| | requirements of a relevant IEC component standard that includes such requirements. | | | |
| | Requirements for voltage dependent resistors (VDR's) are in Annex Q.* | EL 2124-18 | Not used | N/A |
| 4.7.3.5 | Materials for air filter assemblies: Air filter assemblies shall be constructed of V-2 CLASS MATERIAL, or HF-2 CLASS FOAMED MATERIAL. | EL 2124-19 | No air filter assemblies | N/A |
| 4.7.3.6 | Materials used in high-voltage components | | No high voltage components used | N/A |
| | a) High-voltage components operating at peak-to-peak voltages exceeding 4 kV shall either be | EL 2124-20 | 7 | N/A |
| | of V-2 CLASS MATERIAL, or | | | |
| | HF-2 CLASS FOAMED MATERIAL, or comply with 14.4 of IEC 60065 or | | | |
| | pass the needle flame test according to IEC 60695-11-5. | | | |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 50 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

| b) Compliance is checked by inspection of the equipment and material data sheets and, if necessary, by - the tests for V-2 CLASS MATERIAL or HF-2 CLASS FOAMED MATERIAL; or | EL 2124-21 | N/A |
|--|------------|-----|
| the test described in 14.4 ofIEC 60065; orthe needle flame test | | |
| according to IEC 60695-11-5. | | |
| c) In addition to above, the following details apply, referring to clauses of IEC 60695-11-5: Clause 7 - Severities | EL 2124-22 | N/A |
| Clause 8 - Conditioning | EL 2124-23 | N/A |
| Clause 11 – Evaluation of test results | EL 2124-24 | N/A |

* Total number of Requirements to be observed / inspected = 08

Total No of applicable Requirement = 05

No of Requirements for which the sample passed:

= 05

Total number of tests to be conducted :

= 17

Total No of applicable Tests

= 04

No. of tests for which the sample passed:

= 04

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH

Technical Manager

F-21 SEC-11 ON NOIDA STATES



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 51 of 107 ULR-TC543320000000935P

Tests relating to Insulating Properties

EL 2125 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|---|---------|
| 5.0 | ELECTRICAL REQUIREMENTS AND SIMULATED ABNORMAL CONDITIONS* | EL 2125-00 | | Р |
| 5.1 | Touch current and protective conductor current* | EL 2125-01 | See below | Р |
| 5.1.2 | Configuration of equipment under test (EUT)* | EL 2125-02 | Complies | Р |
| 5.1.2.1 | Single connection to an a.c. mains supply* | EL 2125-03 | Complies | Р |
| 5.1.2.2 | Redundant multiple connections to an a.c. mains supply* | EL 2125-04 | No multiple connections | N/A |
| 5.1.2.3 | Simultaneous multiple connections to an a.c. mains supply | EL 2125-05 | See above cl. No. 5.1.2.2 | N/A |
| 5.1.3 | Test circuit | EL 2125-06 | As per figure 5A | Р |
| 5.1.4 | Application of measuring instrument | EL 2125-07 | Tested using figure D.1 measuring instrument of annex D | Р |
| 5.1.5 | Test procedure | EL 2125-08 | See table 5.1.6 | Р |
| 5.1.6 | Test measurements | | See below | Р |
| | a) r.m.s value of voltage, U2 measured using the instrument as per Fig. D.1 or r.m.s value of current measured using the instrument as per Fig. D.2 Alternatively, peak value of voltage, U2, is measured using the measuring instrument described in Clause D.1 | EL 2125-09 | See table 5.1.6 | Р |
| | b) Measured touch current (mA): | EL 2125-10 | Instrument as per figure D1 used | Р |
| | c) Calculated value of TOUCH CURRENT (mA) = U2 / 500 | EL 2125-11 | See table 5.1.6 | Р |
| | d) Measured protective conductor current(mA) | EL 2125-12 | See below cl. No. 5.1.7 | N/A |
| | e) Max. protective conductor current =5% of Input current | EL 2125-13 | | N/A |
| 5.1.7 | Equipment with touch current exceeding 3.5 mA | EL 2125-14 | No such equipment | N/A |
| 5.1.7.1 | General | EL 2125-15 | \ | N/A |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 52 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| 5.1.7.2 | Simultaneous multiple connections to the supply | EL 2125-16 | See above cl. No. 5.1.7 | N/A |
|---------|---|------------|--|-----|
| 5.1.8 | Touch currents to telecommunication networks and cable distribution systems and from telecommunication networks | EL 2125-17 | No telecommunication network or cable distribution systems | N/A |
| 5.1.8.1 | Limitation of the touch current to a telecommunication network or to a cable distribution system | EL 2125-18 | See above cl. No. 5.1.8 | N/A |
| | Supply voltage (V) | | See above cl. No. 5.1.8 | N/A |
| | Measured touch current (mA) | | See above cl. No. 5.1.8 | N/A |
| | Max. allowed touch current (mA) | | See above cl. No. 5.1.8 | N/A |
| 5.1.8.2 | Summation of touch currents from telecommunication networks | EL 2125-19 | See above cl. No. 5.1.8 | N/A |
| | a) EUT with earthed telecommunication ports : | | See above cl. No. 5.1.8 | N/A |
| | b) EUT whose telecommunication ports have no reference to protective earth | | See above cl. No. 5.1.8 | N/A |

| * Total number of Requirements to be observed / inspected | = 05 |
|---|------|
| Total No of applicable Requirement | = 04 |
| No of Requirements for which the sample passed | = 04 |
| Total number of tests to be conducted | = 15 |
| Total No of applicable Tests | = 06 |
| No. of tests for which the sample passed | = 06 |

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager

F-21 SEC-11 NOIDA SEC-11



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 53 of 107 ULR-TC543320000000935P

Tests relating to Insulating Properties

EL 2126 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--------------------------|---------|
| 5.2 | Electric strength* | EL 2126-00 | | Р |
| 5.2.1 | General* | EL 2126-01 | See below | Р |
| 5.2.2 | Test procedure | | Table 5B used | Р |
| | a) The test voltages for electric strength for the appropriate grade of insulation [FUNCTIONAL | EL 2126-02 | See table 5.2 | Р |
| | INSULATION if required by 5.3.4 b), BASIC INSULATION, SUPPLEMENTARY INSULATION or | | | |
| | REINFORCED INSULATION] are as specified in either: | | | |
| | - Table 5B using the PEAK | | | |
| | WORKING VOLTAGE (U), as determined in 2.10.2; or | | | |
| | - Table 5C using the | | | |
| | REQUIRED WITHSTAND VOLTAGE, as determined in G.4. | | | |

* Total number of Requirements to be observed / inspected = 02
Total No of applicable Requirement = 02
No of Requirements for which the sample passed: = 02

Total number of tests to be conducted : = 01
Total No of applicable Tests = 01
No. of tests for which the sample passed: = 01

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)
SUBHASH

Technical Manager



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 54 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Insulating Properties

EL 2127 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|---|---------|
| 5.3 | Abnormal operating and fault conditions | EL 2127-00 | | Р |
| 5.3.1 | Protection against overload and abnormal operation | EL 2127-01 | See table 5.3 | Р |
| 5.3.2 | Motors | EL 2127-02 | No motor used | N/A |
| 5.3.3 | Transformers | EL 2127-03 | See annex C | Р |
| 5.3.4 | Functional insulation: | EL 2127-04 | Complies with cl. No. 5.3.4 c) | Р |
| 5.3.5 | Electromechanical components | EL 2127-05 | No such components used | N/A |
| 5.3.6 | Audio amplifiers in ITE : | EL 2127-06 | Not used | N/A |
| 5.3.7 | Simulation of faults | EL 2127-07 | See table 5.3 | Р |
| 5.3.8 | Unattended equipment | EL 2127-08 | No such equipment | N/A |
| 5.3.9 | Compliance criteria for abnormal operating and fault conditions* | | See below | Р |
| 5.3.9.1 | During the tests | EL 2127-09 | No fire, no molten material or no shrinkage or distortion | Р |
| 5.3.9.2 | After the tests | EL 2127-10 | No breakdown occurs | Р |

= 00

* Total number of Requirements to be observed / inspected

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 11

Total No of applicable Tests = 07

No. of tests for which the sample passed: = 07

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH

Technical Manager

F-21 SEC-11 NOIDA



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 55 of 107

Tests relating to Communicating Connection

EL 2128 - V1.4

ULR-TC543320000000935P

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--|---------|
| 6.1 | Protection of telecommunication network service persons, and users of other equipment connected to the network, from hazards in the equipment | EL 2128-00 | Equipment is not for connection to telecommunication network | N/A |
| 6.1.1 | Protection from hazardous voltages | EL 2128-01 | See above cl. No. 6.1 | N/A |
| 6.1.2 | Separation of the telecommunication network from earth* | | See above cl. No. 6.1 | N/A |
| 6.1.2.1 | Requirements: - Surge suppressors that bridge the insulation shall have a minimum rated operating voltage U _{op} of U _{op} =U _{peak} + ΔU _{sp} + ΔU _{sa} Where U _{peak} is 360V or 180V ΔU _{sp} is the maximum increase of the rated operating voltage due to variations in component production(If not specified by the manufacturer, shall be taken as 10% of the rated operating voltage of the component) ΔU _{sa} is the maximum increase of the rated operating voltage due to the component ageing over the expected life of the equipment(If not specified by the manufacturer, shall be taken as 10% of the rated operating voltage of the component) -Insulation is subjected to electric strength test according to 5.2.2. The a.c test voltage is 1.5kV or 1.0kV - Components bridging the insulation that are left in place during electric strength testing shall not be damaged. There shall be no breakdown of insulation during electric | | See above cl. No. 6.1 | N/A |
| 6.1.2.2 | strength testing. Exclusions | EL 2128-03 | See above cl. No. 6.1 | N/A |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 56 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

* Total number of Requirements to be observed / inspected = 00

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 04

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 57 of 107 ULR-TC543320000000935P

Tests relating to Communicating Connection

EL 2129 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--|---------|
| 6.2 | Protection of equipment users from overvoltages on telecommunication networks* | EL 2129-00 | Equipment is not for connection to telecommunication network | N/A |
| 6.2.1 | Separation requirements | EL 2129-01 | See above cl. No. 6.2 | N/A |
| 6.2.2 | Electric strength test procedure | EL 2129-02 | See above cl. No. 6.2 | N/A |
| 6.2.2.1 | Impulse test | EL 2129-03 | See above cl. No. 6.2 | N/A |
| 6.2.2.2 | Steady-state test | EL 2129-04 | See above cl. No. 6.2 | N/A |
| 6.2.2.3 | Compliance criteria | EL 2129-05 | See above cl. No. 6.2 | N/A |

* Total number of Requirements to be observed / inspected

Total No of applicable Requirement

= 01 = 00

No of Requirements for which the sample passed:

= N/A

Total number of tests to be conducted :

= 05

Total No of applicable Tests

= 00

No. of tests for which the sample passed:

= N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 /

Page 58 of 107

Dated: 19/11/2020 IEC

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Communicating Connection

EL 2130 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--|---------|
| 6.3 | Protection of the telecommunication wiring system from overheating | EL 2130-00 | Equipment is not for connection to telecommunication wiring system | N/A |
| | a) If current limiting is due to the inherent impedance of the power source, the output current into any resistive load, including a short-circuit, is measured. The current limit shall not be exceeded after 60 s of test. Max. output current (A): | EL 2130-01 | See above cl. No. 6.3 | N/A |
| | b) If current limiting is provided by an overcurrent protective device having a specified time/current characteristic: | EL 2130-02 | See above cl. No. 6.3 | N/A |
| | the time/current characteristic shall show that a current equal to 110 % of the current limit will be interrupted within 60 min; and | | 1 | |
| | c) the output current into any resistive load, including a short-circuit, with the overcurrent protective device bypassed, measured after 60 s of test, shall not exceed 1 000/U, where U is the output voltage measured in accordance with 1.4.5 with all load circuits disconnected. | EL 2130-03 | See above cl. No. 6.3 | N/A |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 59 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

| d) If current limiting is provided by an overcurrent protective device that does not have a | EL 2130-04 | See above cl. No. 6.3 | | N/A |
|--|------------|-----------------------|----|-----|
| specified time/current characteristic: | | | | |
| the output current into any resistive load, including a short- circuit, shall not exceed the | | | | |
| current limit after 60 s of test; and | | | | |
| the output current into any resistive load, including a short- circuit, with the overcurrent | | | | |
| protective device bypassed, measured after 60 s of test, shall not exceed 1 000/U, where | | | :4 | |
| U is the output voltage measured in accordance with 1.4.5 with all load circuits disconnected. | | | ~ | |

* Total number of Requirements to be observed / inspected = 00

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 05

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager

F-21 SEC-11 NOIDA ON A PLANTAGE SEC-11 NOIDA ON A PLANTAGE SECTION OF THE PLAN



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 60 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Connection to cable distribution system

EL 2131 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|---|---------|
| 7 | Connection to cable distribution systems* | EL 2131-00 | | N/A |
| 7.1 | General requirements* | EL 2131-01 | Equipment is not for connection to cable distribution systems | N/A |
| 7.2 | Protection of cable distribution system service persons, and users of other equipment connected to the system, from hazardous voltages in the equipment | EL 2131-02 | See above cl. No. 7.1 | N/A |
| 7.3 | Protection of equipment users from overvoltages on the cable distribution system | EL 2131-03 | See above cl. No. 7.1 | N/A |
| 7.4 | Insulation between primary circuits and cable distribution systems | EL 2131-04 | See above cl. No. 7.1 | N/A |
| 7.4.1 | General | EL 2131-05 | See above cl. No. 7.1 | N/A |
| 7.4.2 | Voltage surge test | EL 2131-06 | See above cl. No. 7.1 | N/A |
| 7.4.3 | Impulse test | EL 2131-07 | See above cl. No. 7.1 | N/A |

*Total number of Requirements to be observed / inspected = 02

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 06

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH

Technical Manager



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 61 of 107 ULR-TC543320000000935P

Tests relating to Fire Safety

EL 2132 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|---|---------|
| A | ANNEX A, TESTS FOR RESISTANCE TO HEAT AND FIRE | EL 2132-00 | See below | Р |
| A.1 | Flammability test for fire enclosures of movable equipment having a total mass exceeding 18 kg, and of stationary equipment (see 4.7.3.2) | EL 2132-01 | Mass <18Kg. | N/A |
| A.1.1 | Samples: | EL 2132-02 | See above A.1 | N/A |
| | Wall thickness (mm): | | See above A.1 | N/A |
| A.1.2 | Conditioning of samples; temperature (°C): | EL 2132-03 | See above A.1 | N/A |
| A.1.3 | Mounting of samples : | EL 2132-04 | See above A.1 | N/A |
| A.1.4 | Test flame (see IEC 60695-11-3) | EL 2132-05 | See above A.1 | N/A |
| | Flame A, B, C or D : | | See above A.1 | N/A |
| A.1.5 | Test procedure | EL 2132-06 | See above A.1 | N/A |
| A.1.6 | Compliance criteria | EL 2132-07 | See above A.1 | N/A |
| | Sample 1 burning time (s): | | See above A.1 | N/A |
| | Sample 2 burning time (s): | | See above A.1 | N/A |
| | Sample 3 burning time (s): | | See above A.1 | N/A |
| A.2 | Flammability test for fire enclosures of movable equipment having a total mass not exceeding 18 kg, and for material and components located inside fire enclosures (see 4.7.3.2 and 4.7.3.4) | EL 2132-08 | Certified material used (see table 1.5.1) | P |
| A.2.1 | Samples, material: | EL 2132-09 | See above A.2 | N/A |
| | Wall thickness (mm): | | See above A.2 | N/A |
| A.2.2 | Conditioning of samples; temperature (°C): | EL 2132-10 | See above A.2 | N/A |
| A.2.3 | Mounting of samples : | EL 2132-11 | See above A.2 | N/A |
| A.2.4 | Test flame (see IEC 60695-11-4) | EL 2132-12 | See above A.2 | N/A |
| | Flame A, B or C: | | See above A.2 | N/A |
| A.2.5 | Test procedure | EE 2532-13 | See above A.2 | N/A |

F-21 SEC-11 NOIDA

OIDA STATU



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 62 of 107 ULR-TC543320000000935P

Tests relating to Fire Safety

EL 2132 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--------------------------|---------|
| A.2.6 | Compliance criteria | EL 2132-14 | See above A.2 | N/A |
| | Sample 1 burning time (s): | | See above A.2 | N/A |
| | Sample 2 burning time (s): | | See above A.2 | N/A |
| | Sample 3 burning time (s): | | See above A.2 | N/A |
| A.2.7 | Alternative test acc. To IEC 60695-11-5, cl. 5 and 9 | EL 2132-15 | See above A.2 | N/A |
| | Sample 1 burning time (s): | | See above A.2 | N/A |
| | Sample 2 burning time (s): | | See above A.2 | N/A |
| | Sample 3 burning time (s): | | See above A.2 | N/A |
| A.3 | Hot flaming oil test (see 4.6.2) | EL 2132-16 | No such openings | N/A |
| A.3.1 | Mounting of samples | EL 2132-17 | See above A.3 | N/A |
| A.3.2 | Test procedure | EL 2132-18 | See above A.3 | N/A |
| A.3.3 | Compliance criterion | EL 2132-19 | See above A.3 | N/A |

* Total number of Requirements to be observed / inspected = 00

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 20

Total No of applicable Tests = 02

No. of tests for which the sample passed: = 02

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(ASOUBLASIA)

Technical Manager



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 63 of 107

ULR-TC543320000000935P

Tests relating to Insulating Properties

EL 2133 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--------------------------|---------|
| В | ANNEX B, MOTOR TESTS UNDER ABNORMAL CONDITIONS(see 4.7.2.2 and 5.3.2) | EL 2133-00 | | N/A |
| B.1 | General requirements | EL 2133-01 | No motors used | N/A |
| | Position : | | See above B.1 | N/A |
| | Manufacturer : | | See above B.1 | N/A |
| | Type: | | See above B.1 | N/A |
| | Rated values : | | See above B.1 | N/A |
| B.2 | Test conditions | EL 2133-02 | See above B.1 | N/A |
| B.3 | Maximum temperatures | EL 2133-03 | See above B.1 | N/A |
| B.4 | Running overload test | EL 2133-04 | See above B.1 | N/A |
| B.5 | Locked-rotor overload test | EL 2133-05 | See above B.1 | N/A |
| | Test duration (days): | | See above B.1 | N/A |
| | Electric strength test: test voltage (V) : | | See above B.1 | N/A |
| B.6 | Running overload test for d.c. motors in secondary circuits | EL 2133-06 | See above B.1 | N/A |
| B.6.1 | General | EL 2133-07 | See above B.1 | N/A |
| B.6.2 | Test procedure | EL 2133-08 | See above B.1 | N/A |
| B.6.3 | Alternative test procedure | EL 2133-09 | See above B.1 | N/A |
| B.6.4 | Electric strength test; test voltage (V): | EL 2133-10 | See above B.1 | N/A |
| B.7 | Locked-rotor overload test for d.c. motors in secondary circuits | EL 2133-11 | See above B.1 | N/A |
| B.7.1 | General | EL 2133-12 | See above B.1 | N/A |
| B.7.2 | Test procedure | EL 2133-13 | See above B.1 | N/A |
| B.7.3 | Alternative test procedure | EL 2133-14 | See above B.1 | N/A |
| B.7.4 | Electric strength test; test voltage (V): | EL 2133-15 | See above B.1 | N/A |
| B.8 | Test for motors with capacitors | EL 2133-16 | See above B.1 | N/A |
| B.9 | Test for three-phase motors | EL 2133-17 | See above B.1 | N/A |
| B.10 | Test for series motors | EL 2133-18 | See above B.1 | N/A |
| | Operating voltage (V): | TEST | See above B.1 | N/A |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 64 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

* Total number of Requirements to be observed / inspected

= 00

Total No of applicable Requirement

= 00

No of Requirements for which the sample passed:

= N/A

Total number of tests to be conducted

= 19

Total No of applicable Tests

= 00

No. of tests for which the sample passed:

= N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 65 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2134 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|---|---------|
| С | ANNEX C, TRANSFORMERS (see 1.5.4 and 5.3.3)* | EL 2134-00 | · | P |
| | Position : | | See table 1.5.1 | Р |
| | Manufacturer : | | See table 1.5.1 | Р |
| | Type: | | See table 1.5.1 | Р |
| | Rated values : | | See table 1.5.1 | Р |
| | Method of protection: | | See table 1.5.1 | Р |
| C.1 | Overload test | EL 2134-01 | See table 5.3 | Р |
| C.2 | Insulation | EL 2134-02 | See table 5.2 and C.2 | Р |
| | Protection from displacement of windings: | | Windings mechanically secured and soldered to pins insulations tapes and coil spacer tapes provided to avoid displacement | Р |

* Total number of Requirements to be observed / inspected = 01

Total No of applicable Requirement = 01

No of Requirements for which the sample passed: = 01

Total number of tests to be conducted : = 02

Total No of applicable Tests = 02

No. of tests for which the sample passed: = 02

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

= N/A

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 66 of 107 ULR-TC543320000000935P

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Tests relating to Insulating Properties

EL 2135 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|---------------------------------|---------|
| D | ANNEX D, MEASURING INSTRUMENTS FOR TOUCH- CURRENT TESTS (see 5.1.4) | EL 2135-00 | | Р |
| D.1 | Measuring instrument | EL 2135-01 | Measuring Instrument D.1 used | Р |
| D.2 | Alternative measuring instrument | EL 2135-02 | Alternative instrument not used | N/A |

* Total number of Requirements to be observed / inspected = 00

Total No of applicable Requirement = 00

No of Requirements for which the sample passed:

Total number of tests to be conducted : = 03

Total No of applicable Tests = 02

No. of tests for which the sample passed: = 02

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager

> F-21 SEC-11 NOIDA O



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

= 00

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 67 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Thermal Properties

EL 2136- V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|-----------|--------------------------|---------|
| Е | ANNEX E, TEMPERATURE RISE OF A WINDING (see 1.4.13) | EL2136-00 | | N/A |

Total number of Requirements to be observed / inspected

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 01

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 68 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2137 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdic |
|---------|---|-----------|--------------------------|--------|
| F | ANNEX F, MEASUREMENT OF CLEARANCES AND CREEPAGE DISTANCES (see 2.10 and Annex G) | EL2137-00 | Complies | P |

* Total number of Requirements to be observed / inspected = 00

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 01
Total No of applicable Tests = 01

No. of tests for which the sample passed: = 01

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 69 of 107

ULR-TC543320000000935P

Tests relating to Electrical safety

EL 2138 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|---------------------------|---------|
| G | ANNEX G, ALTERNATIVE METHOD FOR DETERMINING MINIMUM CLEARANCES | EL 2138-00 | Alternate method not used | N/A |
| G.1 | Clearances | EL 2138-01 | See above G | N/A |
| G.1.1 | General | EL 2138-02 | See above G | N/A |
| G.1.2 | Summary of the procedure for determining minimum clearances | EL 2138-03 | See above G | N/A |
| G.2 | Determination of mains transient voltage (V) | EL 2138-04 | See above G | N/A |
| G.2.1 | AC Mains supply | EL 2138-05 | See above G | N/A |
| G.2.2 | Earthed d.c. mains supplies | EL 2138-06 | See above G | N/A |
| G.2.3 | Unearthed d.c. mains supplies | EL 2138-07 | See above G | N/A |
| G.2.4 | Battery operation | EL 2138-08 | See above G | N/A |
| G.3 | Determination of telecommunication network transient voltage (V) | EL 2138-09 | See above G | N/A |
| G.4 | Determination of required withstand voltage (V) | EL 2138-10 | See above G | N/A |
| G.4.1 | Mains transients and internal repetitive peaks | EL 2138-11 | See above G | N/A |
| G.4.2 | Transients from telecommunication networks: | EL 2138-12 | See above G | N/A |
| G.4.3 | Combination of transients | EL 2138-13 | See above G | N/A |
| G.4.4 | Transients from cable distribution systems | EL 2138-14 | See above G | N/A |
| G.5 | Measurement of transient voltages (V) | EL 2138-15 | See above G | N/A |
| | a) Transients from a mains supply | | See above G | N/A |
| | For an a.c. mains supply | | See above G | N/A |
| | For a d.c. mains supply | | See above G | N/A |
| | b) Transients from a telecommunication network | | See above G | N/A |
| G.6 | Determination of minimum clearances | EL 2138-16 | See above G | N/A |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 70 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC54332000000935P

* Total number of Requirements to be observed / inspected = 00

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 17

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 71 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Radiation Safety

EL 2139 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--------------------------|---------|
| Н | ANNEX H, IONIZING RADIATION (see 4.3.13) | EL 2139-00 | | N/A |

* Total number of Requirements to be observed / inspected

= 00

Total No of applicable Requirement

= 00

No of Requirements for which the sample passed:

= N/A

Total number of tests to be conducted :

= 01

Total No of applicable Tests

= 00

No. of tests for which the sample passed:

= N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)
SUBHASH
Technical Manager

F-21 SEC-11 TO NOIDA OF



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 72 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2: 2013

ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2140 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--|---------|
| J | ANNEX J, TABLE OF ELECTROCHEMICAL POTENTIALS (see 2.6.5.6)* | EL 2140-00 | No earthing and bonding terminals used | N/A |
| | Metal(s) used : | | | N/A |

* Total number of Requirements to be observed / inspected

= 01

Total No of applicable Requirement

= 00

No of Requirements for which the sample passed:

= N/A

Total number of tests to be conducted :

= 00

Total No of applicable Tests

= 00

No. of tests for which the sample passed:

= N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH

Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 73 of 107

= 01

ULR-TC543320000000935P

Tests relating to General Requirement

EL 2141 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--------------------------|---------|
| К | ANNEX K, THERMAL CONTROLS (see 1.5.3 and 5.3.8)* | EL 2141-00 | 4,0 | N/A |
| K.1 | Making and breaking capacity | EL 2141-01 | No thermal control | N/A |
| K.2 | Thermostat reliability; operating voltage (V): | EL 2141-02 | See above K.1 | N/A |
| K.3 | Thermostat endurance test; operating voltage (V): | EL 2141-03 | See above K.1 | N/A |
| K.4 | Temperature limiter endurance; operating voltage (V): | EL 2141-04 | See above K.1 | N/A |
| K.5 | Thermal cut-out reliability | EL 2141-05 | See above K.1 | N/A |
| K.6 | Stability of operation | EL 2141-06 | See above K.1 | N/A |

*Total number of Requirements to be observed / inspected

= 00Total No of applicable Requirement

No of Requirements for which the sample passed: = N/A

= 06Total number of tests to be conducted

= 00 Total No of applicable Tests

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

Technical Manager



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 74 of 107 ULR-TC543320000000935P

Tests relating to General Requirement

EL 2142 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--|---------|
| L | ANNEX L, NORMAL LOAD CONDITIONS FOR SOME TYPES OF ELECTRICAL BUSINESS EQUIPMENT (see 1.2.2.1 and 4.5.2)* | EL 2142-00 | V x | Р |
| L.1 | Typewriters* | EL 2142-01 | See below L.7 | N/A |
| L.2 | Adding machines and cash registers* | EL 2142-02 | See below L.7 | N/A |
| L.3 | Erasers* | EL 2142-03 | See below L.7 | N/A |
| L.4 | Pencil sharpeners* | EL 2142-04 | See below L.7 | N/A |
| L.5 | Duplicators and copy machines* | EL 2142-05 | See below L.7 | N/A |
| L.6 | Motor-operated files* | EL 2142-06 | See below L.7 | N/A |
| L.7 | Other business equipment* | EL 2142-07 | Maximum normal load is obtained by operating the equipment at rated output | Р |

* Total number of Requirements to be observed / inspected = 08

Total No of applicable Requirement = 02

No of Requirements for which the sample passed: = 02

Total number of tests to be conducted : = 00

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager

F-21 SEC-11 NOIDA S



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 75 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2143 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|------------------------------|---------|
| М | ANNEX M, CRITERIA FOR TELEPHONE RINGING SIGNALS (see 2.3.1) | EL 2143-00 | | N/A |
| M.1 | Introduction* | EL 2143-01 | No telephone ringing signals | N/A |
| M.2 | Method A | EL 2143-02 | See above M.1 | N/A |
| M.3 | Method B | EL 2143-03 | See above M.1 | N/A |
| M.3.1 | Ringing signal | EL 2143-04 | See above M.1 | N/A |
| M.3.1.1 | Frequency (Hz) : | EL 2143-05 | See above M.1 | N/A |
| M.3.1.2 | Voltage (V): | EL 2143-06 | See above M.1 | N/A |
| M.3.1.3 | Cadence; time (s), voltage (V): | EL 2143-07 | See above M.1 | N/A |
| M.3.1.4 | Single fault current (mA): | EL 2143-08 | See above M.1 | N/A |
| M.3.2 | Tripping device and monitoring voltage: | EL 2143-09 | See above M.1 | N/A |
| M.3.2.1 | Conditions for use of a tripping device or a monitoring voltage | EL 2143-10 | See above M.1 | N/A |
| M.3.2.2 | Tripping device | EL 2143-11 | See above M.1 | N/A |
| M.3.2.3 | Monitoring voltage (V): | EL 2143-12 | See above M.1 | N/A |

* Total number of Requirements to be observed / inspected

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 12

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager

F-21 SEC-11 NOIDA A

= 01



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 76 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Electrical safety

EL 2144 – V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--------------------------|---------|
| N | ANNEX N, IMPULSE TEST GENERATORS (see 1.5.7.2, 1.5.7.3, 2.10.3.9, 6.2.2.1, 7.3.2, 7.4.3 and Clause G.5) | EL 2144-00 | | N/A |
| N.1 | ITU-T impulse test generators | EL 2144-01 | | N/A |
| N.2 | IEC 60065 impulse test generator | EL 2144-02 | | N/A |

* Total number of Requirements to be observed / inspected = 00

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 03

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager

> F-21 NOIDA D W SEC-11 T



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 77 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to General Requirements

EL 2145- V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|-------------------------------|------------|--------------------------|---------|
| Р | ANNEX P, NORMATIVE REFERENCES | EL 2145-00 | | N/A |

* Total number of Requirements to be observed / inspected

= 00

Total No of applicable Requirement

= 00

No of Requirements for which the sample passed:

= N/A

Total number of tests to be conducted

= 01

Total No of applicable Tests

= 00

No. of tests for which the sample passed:

= N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 78 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to General Requirements

EL 2146 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | | Verdict |
|---------|--|------------|--------------------------|-----------------------|---------|
| Q | ANNEX Q, Voltage dependent resistors (VDRs) (see 1.5.9.1) | EL 2146-00 | No VDRs used | = | N/A |
| | A VDR shall comply with iec 61051-2, whether a fire enclosure is provided or not, taking into account all of the following: | | See above Q | 1 2 3 | N/A |
| | a) Preferred climatic categories Lower category temperature: -10°C Upper category temperature: +85°C Duration of damp Test, steady state test: 21 days | | See above Q | | N/A |
| | b) Maximum continuous voltage: Atleast 1,25 times the rated voltage of the equipment or Atleast 1,25 times the upper voltage of the rated voltage range | | See above Q | 3 1 1 1 1 | N/A |
| | c) Combination pulse : | EL 2146-01 | See above Q | | N/A |
| | d) Body of the VDR shall comply with Needle flame test according to IEC 60695-11-5 with the following test severities: duration of application of the test flame: 10 s | EL 2146-02 | See above Q | | N/A |
| | after flame time: 5s [This test is not required if VDR complies with V-1 CLASS MATERIAL] | | | R 8 | |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

| Report No.: ATS/201106/02 | IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / | Page 79 of 107 |
|---------------------------|--|------------------------|
| Dated: 19/11/2020 | IEC 60950-1: 2005 + A1:2009 + A2 : 2013 | ULR-TC543320000000935P |

Total number of Requirements to be observed / inspected = 00

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 03

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

00 : 42 : 2012

Page 80 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2: 2013

ULR-TC543320000000935P

EL 2147- V1.4

Tests relating to General Requirement

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--------------------------|---------|
| R | ANNEX R, EXAMPLES OF REQUIREMENTS FOR QUALITY CONTROL PROGRAMMES* | EL 2147-00 | | N/A |
| R.1 | Minimum separation distances for unpopulated coated printed boards (see 2.10.6.2)* | EL 2147-01 | | N/A |
| R.2 | Reduced clearances (see 2.10.3)* | EL 2147-02 | | N/A |

* Total number of Requirements to be observed / inspected = 03

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 00

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 81 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to General Requirement

EL 2148 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--------------------------|---------|
| S | ANNEX S, PROCEDURE FOR IMPULSE TESTING (see 6.2.2.3)* | EL 2148-00 | | N/A |
| S.1 | Test equipment* | EL 2148-01 | | N/A |
| S.2 | Test procedure* | EL 2148-02 | | N/A |
| S.3 | Examples of waveforms during impulse testing* | EL 2148-03 | | N/A |

* Total number of Requirements to be observed / inspected

= 04 = 00

Total No of applicable Requirement

= N/A

No of Requirements for which the sample passed:

= 00

Total No of applicable Tests

= 00

No. of tests for which the sample passed:

Total number of tests to be conducted :

= N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)
SUBHASH

Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 82 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Protection against Ingress of water

EL 2149 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|--------------------------|---------|
| Т | ANNEX T, GUIDANCE ON PROTECTION AGAINST INGRESS OF WATER (see 1.1.2)* | EL 2149-00 | IPX0 | N/A |

* Total number of Requirements to be observed / inspected

. = 01

Total No of applicable Requirement

= 00

No of Requirements for which the sample passed:

= N/A

Total number of tests to be conducted

= 00

Total No of applicable Tests

= 00

No. of tests for which the sample passed:

= N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 83 of 107

ULR-TC543320000000935P

Tests relating to Wiring

EL 2150 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|-----------|--|-----------|--------------------------|---------|
| U | ANNEX U, INSULATED WINDING WIRES FOR USE WITHOUT INTERLEAVED INSULATION (see 2.10.5.4) | EL2150-00 | | N/A |
| U.1 | GENERAL | EL2150-01 | | N/A |
| U.2 | TYPE TESTS | EL2150-02 | | N/A |
| U.2.1 | GENERAL | EL2150-03 | | N/A |
| U.2.2 | ELECTRIC STRENGTH | EL2150-04 | | N/A |
| U.2.2.1 | SOLID ROUND WINDING WIRE AND STRANDED WINDING WIRES | EL2150-05 | | N/A |
| U.2.2.1.1 | WIRES WITH NOMINAL CONDUCTOR DIAMETER UPTO AND INCLUDING 0.100MM | EL2150-06 | | N/A |
| U.2.2.1.2 | WIRES WITH NOMINAL CONDUCTOR DIAMETER OVER 0.100MM AND INCLUDING 2.500MM | EL2150-07 | × | N/A |
| U.2.2.1.3 | WIRES WITH NOMINAL CONDUCTOR DIAMETER OVER 2.500MM | EL2150-08 | Ç. | N/A |
| U.2.2.2 | SQUARE OR RECTANGULAR WIRES | EL2150-09 | | N/A |
| U.2.3 | FLEXIBILITY AND ADHERENCE | EL2150-10 | | N/A |
| U.2.4 | HEAT SHOCK | EL2150-11 | | N/A |
| U.2.5 | RETENTION OF ELECTRIC STRENGTH AFTER BENDING | EL2150-12 | | N/A |
| U.3 | TESTING DURING MANUFACTURING | EL2150-13 | | N/A |
| U.3.1 | GENERAL | EL2150-14 | | N/A |
| U.3.2 | ROUTINE TESTS | EL2150-15 | | N/A |
| U.3.3 | SAMPLING TEST | EL2150-16 | | N/A |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 84 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

*- Total number of Requirements to be observed / inspected = 00

Total No of applicable Requirement = 00

No of Requirements for which the sample passed = N/A

Total number of tests to be conducted = 17

Total No of applicable Tests = 00

No. of tests for which the sample passed = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 85 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2151 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|---------------------------------------|---------|
| V | ANNEX V, AC POWER DISTRIBUTION SYSTEMS (see 1.6.1) * | EL 2151-00 | TN power distribution system used | Р |
| V.1 | Introduction* | EL 2151-01 | See Above | Р |
| V.2 | TN power distribution systems | EL 2151-02 | 2 TN-S power distribution system used | |
| V.3 | TT Power Distribution systems | EL 2151-03 | See Above | N/A |
| V.4 | IT Power Distribution systems | EL 2151-04 | See Above | N/A |

* Total number of Requirements to be observed / inspected = 02

Total No of applicable Requirement = 02

No of Requirements for which the sample passed: = 02

Total number of tests to be conducted : = 03

Total No of applicable Tests = 01

No. of tests for which the sample passed: = 01

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager

F-21 SEC-11 H NOIDA O



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 86 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2152 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--------------------------|---------|
| W | ANNEX W, SUMMATION OF TOUCH CURRENTS * | EL 2152-00 | No such construction | N/A |
| W.1 | Touch current from electronic circuits* | EL 2152-01 | See above | N/A |
| W.1.1 | Floating circuits* | EL 2152-02 | See above | N/A |
| W.1.2 | Earthed circuits* | EL 2152-03 | See above | N/A |
| W.2 | Interconnection of several equipments* | EL 2152-04 | -04 See above | |
| W.2.1 | Isolation* | EL 2152-05 | See above | N/A |
| W.2.2 | Common return, isolated from earth* | EL 2152-06 | See above | N/A |
| W.2.3 | Common return, connected to protective earth* | EL 2152-07 | See above | N/A |

* Total number of Requirements to be observed / inspected = 08

Total No of applicable Requirement = 00

No of Requirements for which the sample passed: = N/A

Total number of tests to be conducted : = 00

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

Approving Authority)

SUBHASH

Technical Manager



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

= 03

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 87 of 107 ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2153- V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--------------------------|---------|
| Х | ANNEX X, MAXIMUM HEATING EFFECT IN TRANSFORMER TESTS (see clause C.1)* | EL 2153-00 | | Р |
| X.1 | Determination of maximum input current* | EL 2153-01 | See below | P |
| X.2 | Overload test procedure* | EL 2153-02 | See table 5.3 | Р |

* Total number of Requirements to be observed / inspected

Total No of applicable Requirement = 03

No of Requirements for which the sample passed: = 03

Total number of tests to be conducted : = 00

Total No of applicable Tests = 00

No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager

F-21 SEC-11 NOIDA OF



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 88 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

Tests relating to Radiation Safety

EL 2154- V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--------------------------|---------|
| Y | ANNEX Y, ULTRAVIOLET LIGHT CONDITIONING TEST (see 4.3.13.3) | EL 2154-00 | | N/A |
| Y.1 | Test apparatus : | EL 2154-01 | | N/A |
| Y.2 | Mounting of test samples : | EL 2154-02 | | - N/A |
| Y.3 | Carbon-arc light-exposure apparatus : | EL 2154-03 | | N/A |
| Y.4 | Xenon-arc light exposure apparatus : | EL 2154-04 | | N/A |

* Total number of Requirements to be observed / inspected

= 00

Total No of applicable Requirement

= 00

No of Requirements for which the sample passed:

= N/A

Total number of tests to be conducted

= 05

Total No of applicable Tests

= 00

No. of tests for which the sample passed:

= N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing-in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 89 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

Tests relating to Electrical Safety

EL 2155- V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|---------------------------|---------|
| Z | ANNEX Z, OVERVOLTAGE CATEGORIES (see 2.10.3.2 and Clause G.2)* | EL 2155-00 | Overvoltage Categories II | Р |

* Total number of Requirements to be observed / inspected = 01
Total No of applicable Requirement = 01
No of Requirements for which the sample passed: = 01

Total number of tests to be conducted : = 00
Total No of applicable Tests = 00
No. of tests for which the sample passed: = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 90 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Mechanical Properties

EL 2156 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---------------------------------------|------------|--------------------------|---------|
| AA | ANNEX AA, MANDREL TEST (see 2.10.5.8) | EL 2156-00 | | N/A |

* Total number of Requirements to be observed / inspected

= 00

Total No of applicable Requirement

= 00

No of Requirements for which the sample passed:

= N/A

Total number of tests to be conducted

= 01

Total No of applicable Tests

= 00

No. of tests for which the sample passed:

= N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH

Technical Manager





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 91 of 107 ULR-TC543320000000935P

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

EL 2158 - V1.4

| Tests i | relating | to | Electric | al Safety | |
|---------|----------|----|----------|-----------|--|
| | | | | | |

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|-------------------------------------|---------|
| СС | Evaluation of integrated circuit (IC) current limiters* | EL 2158-00 | No IC as current limiters are used. | N/A |
| CC.1 | Integrated circuit (IC) current limiters* | EL 2158-01 | See above CC | N/A |
| CC.2 | Test program 1 | EL 2158-02 | See above CC | N/A |
| CC.3 | Test program 2 | EL 2158-03 | See above CC | N/A |
| CC.4 | Test program 3 | EL 2158-04 | See above CC | N/A |
| CC.5 | Compliance | EL 2158-05 | See above CC | N/A |

*- Total number of Requirements to be observed / inspected = 02

Total No of applicable Requirement = 00

No of Requirements for which the sample passed = N/A

Total number of tests to be conducted = 04

Total No of applicable Tests = 00

No. of tests for which the sample passed = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)

SUBHASH Technical Manager

> F-21 SEC-11 II NOIDA O



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 92 of 107

Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P

Tests relating to Mechanical Properties

EL 2159 - V1.4

| Cl. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|--|------------|------------------------------|---------|
| DD | Requirements for the mounting means of rack-mounted equipment* | EL 2159-00 | Not a rack mounted equipment | N/A |
| DD.1 | General | | See above DD | N/A |
| DD.2 | Mechanical strength test, variable N : | EL 2159-01 | See above DD | N/A |
| DD.3 | Mechanical strength test, 250N, including end stops: | EL 2159-02 | See above DD | N/A |
| DD.4 | Compliance*: | EL 2159-03 | See above DD | N/A |

*- Total number of Requirements to be observed / inspected = 02

Total No of applicable Requirement = 00

No of Requirements for which the sample passed = N/A

Total number of tests to be conducted = 02

Total No of applicable Tests = 00

No. of tests for which the sample passed = N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 93 of 107

ULR-TC543320000000935P

Tests relating to Mechanical Properties

EL 2160 - V1.4

| CI. No. | Test / Requirement name | Test Code | Test result/ observation | Verdict |
|---------|---|------------|--------------------------|---------|
| EE | ANNEX EE, Household and home/office document/media shredders | EL 2160-00 | No such equipment | N/A |
| EE.1 | General | | See above EE | N/A |
| EE.2 | Markings and instructions* | EL 2160-01 | See above EE | N/A |
| | Use of markings or symbols*: | | See above EE | N/A |
| | Information of user instructions, maintenance and/or servicing instructions*: | | See above EE | N/A |
| EE.3 | Inadvertent reactivation test : | EL 2160-02 | See above EE | N/A |
| EE.4 | Disconnection of power to hazardous moving parts* | EL 2160-03 | See above EE | N/A |
| | Use of markings or symbols*: | | See above EE | N/A |
| EE.5 | Protection against hazardous moving parts | | See above EE | N/A |
| | Test with test finger (Figure 2A) : | EL 2160-04 | See above EE | N/A |
| | Test with wedge probe (Figure EE1 and EE2) : | EL 2160-05 | See above EE | N/A |

*- Total number of Requirements to be observed / inspected = 02

Total No of applicable Requirement

= 00

No of Requirements for which the sample passed

= N/A

Total number of tests to be conducted

= 04

Total No of applicable Tests

= 00

No. of tests for which the sample passed

= N/A

Certificate: It is certified that the above tests were performed and found to be passing/failing in the requirement tested.

(Approving Authority)



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Dated: 19/11/2020 IEC

Page 94 of 107 ULR-TC543320000000935P

| 1.5.1 | TABLE: List of compone | ents | | | P |
|-----------------|--|--------------|---|--|-----------------------|
| Object/part no. | Manufacturer/ trademark | Type/model | Technical data | Standard | Mark(s) of conformity |
| Enclosure | SABIC INNOVATIVE PLASTICS US L L C | SE1X(GG)(f1) | V-1, 105°C ,minimum thickness 1.5mm | UL 94 (Flammability test equivalent to IEC 60695-11-10) | UL E121562 |
| Alternate | ASAHI KASEI CORPORATION | 540V(f2) | V-1, 105°C ,minimum thickness 1.5mm | UL 94 (Flammability test equivalent to IEC 60695-11-10) | UL E82268 |
| Alternate | SABIC JAPAN L L C | 925U(GG) | V-0, 115°C ,minimum thickness 1.5mm | UL 94 (Flammability test equivalent to IEC 60695-11-10) | UL E207780 |
| Alternate | COVESTRO DEUTSCHLAND AG [PC RESINS] | FR6005 + (Z) | V-0, 105°C, minimum thickness 1.5mm | UL 94 (Flammability test equivalent to IEC 60695-11-10) | UL E41613. |
| Alternate | SABIC JAPAN L L C | 945(GG) | V-0 , 120°C ,minimum thickness 1.5mm | UL 94 (Flammability test equivalent to IEC 60695-11-10) | UL E207780 |
| Plug holder | SABIC INNOVATIVE PLASTICS US L L C | SE1X(GG)(f1) | V-1, 105°C ,minimum thickness 1.5mm | UL 94 (Flammability test equivalent to IEC 60695-11-10) | UL E121562 |
| Alternate | ASAHI KASEI CORPORATION | 540V(f2) | V-1, 105°C ,minimum thickness 1.5mm | UL 94 (Flammability test equivalent to IEC 60695-11-10) | UL E82268 |
| Alternate | SABIC JAPAN L L C | 925U(GG) | V-0, 105°C ,minimum thickness 1.5mm | UL 94 (Flammability test equivalent to IEC 60695-11-10) | UL E207780 |
| Alternate | SABIC JAPAN L L C | 945(GG) | V-0 , 120°C ,minimum thickness 1.5mm | UL 94 (Flammability test equivalent to IEC 60695-11-10) | UL E207780 |
| PCB | CHIAN YOU CO LTD | 02V0 | V-0, 105°C | UL 796 (No equivalent IEC standard) | UL E112804 |
| Alternate | SHENZHEN JINSHIJIE ELECTRONISC CO LTD | JSJ-1, JSJ-3 | V-0, 130°C | UL 796 (No equivalent IEC standard) | UL E503720 |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 Dated: 19/11/2020 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

IEC 60950-1: 2005 + A1:2009 + A2: 2013

Page 95 of 107 ULR-TC543320000000935P

| Alternate | WING SHING ELECTRONIC & PCB LTD | YS-1B, YS-2A, YS-2C,YS-3 | V-0, 130°C | UL 796 (No equivalent IEC standard) | UL E190407 |
|------------------------------|--|-----------------------------|------------|--|------------|
| Alternate | CHIAN YOU CO LTD | 02V0-1, 03V0,12V0 | V-0, 130°C | UL 796 (No equivalent IEC standard) | UL E112804 |
| Alternate | GROW FAST DEVELOPMENT LTD | A2, A3, A4, A5 | V-0, 130°C | UL 796 (No equivalent IEC standard) | UL E305467 |
| Alternate | SHYE FENG (DONGGUAN) CO LTD | 66V0, 99V0, 990V0 | V-0, 130°C | UL 796 (No equivalent IEC standard) | UL E466059 |
| Alternate | JIA HE ELECTRONIC LTD | D1, D3, B, B1 | V-0, 130°C | UL 796 (No equivalent IEC standard) | UL E187621 |
| Fusible resistor (RF1) | ANHUI CHANGSHENG ELECTRONICS CO LTD | FRT-2W | 3.3Ω, 2W | UL 1412 (No equivalent IEC standard) | UL E306095 |
| Alternate | TZAI YUAN ENTERPRISE CO LTD | KNF2W | 3.3Ω, 2W | UL 1412 (No equivalent IEC standard) | UL E355632 |
| Alternate | KAIHUA INDUSTRIAL HONG KONG LTD | FKN-2W Series | 3.3Ω, 2W | UL 1412 (No equivalent IEC standard) | UL E341249 |
| Alternate | Shimeng Electronics (Huizhou) Co Ltd | FKN-2W Series | 10Ω, 2W | UL 1412 (No equivalent IEC standard) | UL E339430 |
| Alternate | SHENZHEN GREAT ELECTRONICS CO LTD | RXF series | 3.3Ω, 2W | UL 1412 (No equivalent IEC standard) | UL E301541 |
| Alternate | SHENZHEN GREAT ELECTRONICS CO LTD | RXF series | 10Ω, 2W | UL 1412 (No equivalent IEC standard) | UL E301541 |
| Alternate | ANHUI CHANGSHENG ELECTRONICS CO LTD | FRT-2W | 10Ω, 2W | UL 1412 (No equivalent IEC standard) | UL E306095 |
| Alternate | TZAI YUAN ENTERPRISE CO LTD | KNF2W | 10Ω, 2W | UL 1412 (No equivalent IEC standard) | UL E355632 |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 96 of 107 Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| Y-capacitor (CY1) Optional | Yinan Don's Electronic Component Co., Ltd. | CT81 | Max. 1000pF, Min. 250Vac, 125°C, Y1 type | IEC/EN 60384-14 | VDE 135256 |
|----------------------------------|---|---|--|---------------------------------------|-----------------------|
| Alternate | Yinan Don's Electronic Component Co., Ltd. | CT81 | Max. 2200pF, Min. 250Vac, 125°C, Y1 type | IEC/EN 60384-14 | VDE 135256 |
| Alternate | Murata Mfg. Co., Ltd. | кх | Max. 2200pF, Min. 250Vac, 125°C, Y1 type | IEC/EN 60384-14 | VDE 40002831 |
| Alternate | Success Electronics Co., Ltd. | SE | Max. 2200pF, Min. 250Vac, 125°C, Y1 type | IEC/EN 60384-14 | VDE 40020002 |
| Alternate | Success Electronics Co., Ltd. | SB | Max. 2200pF, Min. 250Vac, 125°C, Y1 type | IEC/EN 60384-14 | VDE 40016621 |
| Alternate | Walsin Technology Corp. | WD | Max. 2200pF, Min. 250Vac, 125°C, Y1 type | IEC/EN 60384-14 | VDE 40016157 |
| Alternate | Samwha Capacitor Co., Ltd. | SD | Max. 2200pF, Min. 250Vac, 125°C, Y1 type | IEC/EN 60384-14 | VDE 40015804 |
| Alternate | Nanjing Yuyue Electronics Co., Ltd. | СТ7 | Max. 2200pF, Min. 250Vac, 125°C, Y1 type | IEC/EN 60384-14 | VDE 40008010 |
| Alternate | TDK Corporation | CD (miniature series) | Max. 2200pF, Min. 250Vac, 125°C, Y1 type | IEC/EN 60384-14 | VDE 40017931 |
| Common choke (L1) | GlobTek,Inc. | 30D001225- xxx ("xxx" to denote the part number, can | Class B | IS 13252 (Part 1): 2010 + A1: 2013 | Test within equipment |
| | | be any alphanumeric character for marketing purposes only.) | | | |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 / Page 97 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2: 2013 ULR-TC543320000000935P

| Alternate | Dee Van | 30D001225- xxx ("xxx" to | Class B | IS 13252 (Part 1): 2010 + A1: 2013 | Test within equipment |
|---------------------------------|---------------------------------------|--|---|--|-----------------------|
| | | denote the part number, can be any alphanumeric character for marketing purposes only.) | | | |
| Transformer (T1) | GlobTek,Inc. | 90E10PFL0- xxx ("xxx" to denote the part number, can be any alphanumeric character for marketing purposes only.) | Class B | IS 13252 (Part 1): 2010 + A1: 2013 | Test within equipment |
| Alternate | Dee Van | 90E10PFL0- xxx ("xxx" to denote the part number, can be any alphanumeric character for marketing purposes only.) | Class B | IS 13252 (Part 1): 2010 + A1: 2013 | Test within equipment |
| -Bobbin of (T1) | SHOWA DENKO MATERIALS CO., LTD. | CP-J-8800 | Phenolic, V-0, 150 °C, min. Thickness 0.71 mm. | UL 94 (Flammability test equivalent to IEC 60695-11-10) | UL E514814 |
| -Bobbin of T1 (Alternate) | CHANG CHUN PLASTICS CO LTD | T375J, T375HF, T200HF | Phenolic, V-0, 150 °C, min. Thickness 0.71 mm. | UL94 (Flammability test equivalent to IEC 60695-11-10) | UL E59481 |
| -Bobbin of T1 (Alternate) | SUMITOMO BAKELITE Co., LTD | PM-9820, PM-9823 | Phenolic, V-0, 150 °C min. Thickness 0.71 mm. | UL94 (Flammability test equivalent to IEC 60695-11-10) | UL E41429 |
| - Triple insulation wire | Young Chang Silicone Co., Ltd. | STW-B | 130°C | IEC 60950-1 | VDE 40013359 |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 98 of 107 Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| - Triple | Furukawa Electric | TEV D | 1,000 | | R SERV |
|---|---|-------------------------|-----------|--|-----------------|
| insulation wire (Alternate) | Co Ltd | TEX-B | 130°C | IEC 60950-1 | VDE 40020335 |
| - Triple insulation wire (Alternate) | Furukawa Electric Co Ltd | TEX-E | 130°C | IEC 60950-1 | VDE 006735 |
| - Triple insulation wire (Alternate) | KBI COSMOLINK CO., LTD. | TIW-M | 130°C | IEC 60950-1 | VDE 138053 |
| - Triple insulation wire (Alternate) | Great Leoflon Industrial Co., Ltd. | TRW(B) | 130°C | IEC 60950-1 | VDE 136581 |
| - Triple insulation wire (Alternate) | E&B Technology Co., Ltd. | E&B-XXXB/ E&B-XXXB-1 | 130°C | IEC 60950-1 | VDE 40023473 |
| - Triple insulation wire (Alternate) | Dah Jin Technology Co., Ltd. | TLW-B | 130°C | IEC 60950-1 | VDE 40008834 |
| - Triple insulation wire (Alternate) | Heyuan Koshen Insulator Co., Ltd. | TIW-B | 130°C | IEC 60950-1 | VDE 40039102 |
| -Insulation Tape of T1 | SYMBIO INC | 35660Y | Min.130°C | UL 510 (No equivalent IEC standard) | UL E50292 |
| -Insulation Tape of T1 (Alternate) | SYMBIO INC | 35660, MY130 | Min.130°C | UL 510 (No equivalent IEC standard) | UL E50292 |
| -Insulation Tape of T1 (Alternate) | 3M COMPANY ELECTRICAL MARKETS DIV (EMD) | 1350F-1, 1350F-2 | Min.130°C | UL 510 (No equivalent IEC standard) | UL E17385 |
| Magnet Wire | HUIZHOU GOLDEN OCEAN MAGNET WIRE FACTORY | UEW | 130°C | UL 1446 (Equivalent to applicable parts of IEC 60950-1) | UL E225143 |
| Alternate of Magnet Wire | | UEW | 130°C | UL 1446 (Equivalent to applicable parts of IEC 60950-1) | UL E243939 |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 99 of 107
Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| Alternate of Magnet Wire | | XUEW | 130°C | UL 1446 (Equivalent to applicable parts of IEC 60950-1) | UL E17610 |
|-----------------------------------|--|-------------------|---|--|------------|
| -Varnish of T1 | SHOWA DENKO MATERIALS CO., LTD. | WP-2952F-2G | 155°C | UL 1446 (Equivalent to applicable parts of IEC 60950-1) | UL E72979 |
| - Varnish of T1 (Alternate) | ELANTAS PDG, INC. | 468-2 | 155°C | UL 1446 (Equivalent to applicable parts of IEC 60950-1) | UL E75225 |
| Myler sheet | SUMITOMO BAKELITE CO LTD | AV-Lite DP 901 | V-0, 130°C, thickness: min. 0.4mm | UL94 (Flammability test equivalent to IEC 60695-11-10) | UL E41429 |
| Alternate | SABIC INNOVATIVE PLASTICS US L L C | FR700 | V-0, 125°C, thickness: min. 0.4mm | UL94 (Flammability test equivalent to IEC 60695-11-10) | UL E121562 |
| Tube (Optional) | GREAT HOLDING INDUSTRIAL CO LTD | TFL | 150V, 200°C | UL 224 (No equivalent IEC standard) | UL E156256 |
| Alternate | GREAT HOLDING INDUSTRIAL CO LTD | TFS | 600V, 200°C | UL 224 (No equivalent IEC standard) | UL E156256 |
| | GREAT HOLDING INDUSTRIAL CO LTD | TFT | 300V, 200°C | UL 224 (No equivalent IEC standard) | UL E156256 |
| | ZEUS INDUSTRIAL PRODUCTS INC | TFE-SW-600 | 600V, 200°C | UL 224 (No equivalent IEC standard) | UL E64007 |
| | ZEUS INDUSTRIAL PRODUCTS INC | | 300V, 200°C | 111 224 | UL E64007 |
| | SHENZHEN WOER HEAT- SHRINKABLE MATERIAL CO LTD | RSFR | 600V, 125°C | 111 224 | UL E203950 |

Supplementary information:

- Evidences provided by the manufacturer for the listed components are verified by us and the
 evidences conforming to the requirements of the relevent standard.
- 2. Data of Alternate Transformer are same except manufacturer name.



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013

Page 100 of 107

ULR-TC543320000000935P

| 1 6.2 | TABLE: Electrical data (in normal conditions) | | | | | | | | |
|-------|---|------------|-------|--------|-----------|--|--|--|--|
| U (V) | 1 (A) | Irated (A) | P (W) | Fuse # | Ifuse (A) | Condition/status | | | |
| 90 | 0.180 | 0.3 | 10.36 | RF1 | 0.180 | | | | |
| 100 | 0,168 | 0.3 | 10.11 | RF1 | 0.168 | Measurement at 50Hz | | | |
| 240 | 0.086 | 0.3 | 9.54 | RF1 | 0.086 | Woods of the contract of the c | | | |
| 254.4 | 0.083 | 0.3 | 9.46 | RF1 | 0.083 | 1 | | | |

| Voltage (rated) | Current (rated) (A) | Voltage (max.) | Current (max.) | VA (max.) |
|-----------------|---------------------|----------------|----------------|-----------|
| (V) | | (V) | (A) | (VA) |
| 5.2 | 1.5 | 4.45 | 1.93 | 8.58 |

| 2.1.1.7 | TABLE: | Discharge test | | | | N/A |
|-----------|--------------|------------------|-------------------|-----------------------|----------|--------|
| Condition | | τ calculated (s) | τ measured (s) | t u→ 0V (s) | Comments | |
| * | - | | | | | 25.100 |
| Supplemer | ntary inform | nation: No such | | | | - |

| 2.2.2 | TABLE: SELV measurement (under normal conditions) | | | | | P |
|-------------|---|-----------------------|--------------------|--------|--------------------|---|
| Transformer | | Location | Voltage (max.) (V) | | Voltage Limitation | |
| | | | V peak | V d.c. | Component | |
| Transfor | mer (T1) | Pin 6 to Pin 7 | 23.4 | - | | |
| | •• | Across capacitor (C7) | | 5.44 | | |

| 2.2.3 | TABLE: SELV m | TABLE: SELV measurement (under fault conditions) | | | | | |
|----------|-----------------------|--|-----------------|--|--|--|--|
| Location | | Voltage (max.) (V) | Comments | | | | |
| C7 | | Output=0V | short-circuited | | | | |
| Supplem | entary information: I | Nil | | | | | |

| 2.4.2 | TABLE: Limit | ABLE: Limited current circuit measurement | | | | | | |
|----------|-------------------|---|-----------------|----------------|---------------|----------|--|--|
| Location | | Voltage (V) | Current (mA) | Freq. (kHz) | Limit (mA) | Comments | | |
| Y-Cap | pacitor (CY1) | 0.036 | 0.072 | | 0.7 | | | |
| Suppleme | entary informatio | n: Nil | ETEST | | | | | |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No. ATS/201106/02 IS 13252 (Part 1): 2010 ÷ A1: 2013 + A2 : 2015 / Page 101 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| 2.5 | TABLE: Limited powe | wer source measurement | | | | |
|------------------------|-----------------------------|---------------------------------|----------------------|-------------|--|--|
| | | Limits | Measured | Verdic t | | |
| Accordin | ng to Table 2B/2C (normal | condition) Output voltage Uo | c = 5.12Vdc | 4 | | |
| current (in A) | | ≤8 | 1.93 | Р | | |
| apparent power (in VA) | | ≤100 | 8.58 | Р | | |
| Accordin | ng to Table 2B/2C (single f | ault condition) C7 short circui | t Output Voltage= 0V | | | |
| current (| in A) | ≤8 | 0.0 | Р | | |
| apparent power (in VA) | | ≤100 | 0.0 | Р | | |
| Supplem | nentary information: Nil | | | | | |

| 2.6.3.4 | TABLE: Resista | ance of earthing measurement | | N/A |
|-----------------------|---------------------|------------------------------|----------|-----|
| Location | | Resistance measured (Ω) | Comments | |
| | | | | |
| Suppleme | entary information: | Class II equipment. | | |
| | | | | |
| <or></or> | | | | |
| | | ance of earthing measurement | | N/A |
| <or> 2.6.3.4</or> | | | Comments | N/A |
| <or></or> | | ance of earthing measurement | Comments | N/A |

| Location | g voltage measurement RMS voltage (V) | Peak voltage (V) | Comments |
|---------------------------|--|------------------|---------------------|
| Line- Neutral | 240 | 340 | Max. Vpeak and Vrms |
| Y capacitor (CY1) | 106 | 158 | |
| T1 pin 1 to Pin 6 | 183 | 268 | |
| T1 pin 2 to Pin 6 | 204 | 288 | |
| T1 pin 4 to Pin 6 | 112 | 146 | |
| T1 pin 5 to Pin 6 | 218 | 325 | Max. Vpeak and Vrms |
| T1 pin 1 to Pin 7 | 117 | 151 | ** |
| T1 pin 2 to Pin 7 | 103 | 139 | |
| T1 pin 4 to Pin 7 | 131 | 186 | |
| T1 pin 5 to Pin 7 | 107 | 141 | |
| Supplementary information | ı: Nil. | L | A |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 102 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| 2.10.3 and TABLE: Clearance 2.10.4 | and creepa | ge distance r | neasurements | | | Р |
|--|---------------|-----------------|------------------|------------|------------------|------------|
| Clearance (cl) and creepage distance (cr) at/of/between: | U peak (V) | U r.m.s. (V) | Required cl (mm) | cl (mm) | Required cr (mm) | cr (mm) |
| Functional: | | A | NO | | | |
| Line to neutral | 340 | 240 | 1.94 | 4.83 | 2.5 | 4.83 |
| Basic / supplementary | | | | | | |
| - | | | | == | | - |
| Reinforced: | | | * | | | |
| T1(primary to secondary pin on PCB trace) | 325 | 218 | 5.16 | 17.76 | 5.16 | 17.76 |
| Y-Capacitor (CY1) | 158 | 106 | 5.16 | 7.95 | 5.16 | 7.95 |
| Supplementary information: NII | | | | | | |

| 2.10.5 | TABLE: Distance through insu | lation measur | ements | | | Р |
|-----------|---------------------------------|---------------|-----------------|------------------------|-------------------|-------------|
| Distance | through insulation (DTI) at/of: | U peak (V) | U r.m.s. (V) | Test voltage (V) | Required DTI (mm) | DTI (mm) |
| Basic: | | | | 9 | | |
| | - 69 - 67 - 180 | - | | B | | 5174C |
| Supplem | entary: | | 140 | | | |
| | - * | | | | ' | - |
| Reinforce | ed: | | | | | |
| Plastic E | nclosure | 340 | 240 | 3000 | 0.4 | 1.86 |
| Supplem | entary information: Nil | THE REST | | | | |

| 4.3.8 | TABLE: E | Batteries | | | | | | | N/A |
|--|------------------|------------------|----------------------|------------------|-------------------|------------------|------------------|------------------|------------------|
| The tests o | | applicable | only when ap | propriate b | attery | | | ō | N/A |
| Is it possible | le to install | the battery | in a reverse | oolarity pos | olarity position? | | | | N/A |
| | Non-re | chargeable | e batteries | | | Rechargeal | ble batteri | es | |
| | Disch | arging | Un- | Chai | rging | Disch | arging | Reversed | charging |
| | Meas. Current | Manuf. Specs. | intentional charging | Meas. Current | Manuf. Specs. | Meas. Current | Manuf. Specs. | Meas. Current | Manuf. Specs. |
| Max. current during normal condition | | | | | | | | = | |
| Max. current during fault condition | | | | | | | | | |
| Test results | S: | | | | | | | | Verdict |
| - Chemical | leaks | | | | | | | | 122 |
| - Explosion | of the batt | ery | II. | | | | | | |
| - Emission | of flame or | expulsion | of molten met | al | | - | | | |
| - Electric st | trength test | s of equipr | nent after com | pletion of | tests | | | | |
| Supplemer | ntary inform | ation: No b | attery used | KETEST. | 6 | 1 | | | |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 103 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| 5 TABLE: Temperature rise measurements | | | | | | | | | P |
|--|--|--|--------------------------------------|--|-----------------------------------|----------|-------------|---------------------------------|------------------|
| Temperatures were r as for power input me Temperatures are ca temperature of 60°C | measured a easuremen liculated ac | according ts of table cording cl | cl. 1.4.5. 1.6.2 re . 1.4.12.3 | Test in co sulted in h 3 with rega | nighest temp ard to the m | erature | /alue | S. | |
| Test voltage(s) (V): | | | | A: 90V, | 50Hz | | B: 2 | 254.4V, 50 |)Hz |
| t _{amb1} (°C): | A: 26 | B:26 | | t _{amb2} (°C | C): | | A: 2 | 26 B | : 26 |
| Temperature of part/ (measured with therr | | | | | temperatur at T _{amb} | | | lated ure at T _{ma} | Allowed |
| External enclosure (Plastic) | | | A dT (K) | B dT (K) | T (| | B T (°C) | | |
| xternal enclosure (Plastic) | | | | 11 | 09 | 7 | 1 | 69 | 85 |
| Transformer T1 coil | | | | 31 | 28 | 9 | 1 | 88 | 120 |
| Transformer T1 coil | Alternate | - | | 29 | 30 | 8 | 9 | 90 | 120 |
| Choke (L1) | 280 | | | 12 | 14 | 7 | 2 | 74 | 120 |
| Choke (L1) Alternate | Э | | <u>A</u> . | 13 | 12 | 7 | 3 | 72 | 120 |
| PCB near transforme | er (T1) | 1 | 3 A | 16 | 14 | 7 | 6 | 74 | 105 |
| USB Port | | | | 05 | 04 | 6 | 5 | 64 | 70 |
| Supplementary inforr | mation: The | rmocoupl | e method | d used to | determine t | ransform | er co | il tempera | ature |
| Temperatures measu | ured with w | inding res | istance r | nethod: I | Not used | | | | |
| temperature T of wir (winding resistance r | Control of the last of the las | (V) | R ₁ (| Ω) | $R_2(\Omega)$ | T (°C) | | illowed max (°C) | insulation class |
| - | | | - | | - | | | | |
| Supplementary infor | mation: Nil | | | | | | | | |

| 4.5.5 | TABLE: Ball pressure test of thermoplastic parts | | | Р | |
|---------|--|--|--|---|--|
| | Allowed impression diameter (mm): | ≤ 2 mm | | | |
| | | Test temperature Impress (°C) diameter | | | |
| Supplem | entary information: Phenolic material used, no test re | equired | | | |

| 4.6.1, 4.6.2 | Table: Enclosure oper | : Enclosure opening measurements | | | | | | |
|--------------|-------------------------|----------------------------------|----------|----|--|--|--|--|
| Location | | Size (mm) | Comments | | | | | |
| Supplemen | tary information: No op | enings | | D. | | | | |

| 4.7 | Table: | ble: Resistance to fire | | | | | | |
|---------|--------------|-----------------------------|--------------------------------------|----------------|--------------------|--------|-----|--|
| Part | | Manufacturer of material | Type of material | Thickness (mm) | Flammability class | Evider | nce | |
| Suppler | nentary info | rmation: Certified mate | l erial use <u>d. (</u> See table | 1.5.1) | 7, | | | |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2 : 2015 / Page 104 of 107

Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013 ULR-TC543320000000935P

| 5.1.6 | TABLE: Touch co | urrent and p | rotective cor | nductor curre | ent measurer | ment | | Р |
|--|-----------------------------------|-----------------------------------|-------------------------------|-------------------------|------------------------|---------------|----------|--------------------|
| | Test voltage (V) | | | .: AC254.4 | V, 50Hz | | | |
| Measurement location | | t location Polarity (normal) [mA] | | Polarity (reverse) [mA] | | Limit (mA) | Comments | |
| (Terminal | (Terminal A connected to) | | ed to) Switch: Switch: ON OFF | | Switch: Switch: ON OFF | | | |
| L/N to out | put | 0.032 | = | 0.038 | = | 0.25 | | |
| and the second of the second o | stic enclosure with metal foil | 0.007 | | 0.016 | | 0.25 | | Q ala s |
| Suppleme | entary information: | | 1// | | | | | |

| 5.2 | TABLE: Electric strength tests, imp | ulse tests and voltage surge | e tests | P |
|-----------|--|--|---------------------|-----------------------|
| Test vol | tage applied between: | Voltage shape (AC, DC, impulse, surge) | Test voltage (V) | Breakdown Yes / No |
| Function | al: | | | |
| Line to n | eutral(Fusible resistor opened) | AC | 1500 | No |
| Basic / s | upplementary: | | | |
| | Sept. 1 | And And | | |
| Reinforc | ed: | | | |
| | e Transformer (T1) winding to secondary winding | AC | 3000 | No |
| Insulatio | n tape of 2 layer | AC | 3000 | No |
| L/N to er | nclosure | AC | 3000 | No |
| Supplen | nentary information:NIL. | | | 1,000000 |

| 5.3 | TA | BLE: Fault con | dition tests | | | | | Р |
|-------------------|---|---|--------------------|--------------|-------|------------------------|--|---|
| | Ar | nbient temperat | ure (°C) | | | .: 26°C | | Р |
| | | Power source for EUT: Manufacturer, model/type, output rating | | | | | | Р |
| Compon No. | ent | Fault | Supply voltage (V) | Test time | Fuse# | Fuse current (A) | Observation | |
| Outpu | t | Short-circuit | 90Vac | 4min. | RF1 | 1.22 | Unit shut down immediately Result: No Fire, No hazards | |
| Transforr (T1) | CONTRACTOR | | 254.4Vac | 3 hours | RF1 | D <u>arie</u> | Temperature at Transformer Coil : 60°C Result: No Fire, No hazards | |





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02 IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 / Page 105 of 107 ULR-TC543320000000935P Dated: 19/11/2020 IEC 60950-1: 2005 + A1:2009 + A2 : 2013

| C.2 | TABLE: Insulation of transformers | | | | | | | |
|--|---|---------------|-----------------|--|----------------------------|------------------------------------|---------------------|--|
| | Transformer part name: Manufacturer: | | | Control of the contro | | | _ | |
| | | | | | | | _ | |
| | Туре | _ | | | | | | |
| Clearance (cl) and creepage distance (cr) at/of/between: | | U peak (V) | U r.m.s. (V) | Required cl (mm) | cl (mm) | Required cr (mm) | cr (mm) | |
| Primary /input winding and secondary/output winding (internal) | | 325 | 218 | 5.16 | T.I.W. | 5.16 | T.I.W. | |
| Primary/input winding and core (internal) | | | | 5.16 | T.I.W. | 5.16 | T.I.W. | |
| Secondary/output winding and core (internal) | | | | 5.16 | T.I.W. | 5.16 | T.I.W. | |
| Primary/input part and secondary/output part (external) | | | | 5.16 | 18.83 | 5.16 | 18.83 | |
| Primary/input part and core (external) | | | | 5.16 | T.I.W. | 5.16 | T.I.W. | |
| Primary/input part and secondary/output winding (external) | | | | 5.16 | T.I.W. | 5.16 | T.I.W. | |
| Secondary/output part and core (external) | | | | 5.16 | T.I.W. | 5.16 | T.I.W. | |
| | ry/output part and nput winding | | | 5.16 | T.I.W. | 5.16 | T.I.W. | |
| Description | on of design: | MARA | | | THEFT | | | |
| (a) Bobbi | n | | | | | 1 | | |
| Primary/input pins 1 | | | 1,3,4,5 | | | | | |
| Secondary/output pins | | | 6, 7 | | | | | |
| Material (manufacturer, type, ratings) | | | | See table 1.5.1 | | | | |
| Thickness (mm) | | | | See table 1.5.1 | | | | |
| (b) Gener | ral | | | | | | | |
| Concentr Teflon tub | ic windings on Bobbin/be on all winding exits | are provided | d. Core is co | ditionally fixed vonsidered as pri | vith tape, or mary. The | uter winding is distance insula | second ition tap | |

1.5mm min. winding ends additionally fixed with tape.

Supplementary information:

1. T.I.W.= Triple insulated wire.





NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 106 of 107


Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2: 2013

ULR-TC543320000000935P

Attachment No. 1

Plug Dimension .:



| Type of Plug: Two | pin [X] Thr | ee pin [] | | | | | | | | |
|-------------------|-------------|------------|-------------|----------|-------------|---------------------|--|--|--|--|
| Reference points | Ratings | | | | | | | | | |
| | 2.5A [X] | | 6A [|] | 16A[] | | | | | |
| | Limits | Measured | Limits | Measured | Limits | Measured | | | | |
| Α | | 2 22 | 22.05-22.35 | | 28.45-28.75 | | | | | |
| В | 18.95-19.25 | 19.18 | 18.95-19.25 | | 25.25-25.55 | 122 | | | | |
| С | - | | 7.01-7.085 | | 8.66-8.735 | (1 0.0) | | | | |
| D | 5.03-5.105 | 5.08 | 5.03-5.105 | - | 7.01-7.085 | 2 : | | | | |
| E | 15.77-16.94 | 15.98 | 15.77-16.94 | - | 20.47-21.64 | - | | | | |
| F | = | | 20.47-21.64 | - | 28.47-29.64 | | | | | |
| G | 7.94 (min.) | 11.28 | 7.94 (min.) | - | 9.52 (min.) | | | | | |
| L: ;: | 7.5 | | 7.5 | P== | 9 | | | | | |
| M | 4.58 (max) | | 4.58 (max) | | 6.56 (max) | | | | | |



NABL ACCREDITED AND BIS RECOGNIZED LABORATORY

F-21, Sector - 11, Noida | E-mail: accuratetests@gmail.com | Mobile: 09810820552 Ph: 0120-4114423 | Website: www.accuratetestsolutions.com

Report No.: ATS/201106/02

IS 13252 (Part 1): 2010 + A1: 2013 + A2: 2015 /

Page 107 of 107


Dated: 19/11/2020

IEC 60950-1: 2005 + A1:2009 + A2 : 2013

ULR-TC543320000000935P


Attachment No. 2

Photo Document






EXTERNAL VIEW



PCB VIEW 1



PCB VIEW 2

** End of Test Report**

