# **UL TEST REPORT AND PROCEDURE**

Standard:	ANSI/AAMI ES60601-1 (2005 + C1:09 + A2:10)(Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) CAN/CSA-C22.2 No. 60601-1 (2008) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance)
Certification Type:	Component Recognition
CCN:	QQHM2, QQHM8 (Power Supplies, Medical and Dental)
Product:	Medical power supply
Model:	GTM41080-1812-C1
Rating:	Input: 90-240Vac, 50-60Hz, 0.6A Output: 12Vdc, 1.25A
Applicant Name and Address:	GLOBTEK (HONG KONG) LTD UNIT 1402, BENSON TOWER 74 HUNG TO RD KWUN TONG KOWLOON HONG KONG

This is to certify that representative samples of the products covered by this Test Report have been investigated in accordance with the above referenced Standards. The products have been found to comply with the requirements covering the category and the products are judged to be eligible for Follow-Up Service under the indicated Test Procedure. The manufacturer is authorized to use the UL Mark on such products which comply with this Test Report and any other applicable requirements of UL LLC ('UL') in accordance with the Follow-Up Service Agreement. Only those products which properly bear the UL Mark are considered as being covered by UL's Follow-Up Service under the indicated Test Procedure.

The applicant is authorized to reproduce the referenced Test Report provided it is reproduced in its entirety.

UL authorizes the applicant to reproduce the latest pages of the referenced Test Report consisting of the first page of the Specific Technical Criteria through to the end of the Conditions of Acceptability.

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

Prepared by: Jeffery Chan

Reviewed by: David Shih

#### Supporting Documentation

The following documents located at the beginning of this Procedure supplement the requirements of this Test Report:

- A. Authorization The Authorization page may include additional Factory Identification Code markings.
- B. Generic Inspection Instructions
  - i. Part AC details important information which may be applicable to products covered by this Procedure. Products described in this Test Report must comply with any applicable items listed unless otherwise stated in the body of this Test Report.
  - ii. Part AE details any requirements which may be applicable to all products covered by this Procedure. Products described in this Test Report must comply with any applicable items listed unless otherwise stated in the body of each Test Report.
  - iii. Part AF details the requirements for the UL Certification Mark which is not controlled by the technical standard used to investigate these products. Products are permitted to bear only the Certification Mark(s) corresponding to the countries for which it is certified, as indicated in each Test Report.

#### Product Description

The equipment is a Medical Power Supply, type GTM41080-1812-C1, an electronic component mounted on PWB and housed in plastic enclosure. The enclosure was designed as 2 parts covering the top and bottom halves of the equipment and encapsulated together without opening, the AC inlet was fixed to enclosure by screw.

#### Model Differences

N/A

#### **Technical Considerations**

- Classification of installation and use : Recognized power adaptor, shall be determine in end use application.
- Device type (component/sub-assembly/ equipment/ system) : Component
- Intended use (Including type of patient, application location) : None
- Mode of operation : Continuous
- Supply connection : Appliance coupler
- Accessories and detachable parts included : None
- Other options include : None
- The product was investigated to the following additional standards:: CAN/CSA-C22.2 No. 60601-1 (2008) (Medical Electrical Equipment Part 1: General Requirements for Basic Safety and Essential Performance) Edition 2 Revision Date 2011/06/01, ANSI/AAMI ES60601-1 (2005 + C1:09 + A2:10) (Medical Electrical Equipment Part 1: General Requirements for Basic Safety and Essential Performance) Edition 1 Revision Date 2012/01/01, IEC 60601-1: 2005 + CORR.1 (2006) + CORR.2 (2007) (Medical Electrical Equipment Part 1: General Requirements for Basic Safety and Essential Performance) Edition 3 , EN60601-1:2006
- The product was not investigated to the following standards or clauses:: Clause 52.1, Programmable Electronic Systems (IEC 601-1-4), Clause 48, Biocompatibility (ISO 10993-1), Clause 36, Electromagnetic Compatibility (IEC 60601-1-2),
- The degree of protection against harmful ingress of water is:: IP67
- The mode of operation is:: Continuous
- The product is suitable for use in the presence of a flammable anesthetics mixture with air or oxygen or with nitrous oxide:: No
- The product is classified only to the following hazards: Casualty, Fire, Shock.
- Software is relied upon for meeting safety requirements related to mechanical, fire and shock: No

#### Engineering Conditions of Acceptability

For use only in or with complete equipment where the acceptability of the combination is determined by UL LLC. When installed in an end-product, consideration must be given to the following:

 This power supply has been judged on the basis of the required creepage and clearances in the Standards for Medical Electrical Equipment, IEC 60601-1: 2005 + CORR.1 (2006) + CORR.2 (2007) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) - Edition 3 Sub clause 8.9, ANSI/AAMI ES60601-1 (2005 + C1:09 + A2:10) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) -Edition 1 - Revision Date 2012/01/01, Sub clause 8.9. And CAN/CSA-C22.2 No. 60601-1 (2008) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) Edition 2 - Revision Date 2011/06/01

- The power supply was evaluated as 2 MOPP between Primary and Secondary.
- The Unit provide primary transformer (T1), which was incorporates as Class B, 130 degree C insulation system.
- The reference voltage for Dielectric Voltage Test in End Product: 240Vrms, 640Vpk for T1.
- The leakage current test should be evaluated in end product again.
- The power supply is evaluated as Class II equipment with SELV output.
- End product Risk Management Process to include consideration of requirements specific to the Power Supply.
- End product Risk Management Process to consider the need for simultaneous fault condition testing.
- End product Risk Management Process to consider the need for different orientations of installation during testing.
- End product to determine the acceptability of risk in conjunction to insulation to resistance to heat, moisture, and dielectric strength.
- End product to determine the acceptability of risk in conjunction to the movement of components and conductors as part of the power supply.
- End product to determine the acceptability of risk in conjunction to the routing of wires away from moving parts and sharp edges as part of the power supply.
- Temperature Test was conducted without Test Corner. End product to determine the acceptability of risk in conjunction to temperature testing without test corner as part of the power supply.
- End product to determine the acceptability of risk in conjunction to the Cleaning and Disinfection Methods as part of the power supply.
- End product to determine the acceptability of risk in conjunction to the Leakage of Liquids as part of the power supply.
- End product to determine the acceptability of risk in conjunction to the Arrangement of Indicators as part of the power supply.
- End product to determine the acceptability of risk in conjunction to the results of Mechanical Testing conducted as part of the power supply.
- End product to determine the acceptability of risk in conjunction to the selection of components as it
  pertains to the intended use, essential performance, transport, storage conditions as part of the
  power supply.
- The end-product evaluation shall ensure that the requirements related to Accompanying Documents, Clause 7.9 are met.
- The touch time for external enclosure isn't determined by the client, end product shall consider it according to client's definition.
- Compliance with the requirements for EMC shall be evaluated for the end use product.
- Overcurrent releases of adequate breaking capacity must be employed in the end product
- The end-use product shall ensure that the power supply is used within its ratings.
- The risk management requirements of the standard were not addressed in this project, it shall be considered in end-product.
- The Max. working temperature of this power supply is 50 Deg C. Additional test may require if the temperature is higher than 50 Deg C.

- Maximum ambient temperature of this power supply is 50 deg C at full load.
- Clearance distance was evaluated for operating altitude up to 5000m above sea level.
- For IP67, the AC cord set is used below: AC cord, Model SVT and SJT by SUZHOU TONGYUAN ELECTRIC WIRE & CABLE CO LTD. Plug of AC cord, Model SM001 by SELF-MAN INDUSTRIAL CO. Appliance Coupler of AC cord, Model SM006 by SELF-MAN INDUSTRIAL CO ,
- For IP67 without AC cord set, the AC inlet part should be evaluated in order to fulfill IP67 requirement.

#### Additional Information

The risk management requirements of the standard were not addressed in this project, it shall be considered in end-product.

UL project 4786338356

- Add the alternate AC inlet, Model 6102-91 by SCHURTER (E96454) and IP 67 (including adding AC power cord for IP test)

Additional Standards	Additional Standards					
The product fulfills the re	The product fulfills the requirements of: EN60601-1:2006					
Markings and instruction	ons					
Clause Title	Marking or Instruction Details					
Company identification	Classified or Recognized company's name, Trade name, Trademark or File					
Model	Model number					
Supply Connection	Voltage range, ac/dc, phases if more than single phase					
Direct current						
Supply Frequency	Rated frequency range in hertz					
Class II equipment						
Power Input	Amps, VA, or Watts					
Output	Rated output voltage, power, frequency.					
Special Instructions to	UL Representative					
N/A						

Issue Date:	2013-06-26	Page 6 of 15	Report Reference #	E341350-A21-UL
	2014-04-15			

Production-Line Testing Requirements							
Test Exemptions - The fol	lowing models are exempt f	rom the indicated test					
Model	Model         Grounding Continuity         Dielectric Voltage         Patient Circuit Dielection           Withstand         Voltage Withstand         Voltage Withstand         Voltage Withstand						
- Exempt Necessary Exempt							
	•	oonent /A					
Sample and Test Specific	s for Follow-Up Tests at L						
The following tests shall be conducted in accordance with the Generic Inspection Instructions							
Plastic Enclosure or Part	Test	Sample(s)	Test Specifics				
N/A							

### TABLE: List of Critical Components

Object/part or Description	Manufacturer/ trademark	type/model	technical data	CCN	Marks of Conformity
Plastic Enclosure	SABIC INNOVATIVE Plastics China Ltd. (E45329)	C2950	Min 2.0mm thick, flame class V-1, 85 Deg C, See enclosure 4-07 for details of enclosure dimension.	QMFZ2 /8	UL
AC inlet	SCHURTER (E96454)	6102-31	Rated 15A,250Vac	AXUT2/8	UL/cUL
AC inlet - alternate	SCHURTER (E96454)	6102-91	Rated 15A,250Vac	AXUT2/8	UL/cUL
AC cord (Optional as it is for IP67)	SUZHOÙ TONGYUAN ELECTRIC WIRE & CABLE CO LTD	SVT, SJT	Min. 300V, min.60 Deg C, min.18AWg	ZJCZ/ZJCZ7	UL / CUL (E230449)
-Plug of AC cord (Optional as it is for IP67)	SELF-MAN INDUSTRIAL CO	SM001	10A, 125V	ELBZ/ELBZ7	UL / CUL (E119543)
- Appliance Coupler of AC cord (Optional as it is for IP67)	SELF-MAN INDUSTRIAL CO	SM006	10A, 125V	ELBZ/ELBZ7	UL / CUL (E119543)
Input wire	Various	Various	300V, 80 degree C, 18 AWG or better	AVLV2/8 or ZJCZ	UL/cUL
PCB material	Various	Various	Min. V-1 min. 105 Deg C	ZPMV2	UL
Fuse (F1)	Conquer Electronics Co.Ltd (E82636)	MST	T1.6A/250Vac	JDYX2/8	UL/cUL
Fuse (F1) Alternate	Ever Island Electric Co Ltd & Walter Electric (E56092)	2010	T1.6A/250Vac	JDYX2/8	UL/cUL
Fuse (F1) Alternate	Various	Various	T1.6A/250Vac	JDYX/7	UL/cUL
Bridging diode (D1, D2,			Min.1A, Min. 600V		

#### Issue Date:

Object/part or	Manufacturer/	type/model	technical data	CCN	Marks of
Description	trademark				Conformity
D3, D4)					
Varistor, (MOV1) after fuse (optional)	TKS (E314979)	TVR10471, TVR07471, TVR14471	300Vac	VZCA2/8	UL/cUL
Varistor, (MOV1) after fuse (optional)	Centra (E316325)	CNR07D471K, CNR10D471K, CNR14D471K	300Vac	VZCA2/8	UL/cUL
Varistor, (MOV1) after fuse (optional)	JOYIN (E325508)	7N471K, 10N471K, 14N471K	300Vac	VZCA2/8	UL/cUL
Varistor, (MOV1) after fuse (optional)	Success Electronics Co Ltd (E330256)	SVR07D471K, SVR10D471K, SVR14D471K	300Vac	VZCA2/8	UL/cUL
Varistor, (MOV1) after fuse (optional)	Brightking Shenzhen Co Ltd (E327997)	471KD07, 471KD10, 471KD14	300Vac	VZCA2/8	UL/cUL
Varistor, (MOV1) after fuse (optional)	Ceramate (E315429)	GNR07D471K, GNR10D471K, GNR14D471K	300Vac	VZCA2/8	UL/cUL
Varistor, (MOV1) after fuse (optional)	Walsin (E309297)	07D471K, 10D471K, 14D471K	300Vac	VZCA2/8	UL/cUL
Varistor, (MOV1) after fuse (optional)	Hongzhi (E324904)	HEL-07D471K HEL-10D471K HEL-14D471K	300Vac	VZCA2/8	UL/cUL
Varistor, (MOV1) after fuse (optional)	New Future (E323753)	07D471K 10D471K, 14D471K	300Vac	VZCA2/8	UL/cUL
X cap (CX1) (optional)	Cheng Tung (E193049)	СТХ	Max. 0.22 uF, min. 250 Vac, 100 degree C Min (X2 or X1)		UL/cUL
Alternative	UTX (E183780)	HQX	Max. 0.22 uF, Min. 275Vac, 100 degree C Min (X2)	FOWX2/8	UL/cUL
Alternative	Dain (E147776)	MPX, NPX	Max. 0.22 uF, min. 250 Vac, 100 degree C Min	FOWX2/8	UL/cUL

Object/part or	Manufacturer/	type/model	technical data	CCN	Marks of
Description	trademark				Conformity
			(X2)		
Alternative	Welson (E104572)	WD	Max. 0.22 uF, min. 250 Vac, 100 degree C Min (X2)	FOWX2/8	UL/cUL
Alternative	Sinhua Electronics (Huzhou) Co. Ltd. (E237560)	MPX	Max. 0.22 uF, min. 275 Vac, 100 degree C Min (X2)	FOWX2/8	UL/cUL
Alternative	Jiangsu Xinghua Huayu Electronics Co., Ltd. (E311166)	MPX	Max. 0.22 uF, min. 275 Vac, 100 degree C Min .(X2)	FOWX2/8	UL/cUL
X cap (CX1) Alternative	HongZhi (E192572)	MPX	Max. 0.22 uF, min. 250 Vac, 100 degree C Min .(X2)	FOWX2/8	UL/cUL
Bulk Capacitor (C1)			Rated Min 33uF Min 400V, Min 105Deg C		
Y capacitor (CY1,CY2) (optional)	TDK (E37861)	CD	Max. 2200pF, min. 250 Vac, 100 degree C min. (Y1)	FOWX2	UL
Alternative	Walsin (E146544)	AH	Max. 2200pF, min. 250 Vac, 100 degree C min. (Y1)	FOWX2/8	UL/cUL
Alternative	Jya-Nay (E201384)	JN	Max. 2200pF, min. 250 Vac, 100 degree C min. (Y1)	FOWX2/8	UL/cUL
Alternative	Murata (E37921)	кх	Max. 2200pF, min. 250 Vac, 100 degree C min.(Y1)	FOWX2	UL
Alternative	Success (E114280)	SB, SE	Max. 2200pF, min. 250 Vac, 100 degree C min.(Y1)	FOWX2	UL

Object/part or	Manufacturer/	type/model	technical data	CCN	Marks of
Description	trademark				Conformity
Alternative	Welson (E104572)	WD	Max. 2200pF, min. 250 Vac, 100 degree C min.(Y1)	FOWX2/8	UL/cUL
Alternative	HAOHUA ELECTRONIC CO (E233106)	CT7	Max. 2200pF, min. 250 Vac, 85 degree C min.(Y1)	FOWX2/8	UL/cUL
Alternative	KUNSHAN WANSHENG ELECTRONICS CO LTD (E249006)	CT7	Max. 2200pF, min. 250 Vac, 85 degree C min.(Y1)	FOWX2/8	UL/cUL
Alternative	JERRO ELECTRONICS CORP (E333001)	JX- series	Max. 2200pF, min. 250 Vac, 85 degree C min.(Y1)	FOWX2/8	UL/cUL
Line filter(LF1)	Various	Various	130 Deg C		
-Core			Ferrite core, approximate overall 14.25 mm by 9.77mm by 2.84 mm.		
- Wire			130 Deg C, MW -75 or MW28 Type.	OBMW2	UL
Optocoupler (U1)	Sharp (E64380)	PC817	Rated min. 110degC Provide min 5000Vac isolation test voltage rating.	FPQU2/8	UL/cUL
Optocoupler (U1) Alternative	Everlight ((E214129)	EL817	Rated min. 110degC Provide min 5000Vac isolation test voltage rating.	FPQU2/8	UL/cUL
Optocoupler (U1) Optocoupler (U1) Alternative	Liteon ( E113898)	LTV-817	Rated min. 115degC Provide min 5000Vac isolation test voltage rating.	FPQU2/8	UL/cUL
Optocoupler (U1) Alternative	Cosmo (E169586)	K1010 ,KP1010	Rated min. 115degC Provide min 5000Vac isolation test voltage rating.	FPQU2/8	UL/cUL
Optocoupler (U1) Alternative	Fairchild (E90700)	H11A817B F0D817B	Rated min. 110degC Provide min 5000Vac isolation test voltage rating.	FPQU2/8	UL/cUL
Optocoupler (U1) Alternative	Bright Led Electronics Corp. (E236324)	BPC-817	Rated min. 125degC Provide min 5000Vac isolation test voltage rating.	FPQU2/8	UL/cUL

Object/part or Description	Manufacturer/ trademark	type/model	technical data	CCN	Marks of Conformity
Resistance(R1)			SMD type, rated Max.1.5M ohm, min.1/8 W.		
Resistance(R2)			SMD type, rated Max. 1.5M ohm, min.1/8 W.		
Transistor (Q1)			Rated minimum 600 V, Min.4A. Secured to Heat Sink, by metal clamp.		
Transformer (T1)	SHAN DONG BOAM ELECTRIC CO LTD	XF00579A	(OBJY2) Class B		
- Insulation system used in T1	SHAN DONG BOAM ELECTRIC CO LTD (E252329)	BOAM-01	Class 130 (B) Insulation System	OBJY2/8	UL
-Core used in T1			Ferrite core ,approximate overall 22.08mm by 5.67mm by 9.35 mm		
-Primary winding used in T1	Various	Various	Polyurethane with or without overcoat Polyamide, 130 Deg C min.	OBMW2	UL
-Secondary wire of T1	Furukawa (E206440)	TEX-E	Rated 130 Deg C, Triple insulated wire	OBJT2	UL
-Bobbin for T1	Sumitomo Bakelite CO.,LTD (E41429)	PM-9820	Phenolic, 150deg C, V-0	QMFZ2/8	UL/cUL
-Insulation tape wrapped used in T1	YAHUA(E165111)	PZ	Rated 130 degC.	OANZ2	UL
-Varnish used in T1	NOROO PAINT&COATINGS CO.,LTD(E93947)	DVB-2085(C), DVB-2085(1)	Rated 130 degC.	OBOR2	UL
-Tube	GREAT HOLDING INDUSTRIAL CO LTD (E156256)	TFL	VW-1. Rated 150V, 200 degC for TFL	YDTU2	UL
Transformer (T1) (Alternate)	GlobTek/ WUXI ZHONGTONG ELECTRONICS CO LTD	XF00579A	(OBJY2) Class B		
<ul> <li>Insulation system used in T1</li> </ul>	GLOBTEK INC (E243347)	GTX-130-TM	Class 130 (B) Insulation System	OBJY2	UL
- Insulation system used	WUXI ZHONGTONG	ZT-130	Class 130 (B) Insulation System	OBJY2/8	UL

#### Issue Date:

Object/part or Description	Manufacturer/ trademark	type/model	technical data	CCN	Marks of Conformity
in T1 (Alternate)	ELECTRONICS CO LTD (E315275)				
- Primary winding used in T1	Various	Various	Polyurethane with or without overcoat Polyamide, 130 Deg C min.	OBMW2	UL
-Secondary winding used in T1	GREAT LEOFLON INDUSTRIAL CO LTD (E211989)	TRW(B)	Rated 130 Deg C Triple insulated wire	OBJT2	UL
-Secondary winding used in T1 (Alternate)	COSMOLINK CO LTD (E213764)	TIW-M	Rated 130 Deg C Triple insulated wire	OBJT2	UL
-Bobbin for T1 (From Glotek and Zhongtong)	Changchun Plastics (E59481)	T375J T373J T375HF	Phenolic, 150 Deg C, V-0. For the type T373J with color BK and BN, the min thickness is 2.0mm.	QMFZ2/8	UL
-Bobbin for T1 (From Glotek and Zhongtong) (Alternate)	Sumitomo Bakelite CO.,LTD (E41429)	PM-9820	Phenolic, 150DegC, V-0	QMFZ2/8	UL
- Core used in T1			Ferrite core ,approximate overall 22.08mm by 5.67mm by 5.7 mm		
- Insulation Tape used in T1	JINGJIANG YAHUA (E165111)	PZ, CT	Rated 130 Deg C	OANZ2	UL
- Insulation Tape used in T1 (Alternate)	JINGJIANG JINGYI ADHESIVE PRODUCT CO LTD(E246950)	JY25-A	Rated 130 Deg C	OANZ2	UL
- Varnish used in T1	WU JIANG TAIHU INSULATING MATERIAL CO LTD(E228349)	T-4260(a)	Rated 130 Deg C	OBOR2	UL
- Tube	GREAT HOLDING INDUSTRIAL CO LTD (E156256)	TFL, TFT	VW-1. Rated 150V, 200 Deg C for TFL; Rated 300V, 200 Deg C for TFT	YDPU2	UL
- Tube (Alternate)	SHENZHEN WOER	WF	VW-1. Rated 600V, 200 Deg C	YDPU2/8	UL/cUL


Object/part or Description	Manufacturer/ trademark	type/model	technical data	CCN	Marks of Conformity
	HEAT-SHRINKABLE MATERIAL CO LTD (E203950)				
Heat Sink - HS1			Aluminum. Approximate overall dimension 26mm by 17mm, 1.5mm thick, secured to PWB by soldering		
Insulation tape provided on HS1(optional)	CHANG SHU LIANG YI TAPE INDUSTRY CO LTD (E246820)	LY-XX	Rated 130 Deg C	OANZ2	UL
Insulation tape provided on HS1 (Alternate)	3M COMPANY ELECTRICAL MARKETS DIV (EMD) (E17385)	1350T-1, 44	Rated 130 Deg C	OANZ2	UL
Insulation tape provided on HS1 (Alternate)	YAHUA ADHESIVE TAPE CO LTD (E165111)	СТ	Rated 130 Deg C	OANZ2	UL
Insulation tape provided on HS1 (Alternate)	SYMBIO INC (E50292)	35660Y	Rated 130 Deg C	OANZ2	UL
Output wire	Various	Various	300V, 80 Deg C, 24AWG or better	AVLV2/8 or ZJCZ	UL/cUL
Potting Compound(filled within unit, including the potting on AC inlet)	SUZHOU POCHELY ELECTRONIC MATERIAL CO LTD(E304947)	HB-5225A/B	Rated V-0, minimum 90 Deg C	QMFZ2	UL
Label (optional)	Dongguan Xianquan Printing Co Ltd( MH27594)	XQ03	Rated min 80 Deg C Suitable for use on the plastic enclosure	PGDQ2	UL
Label (optional) (Alternate)	Fan JA Paper Printing Co Ltd( MH19546)	FJ-03-3	Rated min 80 Deg C Suitable for use on the plastic enclosure	PGDQ2/8	UL/cUL
Label (optional) (Alternate)	Fan JA Paper Printing Co Ltd( MH19546)	FJ07	Rated min 80 Deg C Suitable for use on the plastic enclosure	PGDQ2/8	UL/cUL

## Issue Date: 2013-06-26 Page 14 of 15 Report Reference # E341350-A21-UL 2014-04-15


Object/part or Description	Manufacturer/ trademark	type/model	technical data	CCN	Marks of Conformity
Label (optional) (Alternate)	Dongguan Xianquan Printing Co Ltd( MH47303)	XQ004-B	Rated min 80 Deg C Suitable for use on the plastic enclosure	PGDQ2/8	UL
Label (optional) (Alternate)	E-Lin Adhesive ( MH45549 )	EL-15	Rated min 80 Deg C Suitable for use on the plastic enclosure	PGDQ2/8	UL/cUL
Label (optional) (Alternate)	SHENZHEN CORWIN PRINTING CO LTD(MH47077)	CW-01	Rated min 80 Deg C Suitable for use on the plastic enclosure	PGDQ2/8	UL/cUL
Label (optional) (Alternate)	YUEN CHANG SPECIAL PRINTING (SHENZHEN) CO LTD (MH29752)	JL-08	Rated min 80 Deg C Suitable for use on the plastic enclosure	PGDQ2	UL/cUL


# **Enclosures**


<u>Type</u>	Supplement Id	Description
Collateral		
Particular		
Photographs	3-01	Top View of the unit
Photographs	3-02	Bottom View of the unit
Photographs	3-03	Top view of the unit / No potting compound - without enclosure
Photographs	3-04	Bottom view of the unit / No potting compound - without enclosure
Photographs	3-09	Top View of the unit (alternate AC inlet)
Diagrams	4-01	Specification - Transformer T1 from BOAM
Diagrams	4-02	Specification - Transformer T1 from Glob Tek
Diagrams	4-03	Specification - Transformer T1 from ZhongTong
Diagrams	4-05	Specification - Power Supply GTM41080-1812-C1
Diagrams	4-06	Dimension drawing - Top cover
Diagrams	4-07	Dimension drawing - Enclosure
Diagrams	4-08	Dimension drawing - Heatsink HS1
Diagrams	4-09	Specification- LF1- page 1
Diagrams	4-10	Specification- LF1- page 2
Diagrams	4-11	Specification- LF1- page 3
Schematics + PWB	5-01	PCB Layout
Manuals		
Miscellaneous	7-01	Label
Miscellaneous	7-02	Client Declaration table
Miscellaneous	7-03	Fuse specification (type MST) - 1
Miscellaneous	7-04	Fuse specification (type:MST) - 2
Miscellaneous	7-05	Fuse specification (Type 2010)
Miscellaneous	7-06	Multiple factories agreement












		零件承认书 erial Appro	val		
制造商: Manufacturer		山东宝岩电气有限公司			
供应商 <b>:</b> Supplier			东宝岩电气有限公司 DONG BOAM CO.,LTD		
供应商料号: Supplier P/N		320-	01951403 (R)		
名称: Part Name		TR	RANSFORMER		
品名/规格: SPEC		>	XF00579A		
GlobTek料号: GlobTek P/N		320-01951403			
Edition No: 版本		С			
作成 <b>:</b> Made by	确认: Check		承认: Approval		
孙小丽		黄丽红	潘秀丽		
PS承认章: Approval Stamp	RD承i Approv	人章: /al Stamp	QC承认章: Approval Stamp		



# SPECIFICATION

CUSTOME					AHON		
			K(SUZHOU)		NAME	TRANSF	
MODEL N	0.	EE	2218	PAR	ΓNO.	320-0195	1403(R)
2 SCHE		4 ○ <u></u> 2 ○ <u></u>	$ \begin{array}{c} \mathbf{N2}\\ 0.20  \mathbf{87Ts}\\ \mathbf{N1}\\ 0  \mathbf{215Ts}\\ \mathbf{E1}\\ \mathbf{E1}\\ 0  \mathbf{E1}\\ \mathbf{E1}\\ 0  \mathbf{E1}\\ 0  \mathbf{E1}\\ 0 $		φ 0.5 10Ts	○ B ○ A	
* F	REMOVE P	'IN :3#,	START POIN 6#, 7#, 8#,   (A; BLACK	9#,10#			
SPEC NO.	KF-120	309-C	DATE	2012.03.09	SHEET NO.		2
	KF-120 DATE	309-C REVI		2012.03.09 CHECKED	SHEET NO. DESIGN	CHECK	2 APPROVAL
						CHECK	
						CHECK	

# **SPECIFICATION**

#### PROPRIÉTARY INFORMATION:

DIA-05

PROPRIETARY OF GLOBTEK, INC. ANY REPRODUCTION, DISCLOSURE OR USE OF THIS DRAWING, IN WHOLE OR IN PART, IS HEREBY PROHIBITED EXCEPT AS SPECIFIED IN WRITING BY GLOBTEK, INC. 1. NOTES:

DIMENSIONS ARE IN MM UNLESS SPECIFIED OTHERWISE.


## 2. ELECTRICAL SPECIFICATIONS:

INPUT VOLTAGE: INPUT CURRENT: INPUT FREQUENCY: 85-264 VAC 0.6 Amp RMS MAX 47-63 Hz

INFOT FREQUENCE.	47-03 HZ	
OUTPUT VOLTAGE:	12 VDC	
OUTPUT CURRENT:		I LOAD REQUIRED TO MAINTAIN OUTPUT VOLTAGE REGULATION
OUTPUT POWER (RATED):	15 WATTS MAX	
OUTPUT LOAD REGULATION:		URED AT O/P CONNECTOR
LINE VOLTAGE REGULATION:	+/- 1%TYPIC	AL MEASURED AT THE OUTPUT CONNECTOR
OUTPUT RIPPLE (PEAK TO PEAK):		MEASURED AT 20 MHz
· · · · · · · · · · · · · · · · · · ·	BANDWIDTH	WITH 0.1 µf CERAMIC CAPACITOR IN PARALLEL WITH 10 µf
		TIC CAPACITOR CONNECTED AT THE END
		CONNECTOR AT NOMINAL LINE
TURN-ON/TURN-OFF OVERSHOOT:		I, 1mS TYPICAL RECOVERY TIME FOR 25% STEP LOAD
TURN-ON DELAY:	1 SECOND, <sup>2</sup>	
HOLD-UP TIME:		L AT NOMINAL INPUT VOLTAGE AND FULL LOAD
INRUSH CURRENT:		AT 115VAC INPUT AND 60A TYPICAL AT 230 VAC INPUT
PROTECTION		
OVER-VOLTAGE:	PROTECTED	WITH 16V ZENER CLAMP ACROSS OUTPUT
SHORT CIRCUIT:		, UNIT WILL RECOVER UPON REMOVAL OF FAULT
INPUT:	INPUT LINE	
SAFETY:		
DIELECTRIC WITHSTAND VOLTAGE:	5656 VDC FROM F	PRIMARY TO SECONDARY
EARTH LEAKAGE:		264 VAC INPUT VOLTAGE, NORMAL CONDITION
AIR CREEPAGE/ CLEARANCE:	8 mm OR AS	REQUIRED IN EN60601-1 STANDARD, 3-rd EDITION
APPROVALS		
SAFETY APPROVAL(PENDING):	EN60601-1:2	006 MEDICAL ELECTRICAL EQUIPMENT PART I:
	GENERAL R	EQUIREMENT FOR BASIC SAFETY AND ESSENTUAL
	PERFORMA	NCE, 3-rd EDITION
EMI:	COMPLIES V	VITH EN55011 CLASS B AND FCC PART 15 CLASS B, WHEN
		H RESISTIVE LOAD, BOTH CONDUCTED AND RADIATED EMI
		COMPLY WITH EN60601-1-2: 2007 MEDICAL ELECTRIC
	EQUIPMENT	PART 1-2:GENERAL REQUIREMENTS FOR BASIC SAFETY,
		PERFORMANCE, COLLATERAL STANDARD; ELECTROMAGNETIC
	COMPATIBIL	ITY
EFFICIENCY:	ENERGY ST	AR VERSION 2.0, LEVEL V
	COMPLIES T	O SECTION 301 OF THE ENERGY INDEPENDENCE AND
	SECURITY A	CT (EISA)
	CECP TIER 2	2 (CHINA), MEPS TIER 2 (AUSTRALIA), CODE OF CONDUCT (EUROPE)
OTHERS		
MTBF:	200,000 HOL	IRS AT 25℃ AMBIENT TEMPERATURE, 5W LOAD
OPERATING TEMPERATURE:	0℃ TO 50° C	AMBIENT TEMPERATURE
HUMIDITY:	0% TO 90% I	RELATIVE HUMIDITY
STORAGE TEMPERATURE:	-20℃ TO +5	5°C
RoHS:	COMPLIES V	VITH EU 2002/95/EC AND CHINA SO/T 11363-2006
) GiobTek; inc.		Drawing Title: SWITCHING POWER SUPPLY, UNIVERSAL INP
ere en er al al al al al en eren		



ENERGY STAR PARTNER



Created by UL Document Assembler 2014-04-15 23:21:28 -05:00


SHEET 3 of 8

#### DIA-05

PROPRIETARY OF GLOBTEK, INC. ANY REPRODUCTION, DISCLOSURE OR USE OF THIS DRAWING, IN WHOLE OR IN PART, IS HEREBY PROHIBITED EXCEPT AS SPECIFIED IN WRITING BY GLOBTEK, INC.


4. INPUT CONNECTOR: STANDARD BLACK COLOR SCHURTER P/N: 6102-3 OR APPROVED EQUIVALENT TYPE: IEC60320 C18







_		
GlobTek; inc.	Drawing Title: SWITCHING POWER SUPPLY, UNIVERSA	l input
www.globtek.com	15 WATTS, 12 VOLTS @ 1.25 AMPS, POTTED	
186 Veterans Drive, Northvale, NJ 07467	MODEL NO: GTM41080-1812-C1	
Tel. 201-784-1000 Fax 201-784-0111	PART NO: TR9ZE1250JSTMDB2554P	REV H

Created by UL Document Assembler 2014-04-15 23:21:28 -05:00



Created by UL Document Assembler 2014-04-15 23:21:28 -05:00





💮 GlobTek, inc.	Drawing Title: SWITCHING POWER SUPPLY, UNIVERSAL INPUT				
www.globtek.com	15 WATTS, 12 VOLTS @ 1.25 AMPS, POTTED				
186 Veterans Drive, Northvale, NJ 07467	MODEL NO: GTM41080-1812-C1				
Tel. 201-784-1000 Fax 201-784-0111	PART NO: TR9ZE1250JSTMDB2554P	REV H			

Created by UL Document Assembler 2014-04-15 23:21:28 -05:00

SHEET 7 of 8

DIA-05


PROPRIETARY OF GLOBTEK, INC. ANY REPRODUCTION, DISCLOSURE OR USE OF THIS DRAWING, IN WHOLE OR IN PART, IS HEREBY PROHIBITED EXCEPT AS SPECIFIED IN WRITING BY GLOBTEK, INC.


## 8. INTERCHANGEABLE BLADE INSERTION INSTRUCTION:


ACTUAL CASE MAY VARY SLIGHTLY FROM THE PICTURE BELOW

#### CHINA RoHS SELF DISCLOSURE TABLE

		物质或元素的					
Name and co	ncentration	of hazardou	is substan	ce or element	in product		
		剧毒有害物质或元素 Hazardous substance or element					
零件名 Name of part	豻 Pb	汞 Hg	镉 Cd	六价铬 Cr(VI)	多溴联苯 PBB	多浪二苯蜷 PBDE	
Diode (ITO-220AB) 二极体	X	0	0	0	0	С	
SMD resistor SMD 电阻	х	0	0	0	0	C	
SMD Diode SMD 二极体	X	0	0	0	0	С	
PLUG 直流输出端 介	X	0	0	0	0	C	
AC PIN 交流输入端子	x	0	0	0	0	C	
O: 表示该有毒有害物质在这部件中所有 O: refers to the concentration of this haz as stipulated in the standard SJ/T 11363 X: 表示该有毒有害物质至少在这部件中的 X: refers to the concentration of this haz stipulated in the standard SJ/T 11363-29	zard substance 3-2006. 的某一同质材料 zard substance	e in the all hoi 卧中的含量超出	mogenous m H SJ/T 1136	naterials in this p 3-2006规定的限	art is below the c 重要求		
obTek, Inc.			<u> </u>			PPLY, UNIVERSAL	
lobTek, inc. globtek.com		15 W	/ATTS, 12	SWITCHING 2 VOLTS @ 1 3TM41080-18	.25 AMPS, F	-	









所有权信息: 本文件所有权属于 GLOBTEX 公司,任何整体和部分的复制都是禁止和非法的,除非取得	
GUISTEK 公司的授权允许。 PROPRIETARY INFORMATION:	RE\
PROPRIETARY OF GLOBTEK, INC. ANY REPRODUCTION, DISCLOSURE	A
OR USE OF THIS DRAWING IN WHOLE OR PART, IS HEREBY PROHIBITED EXCEPT AS SPECIFIED IN WRITING BY GLOBTEK, INC .	
· · · · · · · · · · · · · · · · · · ·	

1.5

	REVISION 修订本		
REV	DESCRIPTION 描述	DATE	APPROVED
A	INITIAL RELEASE	11/03/11	JET

PIN: Material :tin(马口铁)





NOTE: 1.All dimensions are in mm. 2. Material, 1. 5mm AL1050, or equivalent. 3. It is imperative that measurements be within tolerance table for unit to function properly.

	Toleran	ce table		]										
RANGE	GRADE 1	GRADE 2	GRADE 3/					İ						
0~4	+/-0.95	+/-0.1	+/-0,2						PART NO 零件号	REV.版本		DESCRIPTION		NOTES备注
4~16	+/-0.08	+/-0.15	+/-/0.3						GTSZ PI	N: 476-030	13102(R)			
16~64 64~250	+/-0.12 +/-0.25	+/-0.25 +/-0.4	+/-0.5 +/-0.8	-		WHERE L	JSED:用女	Ł:			GlobTek(	Suzhou	i), Co.,Lt	t <b>d</b>
尾注:						LOCATIO	N:区域 GTSZ	,	TOLERANCES 公		el; +86-512-6279-0301	Fax: +86-512-6279	-0355 Web: www.gloi	btek.cn
而影响	btek 公司不对未经 前的安全和性能负责 CSA 或EN标准规定了	,终端用户必须多		Globtek、产品未授权不得使用于医疗设备中 以及危险环境核试验或者飞机上,除非有GLOBTEX 公司首席执行官的书面正式批准。	文件内容未絕允许不得更改	INIT.BY: 申请者	BLUE	DATE: 11/03/11 日期	See table :GRADE	<sup>2</sup> Dr	rawing Title:	HEATSIN	к	
Foot P	lote: ak inc. will not be ile	his for the cefet.		Limitation of Use:		DRAWN:	JOHN	DATE: 11/03/11						
and p unaut	arformance of these norized access and hould consult appli	e parts if repair occurs. En		Globtek product are not authorized for use as mission critical components in life support, hazandous environment, nuclear or aircraft	Contents of this document are subject to change without prior notice	制图 APPROVE	ED:	日期 DATE: 11/03/11	SIZE:A4	MC N/A	)DEL NO型号:	PART NO <sup>2</sup> TR9ZE12	零件号: 50JSTMDB2554P	Rev.版本 A
	ands for proper inst			applications without prior written approval bler from the CEO of Globals inc. 21 · 28 -05 · 00		批准	JET	日期	SCALE比例:	1:1			SHEET 1 OF	- 1



Created by UL Document Assembler 2014-04-15 23:21:28 -05:00

MIS-02

For component without Risk Management Process, please declare the intended use and function of your product.

Clause for	Intended use	Client declaration
IEC60601-1, 3 <sup>rd</sup> .		
Product information	Model name	GTM41080-1812-C1
	Model difference	N/A
	Input rating	90-240V~, 50-60HZ, 0.6A
	Phase	Single
	Output rating/ output loading	12Vdc, 1.25A
	Output circuits are NOT intended for direct patient connection (Type B, BF or CF)	
		Not intended
		Intended:
		(circuit/output identity #)
	Applied Part	🔲 Туре В
		Type BF
		Type CF
		To be determined in the end-product
		evaluation
	Mode of operation	Continuous
		Duty Cycle:
	Maximum Operating temperature Tma	50 degree C
	Maximum normal load	Output was connected to resistive load as
		rated and operated continuously.
	Weight	kg
	Dimension	64X56X40mm

Issue Date: 2011-05-11 Revision Date: 2011-05-23 MIS-02

	According and date	MIS-02			
	Accessories and deta	chable parts	Part:		
			To be determined in the end-product		
			evaluation		
	Options include		None None		
5.7 Humidity	Relative Humidity?		%RH		
preconditioning	Temperature?		degree C		
treatment (keep	Recommend Period f	or Humidity preconditioning treatment?	hrs (≥48hrs)		
conformance to the					
actual test condition)					
8.9 CREEPAGE	Provides MOPP or M	OOP isolation?			
DISTANCES and AIR			🛛 МОРР		
CLEARANCES	Altitude?		5000 m		
	Pollution Degree?		1		
	Material group (CTI)?				
		aterial group classification			
	Material group	Comparative tracking index (CTI)			
	1	600 <u>&lt;</u> CTI			
	. Market	$400 \le CTI < 600$			
	llla	175 <u>&lt;</u> CTI < 400			
	NID	100 <u>&lt;</u> CTI < 175			
	Overvoltage category	?			

MIS-02

	1		10110 0	-			
						IV IV	
11 Protection	Table 23: Externa	I surfaces of ME EQ	UIPMENT that are lik	ely to be touched	for a time "t"	🛛 N/A	
against excessive						Parts:	
temperatures and	Tabl	e 23—Allowable max that a	(imum temperatures are likely to be touch	for me equipment pa ed	rts	Material:	
other HAZARDS	Maximum temperature * °C			<b>b</b> i	Metal and liquids		
	Me equipment and its parts		Metal and liquids	Glass, porcelain, vitreous material	Molded material, plastic, rubber, wood	Glass, porcelain, vitreous material	
	External surfaces	<i>t</i> < 1 s	74	80	86		
	OF ME EQUIPMENT that are likely to	1 s ≤ <i>t</i> < 10 s	56	66	71		
	be touched for a time "7"	10 s <u>&lt;</u> <i>t</i> < 1 min	51	56	60	Touch time:	
		1 min <u>&lt;</u> f	48	48	48	$\Box$ t<1s	
	Table 24: APPLIED PART having contact with the PATIENT for a time "t"         Table 24Allowable maximum temperatures for skin contact with ME EQUIPMENT APPLIED PARTS			□       10 s ≤ t < 1 min         □       1 min ≤ t         ☑       N/A         □       Parts:         Material:			
	Maximum temperature °* °C				Metal and liquids		
	Applied parts <b>of</b> me equipment		Metal and liquids	Glass, porcelain, vitreous material	Molded material, plastic, rubber, wood	Glass, porcelain, vitreous material	
	APPLIED PART	t < 1 min	51	56	60	Molded material, plastic, rubber, wood	
	having contact with the patient	1 min <u>&lt;</u> t < 10 min	48	48	48		
	for a time "7"	10 min <u>&lt;</u> t	43	43	43	Touch time:	
						$\Box$ t<1s	
						$\Box 1 s \le t < 10 s$	
						$\Box 10 \text{ s} \le t < 1 \text{ min}$	
						$\square 1 \min \le t$	

3 | Page

#### MIS-02

Γ	13 Hazardous	Electrical SINGLE FAULT CONDITIONS according to 8.1	see appended test table 13
	SITUATIONS and fault		
	conditions		

lynn \_\_\_\_\_\_\_\_\_ SIGNATURE (Authorized person): \_

# DRAFT CB TEST CERTIFICATE INFORMATION

## Generated by ULtraLink on: 2013/06/18

Product	Medical power supply GLOBTEK (HONG KONG) LTD UNIT 1402, BENSON TOWER 74 HUNG TO RD KWUN TONG KOWLOON HONG KONG		
Name and address of the Applicant			
Name and address of the Manufacturer	GLOBTEK (HONG KONG) LTD UNIT 1402, BENSON TOWER 74 HUNG TO RD KWUN TONG KOWLOON HONG KONG		
Name and address of the Factory(ies)	GLOBTEK, INC. 186 VETERANS DR. NORTHVALE, NJ 07647 USA GLOBTEK (SUZHOU) CO., LTD BUILDING 4, NO. 76, JIN LING EAST RD., SUZHOU INDUSTRIAL PARK, SUZHOU,JIANGSU 215021, CHINA		
Rating and principal characteristics	Input: 90-240Vac, 50-60Hz, 0.6A Output: 12Vdc, 1.25A		
Trademarks (if any)			
	GlobTef ,Inc.		
Model / Type ref.	GTM41080-1812-C1		
Additional information (if necessary)	This report comprises enclosures. This report was modified to:		
A sample of the product was tested and found to be in conformity with	IEC 60601-1: 2005 + CORR. 1 (2006) + CORR. 2 (2007) See Test Report for National Differences.		
As shown in the Test Report Ref. No. which forms part of this Certificate	E341350-A21		

Client Representative	MS. Demon Zhou
Client email (or fax)	demon.zhou@globtek.cn

This form is to acknowledge that the above information has been reviewed and the material has been found to be accurate as stated. This is also to record client's confirmation that above factories manufacture product(s) that are equal to those submitted for testing and certification. (Refer to IECEE 02, Sub-clause 6.2.5: "When the application covers more than one factory, the address of each factory shall be stated in the CB Test Certificate and the NCB shall take steps to ensure that the products from all the factories are equal. That shall be confirmed in the Test Report.")

Signed:	my shang	Dated:	TOIL 6. 15
	0	,	

\*Definitions per IECEE 02 (http://www.iecee.com/cbscheme/pdf/IECEE02.pdf):

Applicant: A firm or a person who applies to an NCB for obtaining a CB Test Certificate.

Manufacturer: An organization, situated at a stated location or locations, that carries out or controls such stages in the manufacture, assessment, handling and storage of a product that enables it to accept responsibility for continued compliance of the product with the relevant requirements and undertakes all obligations in that connection. <u>Factory</u>: The location(s) at which the product is produced or assembled and follow-up service is established by the NCB. Issue Date:2013-06-26Page 1 of 4Revision Date:2014-04-15Test Record

Report Reference #

## **Test Record No. 1**

The manufacturer submitted representative production samples of Medical Power Supply, models GTM41080-1812-C1.

Test results are valid only for the tested equipment. These tests are considered representative of the products covered by this Test Report. The test methods and results of the above tests have been reviewed and found to be in accordance with the requirements in the Standard(s) referenced at the beginning of this Test Report.

The results of this investigation, including construction review and testing, indicate that the products evaluated comply with the applicable requirements in the standard for IEC 60601-1: 2005 + CORR.1 (2006) + CORR.2 (2007) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) - Edition 3, ANSI/AAMI ES60601-1 (2005 + C1:09 + A2:10) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) - Edition 1 - Revision Date 2012/01/01, CAN/CSA-C22.2 No. 60601-1 (2008) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) - Edition 1 - Revision Date 2012/01/01, CAN/CSA-C22.2 No. 60601-1 (2008) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) Edition 2 - Revision Date 2011/06/01

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

Issue Date:	2013-06-26	Page 2 of 4
Revision Date:	2014-04-15	Test Record

Report Reference #

The following tests were conducted:

Test	Testing Location/Comments
Power Input Test (4.11)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan ,This test is performed at 80V input voltage instead of 81V as customer required.
Humidity Preconditioning Treatment (5.7)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan
Durability of Marking Test (7.1.3)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan
Low Voltage Reliability (8.4.2 and 8.11.1)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan
Voltage or Charge Limitation (8.4.3)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan
Working Voltage Measurement (8.5.4)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan
Dielectric Voltage Withstand (8.8.3)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan
Ball Pressure (8.8.4.1)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan
Temperature Test (11)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan / This test is performed at 80V input voltage instead of 81V as customer required.
Interruption of Power Supply (11.8)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan

Issue Date:	2013-06-26	Page 3 of 4
Revision Date:	2014-04-15	Test Record

Report Reference #

Abnormal Operation and Single Fault Conditions (13)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan
Power Availability (13.1.2)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan
Enclosure Mechanical Strength (15.3)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan
Drop Test (15.3.4)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan
Mold Stress Relief Test (15.3.6)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan
Transformer Overload and Short-Circuit Tests (15.5.1)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan
Leakage Current Test (8.7)	Underwriters Laboratories Taiwan Co., Ltd./4th & 5th Fl., No. 35, Sec. 2, ChungYang S. Road, Peitou, Taipei City 112, Taiwan

Test results are valid only for the tested equipment. These tests are considered representative of the products covered by this Test Report. The test methods and results of the above tests have been reviewed and found to be in accordance with the requirements in the Standard(s) referenced at the beginning of this Test Report.

The following supplements are provided as a part of this Test Record. NOTE: These supplements are only available to the Applicant via the CDA system.

Type	Supplement Id	Description
Attachment	2-01	CRD
Datasheet	2-02	Datasheet
Insulation Diagram	10-01	Insulation Diagram
Insulation Table	10-02	Insulation Table

Issue Date:2013-06-26Page 4 of 4Revision Date:2014-04-15Test Record

Report Reference #

## **Test Record No. 2**

The manufacturer submitted representative production samples of Medical Power Supply, models GTM41080-1812-C1.

No test was considered necessary due to similarity of previous project investigation except adding the alternate AC inlet, Model 6102-91 by SCHURTER (E96454) and IP rating 67 (IP 67 report was provided by customer and include adding AC power cord), see report E341350-A21, test record 1

The results of this investigation, including construction review and testing, indicate that the products evaluated comply with the applicable requirements in the standard for IEC 60601-1: 2005 + CORR.1 (2006) + CORR.2 (2007) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) - Edition 3, ANSI/AAMI ES60601-1 (2005 + C1:09 + A2:10) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) - Edition 1 - Revision Date 2012/01/01, CAN/CSA-C22.2 No. 60601-1 (2008) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) - Edition 1 - Revision Date 2012/01/01, CAN/CSA-C22.2 No. 60601-1 (2008) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) Edition 2 - Revision Date 2011/06/01

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

The following supplements are provided as a part of this Test Record. NOTE: These supplements are only available to the Applicant via the CDA system.

<u>Type</u>	Supplement Id	Description
Attachment	2-03	CRD

01-ATT-01

Project: <u>13CA03570</u>	File: <u>E341350</u>		Page 1 of 2
Compliance Review Conducted by: _	Sammi Liang/ Annie Niu	Samme: L'Anti Ma	May,20 <sup>th</sup> ,2013
Conducted by. –	Printed Name	Signature	Date

# CONSTRUCTION COMPLIANCE REVIEW RECORD

### SAMPLE IDENTIFICATION:

Sample Card #	Date Received	Sample #	Manufacturer, Product Identification and Ratings		
1556445	01-29-2013		Glob tek, Medical Power Supply, type GTM41080-1812-C1 (UNSEALED)*5 Rated Input: 90-240Vac 50-50Hz, 0.6A Output: 12Vdc, 1.25A		
1556445	01-29-2013		Glob tek, Medical Power Supply, type GTM41080-1812-C1 (SEALED)*3 Rated Input: 90-240Vac 50-50Hz, 0.6A Output: 12Vdc, 1.25A		
1556445	01-29-2013		Shan Dong BOAM /Glob Tek /Wuxi Zhong tong Type XF00579A Transformer*2		
1556445	01-29-2013		Label*7 Type XQ03 and XQ004-B (Dong Guan Xian quan), FJ-03-3 and FJ07 (Fan JA Paper), EL-15 ( E-Lin Adhesive ), CW-01(SHENZHEN CORWIN ), JL-08 (YUEN CHANG )		
1556445	01-29-2013		Fuse*15 Type: MST (Conquer) Rating : T1.6A/250Vac		
1556445	01-29-2013		Insulation Wire*3 Type TEX-E (Furukawa ) , TRW(B) (Great Leoflon) and TIW-M (Cosmolink)		
1556445	01-29-2013		Insulation Tape*2 Type PZ (YAHUA) and JY25-A (JINGJIANG JINGYI )		

The alternation is not related to insulation, therefore no insulation measurement was conducted.

#### **MEASUREMENT INSTRUMENT INFORMATION:** (Ex. Micrometer, Calipers, Comparator)

Inst. ID #	Instrument Type	Function/Range	Last Cal. Date	Next Cal. Date
SUB-LT-CA137	Caliper	0-150mm	2013-03-21	2014-03-20

The following additional information is required when using client's or rented equipment, or when a UL ID Number for an instrument number is not used. The Inst. ID # below corresponds to the Inst. ID # above.

Inst. ID #	Make / Model / Serial Number / Asset No.

### CONSTRUCTION COMPLIANCE REVIEW:

The sample was reviewed for compliance with the construction requirements in the standard(s) indicated below and a complete record including measurements to support compliance with those requirements is detailed in Report Reference Number E341350-A21

Standard(s):

CAN/CSA-C22.2 No. 60601-1 (2008) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) Edition 2 - Revision Date 2011/06/01

ANSI/AAMI ES60601-1 (2005 + C1:09 + A2:10) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) - Edition 1 - Revision Date 2012/01/01 ANSI/AAMI ES60601-1 (2005 + C1:09 + A2:10) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) - Edition 1 - Revision Date 2012/01/01, CAN/CSA-C22.2 No. 60601-1 (2008) (Medical Electrical Equipment - Part 1: General Requirements for

Basic Safety and Essential Performance) Edition 2 - Revision Date 2011/06/01, IEC 60601-1: 2005 + CORR.1 (2006) + CORR.2 (2007) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) - Edition 3

#### 03-ATT-03

Project No.	4786338356	File	E341350	Page	1
Compliance Review					
Conducted by:	Jeffery Chan		Jeffery Chan	Date	2014-03-21
	Printed Name		Signature		

CONSTRUCTION COMPLIANCE REVIEW RECORD Sample Identification -

Sample Card	Date	Sample	
No.	Received	No.	Manufacturer, Product Identification and Ratings
1837704	2014-03- 18	1	GLOBTEK (HONG KONG) LTD, MODEL: GTM41080-1812-C1 Input: 90-240Vac, 50-60Hz, 0.6A
			Output: 12Vdc, 1.25A

Measurement Instrument Information -

Inst. ID No.	Instrument Type	Function/ Range	Last Cal. Date	Next Cal. Date
DC003	Digital Caliper	0-150 mm	2013-04-25	2014-04-25

The following additional information is required when using client's or rented equipment, or when a UL ID Number for an instrument number is not used. The Inst. ID No. below corresponds to the Inst. ID No. above.

Inst. ID No.	Make/Model/Serial Number/Asset No.

[ X ] Measurement instrument information is recorded on UL's Laboratory Project Management (LPM) database. (This statement may be selected only if CRDs are completed at a UL facility)

ULS-02377-	-AAAG7-ConstructionReview-2065
Form Page	1

Form Issued: 2004-12-07 Form Revised: 2007-04-19

Copyright © 2012 UL LLC

Only those products bearing the UL Mark should be considered as being covered by UL.

Project No.	4786338356	File E341350	Page 2
Compliance			
Review Conducted by:	Jeffery Chan	Jeffery Chan	Date 2014-03-21
	Printed Name	Signature	

#### CONSTRUCTION COMPLIANCE REVIEW:

The sample was reviewed for compliance with the construction requirements in the standard indicated below and a complete record including measurements to support compliance with those requirements is detailed in Report Reference No. \_\_\_\_E341350-A21\_\_\_\_\_.

Standard(s): CAN/CSA-C22.2 No. 60601-1 (2008) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) Edition 2 -Revision Date 2011/06/01

ANSI/AAMI ES60601-1 (2005 + C1:09 + A2:10) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) - Edition 1 - Revision Date 2012/01/01

IEC 60601-1: 2005 + CORR.1 (2006) + CORR.2 (2007) (Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance) - Edition 3

ULS-02377-AAAG7-ConstructionReview-2065 Form Page 2 Form Issued: 2004-12-07 Form Revised: 2007-04-19

Copyright © 2012 UL LLC

Only those products bearing the UL Mark should be considered as being covered by UL.