

Report No.: 130300588SHA-001/amendment1 Page 1 of 5

| Applicant:        | GlobTek, Inc.  |                                    |             |                  |
|-------------------|--|------------------------------------|-------------|------------------|
| Address:          | 186 Veterans Dr. Northvale, NJ 07647 USA   |                                    |             |                  |
| Product:          | Medical Power Supply   | Base report                        | No.:        | 130300588SHA-001 |
| Brand name:       |  | Base test pro                      | ocedure:    | EMC              |
| Model(s):         | GT*43004P-***-** (see annex for details)   | Base testing                       | laboratory: |                  |
| Ratings and       | see annex for details  | Intertek Testing Services Shanghai |             |                  |
| principal         |  |                                    |             |                  |
| characteristics:  |  |                                    |             |                  |
| Issued by:        | Intertek Testing Services Shanghai   | Test                               | EMC         |                  |
|                   |  | procedure:                         |             |                  |
| Date of issue:    | August 26, 2015  | Standard:                          | *EN60601-1- | -2: 2007/AC:2010 |
| changes and addit | ns updated relative EMC standards to the latest version customer requirement, surge test for 4kV is conducted. | on.                                | -           | _                |

|               | Signature | Print Name  | <u>Title</u>     |
|---------------|-----------|-------------|------------------|
|               | —1 T      | •           |                  |
| Evaluated by: | Jan)ic    | John Jiang  | Project Engineer |
| Approved by:  | $DA^{U}$  | Daniel Zhao | Reviewer         |
| 1.1.          |           |             |                  |



Report No.: 130300588SHA-001/amendment1 Page 2 of 5

| Standard: | *EN60601-1-2: 2007/AC:2010                       |      |
|-----------|--|------|
| No.1      | Mains terminal continuous disturbance voltage    | Pass |
| No.2      | Mains terminal discontinuous disturbance voltage | NA   |
| No.3      | Radiated emission                                | Pass |
| No.4      | Harmonic Currents                                | Pass |
| No.5      | Flicks   | Pass |
| No.6      | Electrostatic Discharge (ESD)                    | Pass |
| No.7      | Electric Fast Transient /Burst (EFT/B)           | Pass |
| No.8      | Surge  | Pass |
| No.9      | Injected Current                                 | Pass |
| No.10     | RF electromagnetic field susceptibility          | Pass |
| No.11     | Voltage dips and interruption                    | Pass |
| No.12     | Magnetic Fields                                  | NA   |

Note: The item(s) in "bold & italic" means the additional tests has been performed, and test result will be listed in the ANNEX of this amendment report.



Report No.: 130300588SHA-001/amendment1

Page 3 of 5

#### 12. Surge Immunity Test

Test result Pass

12.1 Severity Level 12.1.1 Test level

| Level | -                           | st voltage +/-10%            |
|-------|-----------------------------|------------------------------|
|       | A.C power line(s) to ground | A.C power line(s) to line(s) |
| 1     | 0.5                         | 0.5                          |
| 2     | 1                           | 1                            |
| 3     | 2                           | Not applicable               |
| 4     | 4                           | 4                            |

Notes: 1. The gray rows were the test level which is demanded by customer.

- 2. The requirements above shall apply to equipment and systems used in all environments. When the expected electromagnetic characteristics of the intended use environment justify higher immunity test levels, these higher immunity test levels shall take precedence.
- 3. All other cables except AC power line are not tested directly, the determination of compliance with this requirement shall be based on the response of the equipment or system, considering each surge individually, taking into account the effects of any coupling between cables that are tested directly and cables that are not tested directly.

#### **12.1.2** Compliance Level

Lower immunity compliance levels are allowed, provided they are justified based on significant physical, technological or physiological limitations.


| Test Items           | Highest Compliance Level | Electromagnetic Environment |
|----------------------|--------------------------|-----------------------------|
| A.C power line(s) to | 2                        | All environments            |
| ground               | Others                   | Others                      |
| A.C power line(s) to | 1                        | All environments            |
| line(s)              | Others                   | Others                      |
| N - 4 Tl             | 41 1 4 1 1 4             |                             |

Notes: The gray rows were the selected object.



Report No.: 130300588SHA-001/amendment1
Page 4 of 5

## 12.2 Block Diagram of Test Setup



#### 12.3 Test Setup and Test Procedure

Measurement was performed in shielded room.

Measurement and setting of EUT was applied according to IEC61000-4-5 clause 7.

The test method and equipment is specified by IEC61000-4-5 with modifications by IEC60601-1-2 clause 36.202.5(b).



Report No.: 130300588SHA-001/amendment1 Page 5 of 5

#### 12.4 Test Protocol

Temperature: 26°C Relative Humidity: 45%

| Test No. | Test level | Phase     | Polarity  | Diff./ | Result |
|----------|------------|-----------|-----------|--------|--------|
|          | kV         | 0         |           | Com.   |        |
| 1        | 0.5        | 0°,90°,   | +/-, L-PE | Com.   | NA     |
|          |            | 180°,270° |           |        |        |
| 2        | 0.5        | 0°,90°,   | +/-, N-PE | Com.   | NA     |
|          |            | 180°,270° |           |        |        |
| 3        | 1          | 0°,90°,   | +/-, L-PE | Com.   | NA     |
|          |            | 180°,270° |           |        |        |
| 4        | 1          | 0°,90°,   | +/-, N-PE | Com.   | NA     |
|          |            | 180°,270° |           |        |        |
| 5        | 2          | 0°,90°,   | +/-, L-PE | Com.   | NA     |
|          |            | 180°,270° |           |        |        |
| 6        | 2          | 0°,90°,   | +/-, N-PE | Com.   | NA     |
|          |            | 180°,270° |           |        |        |
| 7        | 4          | 0°,90°,   | +/-, L-N  | Diff.  | Pass   |
|          |            | 180°,270° |           |        |        |

Notes: "NA" means not applicable.

**Observation:** All the functions were operated as normal during and after test.

Conclusion: providing the essential performance and remaining safe

#### 12.5 Measurement Uncertainty

None

The measurement uncertainty describes the overall uncertainty of the given measured value during the operation of the EUT.

Measurement uncertainty of surge test at main terminal is:  $\pm$  18.8%

Measurement uncertainty of surge test at signal/telecom terminal is:  $\pm 19.3\%$ 

The measurement uncertainty is given with a confidence of 95%, k=2.

The measurement uncertainty is traceable to internal procedure TI-036.

### 12.6 Additions, deviations and exclusions from standards