

# Poročilo o preskusu / Test Report

Št. / No.:

T211-0475/12

Datum / Date:

2012-10-08

<b>Proizvod / Product</b>	<b>Listov / Pages</b>
Power supply Model: GT-21089-WWVV-X.X-W2Z series Enclosure: WR91A2600CCP-Y(R)	4
<b>Naročnik / Applicant</b>	<b>Vrsta preskusa / Test procedure</b>
GlobTek, Inc 186 Veterans Dr, Northvale, NJ 07647 / USA	IP41
<b>Proizvajalec / Manufacturer</b>	<b>Št. Merjencev / No. of Items tested</b>
GlobTek, Inc 186 Veterans Dr, Northvale, NJ 07647 / USA	1
<b>Blagovna znamka / Trade Mark</b>	<b>Mapa predmeta št. / Subject File No.</b>
GlobTek	C20121557
<b>Standardi – predpisi / Standards - regulations</b>	<b>Kraj preskusa / Place of test</b>
IEC 60529:2001	SIQ - Slovenian Institute of Quality and Metrology, Tržaška 2, 1000 Ljubljana, Slovenia
	<b>Opomba / Remark</b>
	/

## Zaključek / Conclusion

**Tested product complies with the requirements of stated standards for protection degree IP 41.**

The test results relate only to the items tested.

Date of receipt of test items: 2012-07-16

Date of performance of tests: 2012-07-16 to 2012-09-19

Testni laboratorij je akreditiran pri Slovenski akreditaciji, reg. št.: LP-009 /  
Testing Laboratory is accredited by Slovenian Accreditation, Reg. No. LP-009

Odgovoren za preskušanje / Responsible for the test

Vodja področja / Department Manager

Mirko Čokor  


dr. Miha Otrin  


Slovenski institut za kakovost in meroslovje • Slovenian Institute of Quality and Metrology  
Tržaška cesta 2, SI-1000 Ljubljana, Slovenia • t: +386 1 4778 100 • f: +386 1 4778 444 • e: info@siq.si • http://www.siq.si  
Razmnoževanje poročila, razen v celoti, ni dovoljeno / This report shall not be reproduced except in full

## 1 TEST EQUIPMENT

- Rigid test wire diameter of 1 mm as specified by the standard (2013-01-22),
- Test device for verification of protection against vertically falling water drops-drip box-SIQ

Note: The date of the recommended recalibration is given for each measuring instrument (in brackets).

## 2 EQUIPMENT UNDER TEST (EUT)

Power supply, model GT-21089-WWVV-X.X-W2Z series, enclosure WR91A2600CCP-Y(R) was subjected to testing for IP41 degree of protection (Figures 1 and 2).



Figure 1



Figure 2

### IP41 numeric description:

The first characteristic numeral **X**: indicates the degree of protection against access to hazardous parts and against solid foreign objects. Test equipment for degree 4 is rigid test wire of 1 mm diameter. The protection is satisfactory if the rigid wire does not fully penetrate and adequate clearance is kept.

The second characteristic numeral **Y** indicates the degree of protection provided by enclosures with respect to harmful effects on the equipment due to the ingress of water (degree 1-protected against dripping water). If any water has entered shall have no harmful effects.

## 3 TEST CONDITIONS

During the testing the power supply was connected to the socket outlet, see Figure 3. The plug part (Figure 4) with the socket outlet was not subject of the test. Test results do not relate to the whole power supply but only to the enclosure (without the plug part).



Figure 3: sample unit

Socket  
outlet

Plug part



Figure 4: sample unit

**3.1 Test for protection against solid foreign objects-IP4X (IEC 60529, tables 2 and 7, sub-cl. 13.2)**

Procedure:

- Environmental temperature 23<sup>0</sup>C,
- Rigid test wire diameter of 1 mm (as specified by the standard) is pushed against any openings of the enclosure with the force of 1 N,
- Non-operating condition

**Conclusion:** The rigid test wire was not penetrated into the enclosure.

**3.2 Tests for protection against ingress of water-IPX1 (IEC 60529, table 8, sub-cl. 14.2.1)**

Procedure:

- Test device, drip box-as specified in standard,
- Water flow rate: 1 mm/min,
- The test sample was placed on the turntable under the drip box in most unfavorable normal position (Figures 5 and 6),
- Duration of the exposure: 10 minutes,



Figure 5



Figure 6

**Conclusion:** After the water test there was no water inside the enclosure (Figures 7 and 8).

**4 CONCLUSIONS**

After the exposure was concluded, the visual examination of the sample was performed. Results were obtained as follows:

- The rigid test wire was not penetrated into the enclosure
- After the IPX1 test there was NO water inside the enclosure.

**Result:** Following the acceptance conditions, the equipment under test sustained the test conditions for IP41 degree of protection. The test results relate to the enclosure of the power supply without the plug part.






Figure 7




Figure 8