


This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	GlobTek, Inc.	Manufacturer:	GlobTek (Suzhou) Co., Ltd.
Address:	186 Veterans Drive NORTHVALE NJ 07647	Address:	Building 4 No. 76 JinLing East Road Suzhou Industrial Park SUZHOU Jiangsu 215021
Country:	USA	Country:	China
Contact:	Hans Moritz	Contact:	Demon Zhou
Phone:	(201)784-1000 Ext.253	Phone:	86 512 6279 0301 Ext.189
FAX:	(201)784-0111	FAX:	86 512 6279 0355
Email:	Moritzh@globtek.com	Email:	demon.zhou@globtek.cn
Party Authorized To Apply Mark:	Same as Manufacturer		
Report Issuing Office:	INTERTEK TESTING SERVICES SHANGHAI LIMITED		
Control Number:	<u>4007497</u>	Authorized by:	 for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	Medical Electrical Equipment - Part 1: General Requirements For Basic Safety And Essential Performance [AAMI ES60601-1:2005 +A1]
	Medical Electrical Equipment - Part 1: General Requirements for Basic Safety and Essential Performance (R2018) [CSA C22.2#60601-1:2014 Ed.3]
	Medical Electrical Equipment Part 1-11: General Requirements For Basic Safety And Essential Performance Collateral Standard - Requirements For Medical Electrical Equipment And Medical Electrical Systems Used In The Home Healthcare Environment [IEC 60601-1-11:2015 Ed.2]
	Medical Electrical Equipment - Part 1-11: General Requirements For Basic Safety And Essential Performance - Collateral Standard: Requirements For Medical Electrical Equipment And Medical Electrical Systems Used In The Home Healthcare Environment [CSA C22.2#60601-1-11:2015 Ed.2]
Product:	Medical Power Supply
Brand Name:	 GlobTek, Inc.

Models:

GT followed by M, - or H; followed by 96180- or 96300- or 91120-; followed by 01 to 36; followed by 07.5, 10.5, 14.5, 19.5, 24, 36, 48, 54, 56, 07, 11, 17.9, 30, 38, 48, 54 or 56 ; may be followed by -0.01 to -12.0; maybe followed by -T2, -T2A, -T3, -T3A, -R2, -R3A, -F, -FW, -P2 or -P3; may be followed by -AP, -PP or -SP; may be followed by six characters.

GTM91128LI followed by 1, 2 or 3; followed by CEL; may be followed by M; may be followed by -R2, -T2 or -T2A; followed by -042, -084 or -126; followed by 01 to 20; may be followed by 050 to 140; may be followed by 01 to 36.

GTM91128 followed by two characters; followed by CHRGE or DUALC; may be followed by -R2, -T2 or -T2A; followed by -032 to -126; followed by 01 to 20; may be followed by 050 to 140; may be followed by 01 to 36.